



SRB Technologies (Canada) Inc.

320-140 Boundary Road
Pembroke, Ontario
K8A 6W5

2023 Annual Compliance and Performance Report

Reporting Period: January 1 – December 31, 2023

Licence Number: NSPFL-13.00/2034

Licence Condition: 3.2

This page has been left blank intentionally.

SRB Technologies (Canada) Inc.

2023 Annual Compliance and Performance Report

Submission date: March 28, 2024

Submitted to: **Lester Posada**
Project Officer
Canadian Nuclear Safety Commission

Prepared by: **Jamie MacDonald**
Manager - Health Physics and Regulatory Affairs
SRB Technologies (Canada) Inc.




Signature

Reviewed by: **Katie Levesque**
Executive Assistant
SRB Technologies (Canada) Inc.




Signature

Reviewed by: **Ross Fitzpatrick**
Vice President
SRB Technologies (Canada) Inc.



Signature

Approved by: **Stephane Levesque**
President
SRB Technologies (Canada) Inc.



Signature

This page has been left blank intentionally.

Executive Summary

SRB Technologies (Canada) Incorporated (SRBT) is pleased to provide this compliance and performance report to the Canadian Nuclear Safety Commission (CNSC) as part of our licensed activities.

Our facility continues to process tritium safely, responsibly and efficiently, and we are proud of the level of performance and improvements achieved during 2023. No nuclear safety-related events or significant safety-related issues occurred, and the safety of workers, the public and the environment was maintained at all times.

In 2023, SRBT processed 23,202,623 GBq of tritium into self-luminous light sources and safety devices; in comparison, in 2022, a total of 26,940,372 GBq of tritium was processed.

The ratio of the amount of tritium released to atmosphere versus the amount of tritium processed during the year remained very low (0.09%). This ratio met our annual internal target of 0.11%, and was slightly lower than the ratio achieved in 2022 (0.10%).

Tritium oxide releases to atmosphere fell in 2023 in comparison to the year previous, with 6,540 GBq of oxide being released (vs. 8,816 GBq in 2022).

The total amount of tritium (elemental + oxide) released to the environment through the gaseous effluent pathway decreased (20,520 GBq) compared with the previous year (26,590 GBq).

The average weekly rate of gaseous tritium releases met our target for 2023; on the average, 395 GBq of tritium was released weekly, versus our target of 625 GBq per week.

Once again, no staff member exceeded 1 mSv for the year – a value that represents the dose limit to the public. As well, no action levels were exceeded with respect to radiation doses. This is a testament to the continued diligence of our workers in maintaining radiation exposures as low as reasonably achievable.

The conservatively-calculated dose to the most-exposed member of the public remains far less than 1% of the prescribed annual limit of 1 mSv, as derived from direct sampling and monitoring of the local environment. Groundwater tritium concentrations continue to respond favorably to modified and optimized processing practices.

In 2023, CNSC staff performed two inspections at the facility, resulting in no identified compliance and improvement items.

Our Financial Guarantee for future decommissioning remains fully funded. The Financial Guarantee does not rely on insurance, letters of credit or third-party resources in order to ensure funding availability for future decommissioning of the facility; the funds are held in escrow for access via a Financial Agreement with the Commission.

We continue to improve and implement a successful and effective Public Information Program, and are striving to work towards a collaborative and open relationship with Indigenous communities in the area.

In summary, 2023 represents a highly successful and safe year of operation for SRBT. Continual improvements in compliance and safety is an ongoing mission, and we will always strive to reduce our operational impact on the environment, and to optimize safety and the effective doses to our workers and the public.

Table of Contents

ACRONYMS AND ABBREVIATIONS		9
LIST OF TABLES		13
LIST OF FIGURES		15
Part	Title	Page
SECTION 1 – INTRODUCTION		
1.1	General Introduction	17
1.2	Facility Operation – Compliance Highlights and Significant Events	18
1.3	Summary of Compliance with Licence and OLCs	21
1.4	Production or Utilization	26
1.5	Changes in Management System Documentation	27
SECTION 2 – MANAGEMENT SCAs		
2.1	SCA – Management System	28
2.2	SCA – Human Performance Management	43
2.3	SCA – Operating Performance	48
SECTION 3 – FACILITY AND EQUIPMENT SCAs		
3.1	SCA – Safety Analysis	53
3.2	SCA – Physical Design	54
3.3	SCA – Fitness for Service	55
SECTION 4 – CORE CONTROL PROCESSES SCAs		
4.1	SCA – Radiation Protection	60
4.2	SCA – Conventional Health and Safety	73
4.3	SCA – Environmental Protection	77
4.4	SCA – Emergency Management and Fire Protection	122
4.5	SCA – Waste Management	126
4.6	SCA – Security	132
4.7	SCA – Safeguards and Non-proliferation	133
4.8	SCA – Packaging and Transport of Nuclear Substances	134

SECTION 5 – OTHER MATTERS OF REGULATORY INTEREST		
5.1	Public Information and Disclosure	136
5.2	Preliminary Decommissioning Plan and Financial Guarantee	141
SECTION 6 – IMPROVEMENT PLANS AND FORECAST		
6.1	Emission Reduction Initiatives	142
6.2	Safety Performance Targets for 2024	143
6.3	Planned Modifications and Foreseen Changes	144
SECTION 7 – CONCLUDING REMARKS		145
SECTION 8 – REFERENCES		147
SECTION 9 – APPENDICES		149

Acronyms and Abbreviations

ACR	Annual Compliance Report / Annual Compliance and Performance Report
AOPFN	Algonquins of Pikwakanagan First Nation
Bq	Becquerel <ul style="list-style-type: none">• MBq → megabecquerel• GBq → gigabecquerel• TBq → terabecquerel
BSI	British Standards Institute
CLC	Canada Labour Code
CLW	Clearance Level Waste
CMD	Commission Member Document
CNL	Canadian Nuclear Laboratories
CNSC	Canadian Nuclear Safety Commission
CSA	Canadian Standards Association
CSM	Conceptual Site Model
CVC	Compliance Verification Criteria
DRL	Derived Release Limit
DS	Downspout
ECR	Engineering Change Request
EffMP	Effluent Monitoring Program
EMP	Environmental Monitoring Program
EMS	Environmental Management System
ERA	Environmental Risk Assessment
FASC	Facility Access Security Clearance
FG	Financial Guarantee
FHA	Fire Hazard Assessment

Acronyms and Abbreviations (continued)

FPP	Fire Protection Program
GMP / GWMP	Groundwater Monitoring Program
GTLS	Gaseous Tritium Light Source
HT	Elemental Tritium
HTO	Tritium Oxide
IAEA	International Atomic Energy Agency
IATA	International Air Transportation Agency
ISO	International Organization for Standardization
IT	Information Technology
LCH	Licence Conditions Handbook
LLW	Low-Level Waste
LSC	Liquid Scintillation Counting
LTI	Lost Time Incident
MDA	Minimum Detectable Activity
MW	Monitoring Well
NCR	Non-Conformance Report
NEW	Nuclear Energy Worker
NIST	National Institute of Standards and Technology
NSCA	Nuclear Safety and Control Act
NSPFL	Nuclear Substance Processing Facility Licence
OBT	Organically Bound Tritium
OFI	Opportunity for Improvement
OLC	Operating Limits and Conditions
PAS	Passive Air Sampler

Acronyms and Abbreviations (continued)

PDP	Preliminary Decommissioning Plan
PFD	Pembroke Fire Department
PIP	Public Information Program
PLC	Professional Loss Control
PUTT	Pyrophoric Uranium Tritium Trap
QA	Quality Assurance
QC	Quality Control
RDU	Remote Display Unit
REGDOC	Regulatory Document
RPD	Relative Percent Difference
RW	Residential Well
SAR	Safety Analysis Report
SASC	Special Annual Sampling Campaign
SAT	Systematic Approach to Training
SCA	Safety and Control Area
SRBT	SRB Technologies (Canada) Incorporated
Sv	Sievert <ul style="list-style-type: none">• mSv → millisievert• µSv → microsievert
T2	Molecular Tritium Gas
TDG	Transportation of Dangerous Goods
TNA	Training Needs Analysis
tSIE	Transformed Spectral Index - External Standard
UL	Underwriters Laboratories
VLLW	Very Low-Level Waste

Acronyms and Abbreviations (continued)

WHMIS	Workplace Hazardous Materials Identification System
WHSC	Workplace Health and Safety Committee
WMP	Waste Management Program
WSIB	Workplace Safety and Insurance Board

List of Tables

TABLE	TITLE	PAGE
1	TRITIUM PROCESSED – FIVE-YEAR TREND	26
2	COMMITTEE MEETINGS	34
3	PROCEDURAL ECR SUMMARY	42
4	NUCLEAR SAFETY TASKS PERFORMED PER WORK AREA	43
5	WORKER QUALIFICATION IN SAT-BASED ACTIVITIES	47
6	TRITIUM RELEASED TO PROCESSED RATIO FIVE-YEAR TREND (2019-2023)	48
7	2023 PERFORMANCE TARGETS	49
8	DEPLETED URANIUM INVENTORY BREAKDOWN AT THE END OF 2023	51
9	ACTION LEVELS FOR RADIATION PROTECTION	61
10	ADMINISTRATIVE LIMITS FOR RADIATION PROTECTION	62
11	ADMINISTRATIVE LIMITS FOR SURFACE CONTAMINATION	68
12	PASS RATE FOR CONTAMINATION ASSESSMENTS (2019-2023)	68
13	ZONE ALARMS (2019-2023)	70
14	LOST TIME INCIDENTS FIVE-YEAR TREND (2019-2023)	74
15	REPORTING REQUIREMENTS (N288.4-10)	81
16	REPORTING REQUIREMENTS (N288.5-11)	82
17	REPORTING REQUIREMENTS (N288.7-15)	83
18	PRECIPITATION MONITORING FIVE-YEAR TREND (2019-2023)	85
19	DOWNSPOUT RUNOFF MONITORING FIVE-YEAR TREND (2019-2023)	87
20	EMP QUALITY CONTROL DATA (2019-2023)	93

List of Tables (continued)

TABLE	TITLE	PAGE
21	GASEOUS EFFLUENT DATA (2023)	96
22	GASEOUS EFFLUENT FIVE-YEAR TREND (2019-2023)	97
23	TRITIUM RELEASED TO ATMOSPHERE VS. PROCESSED (2019-2023)	97
24	LIQUID EFFLUENT DATA (2023)	98
25	LIQUID EFFLUENT FIVE-YEAR TREND (2019-2023)	98
26	2015-2023 AVERAGE TRITIUM CONCENTRATION IN MONITORING WELLS	106
27	SLUDGE MONITORING (2019-2023)	110
28	CSA GUIDELINE N288.1-14 EFFECTIVE DOSE COEFFICIENTS FOR H-3	111
29	CSA GUIDELINE N288.1-14 INHALATION RATES	112
30	CSA GUIDELINE N288.1-14 WATER CONSUMPTION RATES	113
31	CSA GUIDELINE N288.1-14 PRODUCE CONSUMPTION RATES	115
32	CSA GUIDELINE N288.1-14 MILK CONSUMPTION RATES	117
33	2023 REPRESENTATIVE PERSONS ANNUAL DOSE BASED ON EMP	118
34	RADIOACTIVE WASTE CONSIGNMENTS (2023)	127
35	INTERIM STORAGE OF LOW-LEVEL WASTE (ZONE 3)	128
36	CLEARANCE-LEVEL WASTE (2023)	129
37	OUTGOING SHIPMENTS OF PRODUCT FIVE-YEAR TREND (2019-2023)	134
38	INCOMING SHIPMENTS OF PRODUCT FIVE-YEAR TREND (2019-2023)	135
39	FACILITY TOURS (2023)	137
40	SAFETY AND PERFORMANCE TARGETS FOR 2024	143

List of Figures

FIGURE	TITLE	PAGE
1	ORGANIZATIONAL CHART	30
2	MANAGEMENT SYSTEM DOCUMENTS	41
3	MAXIMUM ANNUAL WORKER DOSE (2019-2023)	64
4	WORKER DOSE DISTRIBUTION (2023)	64
5	AVERAGE ANNUAL WORKER DOSE – ALL NEW (2019-2023)	65
6	AVERAGE ANNUAL WORKER DOSE – NON-ZERO DOSES (2019-2023)	66
7	COLLECTIVE DOSE (2019-2023)	67
8	CONCEPTUAL SITE MODEL	78
9	HUMAN EXPOSURE PATHWAYS (HTO/T2, GASEOUS SOURCES)	79
10	HUMAN EXPOSURE PATHWAYS (HTO/T2, LIQUID SOURCES)	79
11	CONCEPTUAL ECOLOGICAL MODEL – TERRESTRIAL	80
12	CONCEPTUAL ECOLOGICAL MODEL – AQUATIC / RIPARIAN	80
13	RESIDENTIAL WELL TRITIUM CONCENTRATION TREND (2006-2023)	91
14	MW06-10 AVERAGE TRITIUM CONCENTRATION TREND (2006-2023)	103
15	MW06-10 FIVE-YEAR TREND (2019-2023)	103
16	MW07-13 AVERAGE TRITIUM CONCENTRATION TREND (2007-2023)	104
17	MW07-13 FIVE-YEAR TREND (2019-2023)	105
18	PUBLIC DOSE FIVE-YEAR TREND (2019-2023)	119

This page has been left blank intentionally.

1. Introduction

1.1 General Introduction

For the period of January 1 – December 31, 2023, SRB Technologies (Canada) Inc. (SRBT) operated a tritium processing facility in Pembroke, Ontario, under Nuclear Substance Processing Facility Licence NSPFL-13.00/2034^[1], issued by the Canadian Nuclear Safety Commission (CNSC).

The facility was operated in compliance with the regulatory requirements of the *Nuclear Safety and Control Act* (NSCA), our operating licence, and all other applicable federal, provincial and municipal regulations throughout the review period. As well, no new CNSC-licensed activities were implemented since the previous compliance monitoring report.

Compliance was ensured by the continued implementation of our Management System and associated programs and procedures, coupled with a high level of independent internal and external oversight through audit and inspection activities.

During this period, there were no exceedances of environmental or radiation protection action levels, nor licence / regulatory limits associated with our operating licence. No events occurred during the year which were deemed to meet criteria for reporting to CNSC staff.

The SRBT operating licence includes conditions that require SRBT to prepare and submit an annual compliance report (ACR). This requirement is currently defined as part of the compliance verification criteria (CVC) in the Licence Conditions Handbook (LCH)^[2] relating to condition 3.2 of NSPFL-13.00/2034, which states:

Annual Reporting

The licensee shall submit an annual compliance report by March 31 of each year, covering the operation for the 12-month period from January 1 to December 31 of the previous year that meets the requirements of section 3 of REGDOC-3.1.2.

The purpose of this report is to provide the required information in order to meet the requirements of conditions 3.2 of Licence NSPFL-13.00/2034, and the CVC in the associated LCH.

The information is reported in a format which meets the requirements of CNSC Regulatory Document 3.1.2, *Reporting Requirements, Volume I: Non-Power Reactor Class I Nuclear Facilities and Uranium Mines and Mills*^[3], SRBT's Regulatory Reporting Program, and in consideration of regulatory feedback and comments regarding previous ACRs submitted in the past.

1.2 Facility Operation – Compliance Highlights and Significant Events

SRBT conducted its licenced activities safely and compliantly throughout 2023.

1.2.1 Tritium Processing

In 2023, SRBT conducted 3,962 tritium processing operations (light source filling), with a total of 23,202,623 GBq of tritium being processed into gaseous tritium light sources (GTLS).

Please refer to section 1.4, 'Production or Utilization' for additional details on tritium processing in 2023.

1.2.2 Distribution of Self-luminous Safety Products

In 2023, 739 shipments of our self-luminous safety products were made to customers in 15 different countries, including Canada.

Please refer to section 4.8, 'SCA – Packaging and Transport of Nuclear Substances' for additional details on the distribution of our products in 2023.

1.2.3 Acceptance of Expired Products

In 2023, a total of 11,027 expired (or otherwise removed from service) self-luminous safety 'EXIT' type signs were accepted by SRBT from Canadian and American sources, representing a total activity of 1,642.39 TBq of tritium. In 2022, 15,492 signs were processed representing 2,116.61 TBq of tritium.

These signs were disassembled safely and the light sources removed. A very small number of these signs were evaluated as having light sources that could be reused in other self-luminous devices. Lights that could not be repurposed were packaged and shipped to a licenced radioactive waste management service provider.

As well, an additional 119.38 TBq of tritium was accepted from international origins (i.e. other than Canada and the United States) in the form of expired tritium illuminated devices, such as aircraft signs, dials, gauges and other smaller equipment. These were also processed for shipment to a licenced waste management facility.

Please refer to section 4.5, 'SCA – Waste Management' and section 4.8, 'SCA – Packaging and Transport of Nuclear Substances' for additional details on the acceptance of expired self-luminous safety signs in 2023.

1.2.4 External Oversight

During the year, there were a total of ten major inspections or audits conducted by stakeholders and external parties on our operations.

CNSC staff conducted compliance inspections on two occasions in 2023; a general inspection was conducted in March^[4], and an inspection focused on Fitness for Service was conducted in September^[5]. No risk-significant findings or non-compliances were identified through either inspection activity.

BSI Management Systems, on behalf of the International Organization for Standardization (ISO), conducted a major audit in September 2023, which concluded that SRBT continues to effectively manage our operations in a fashion that ensures the elements of the scope of our certification with ISO 9001 are effectively addressed, and confirmed our continued certification.

One major customer of SRBT products conducted an independent audit of our operations in October 2023, while Underwriters Laboratories (UL) completed four quarterly audits as planned.

Additional details on the above noted external oversight of SRBT operations can be found in section 2.1, 'SCA – Management System'.

Two focused facility inspections were conducted relating to fire protection. Both the Pembroke Fire Department (PFD) and Professional Loss Control (PLC) inspected the facility in 2023.

Details on fire protection-related inspections and audits can be found in section 4.4, 'SCA – Emergency Management and Fire Protection'.

1.2.5 Internal Oversight

Five internal compliance audits were conducted through the year, focused on all aspects of our operations and our organization. A total of three non-conformance reports and seven opportunities for improvement were identified as a result of these activities, all of which have been addressed (or are in the process of being addressed) by the responsible managers.

Additional details on internal oversight of SRBT operations can be found in section 2.1, 'SCA – Management System'.

1.2.6 Reported Events

SRBT did not experience any events that met the regulatory criteria for unplanned event reporting in 2023. Event reporting is governed by the SRBT Regulatory Reporting Program.

1.2.7 Operational Challenges

SRBT did not experience any notable operational challenges in 2023.

1.2.8 Summary of Significant Modifications

No significant modifications were implemented in the facility which pertain to our licensed activities in 2023, and there were no changes to the self-luminous safety light production capacity of the facility.

All minor and non-safety significant modifications to structures, systems and components were conducted in accordance with our change control processes.

Please refer to section 3.2, 'SCA – Physical Design', for more information regarding notable facility modifications carried out in 2023.

1.2.9 Summary of Organizational Structure and Key Personnel

At the conclusion of 2023, SRBT employed 38 employees and managers. No structural changes to the organization were implemented in 2023.

Please refer to section 2.1, 'SCA – Management System' for details regarding SRBT's organizational structure in 2023.

1.3 Summary of Compliance with Licence and OLCs

Throughout 2023, SRBT complied with the conditions of our operating licence^[1], and possessed, transferred, used, processed, managed, stored and disposed of all nuclear substances and radiation devices related to and arising from the operation of the facility in compliance with regulatory requirements.

Specifically:

- All required programs have been implemented and maintained,
- The CNSC was notified as required of changes to the programs, processes and documents referenced in the management system / licensing basis,
- All required records have been established and maintained pursuant to the operating licence, the Nuclear Safety and Control Act and its regulations,
- All pertinent notifications were made, and written reports filed, within prescribed periods,
- An accepted decommissioning strategy continues to be maintained for future use,
- An accepted financial guarantee continues to be maintained for future decommissioning,
- Cost recovery fees were paid on time and in full, and
- Limits on releases of tritium to the atmosphere and sewer, and radiation dose limits to the public and SRBT nuclear energy workers were not exceeded.

SRBT also remained in compliance with requirements of all other federal and provincial regulations as pertaining to the operation of the facility, including the Canada Labour Code and associated regulations, as well as provincial regulations with respect to the management of hazardous materials and waste.

The following summary report is provided respecting SRBT compliance with the Operating Limits and Conditions (OLC) established within our Safety Analysis Report^[6] (SAR) throughout the course of 2023.

Each applicable OLC is repeated below, with a statement of compliance.

1.3.1 Tritium Possession Limit

SRBT is authorized by licence to possess up to 6,000 TBq of tritium in any form.

SRBT possessed less than 6,000 TBq of tritium at all times during 2023.

Please refer to section 2.3, 'SCA – Operating Performance' for more details.

1.3.2 Tritium Processing – Permitted Hours of Operation

Tritium processing operations consist of filling and sealing of gaseous tritium light sources (GTLS) on processing rigs, laser cutting of GTLS, or bulk splitting operations.

Tritium processing operations are restricted to 0700h – 1900h, seven days a week, unless specifically approved by senior management.

Senior Management continued to approve tritium processing operations to commence at 0600h, adding one hour of potential processing time to each operating day. No tritium processing operations occurred outside of this time period in 2023.

This authorization was granted in order to accommodate a more flexible scheduling arrangement with workers, and to help optimize production throughput during a period of high product demand.

This change remained in place for the entirety of 2023. This change in work scheduling did not result in any safety-related impact on workers, members of the public or the environment.

Originally, the 0700h – 1900h operating time period was enacted in order to align operating hours with the chosen 12-hour time period used in establishing the meteorological parameters which form an input of the facility derived release limits (DRL), such as average wind speed and direction.

As the release limits for gaseous effluent established for the facility are not related to the calculated DRLs (rather, they are established at far lower levels intended to ensure protection of groundwater resources), there are no significant technical or safety-related reasons to restrict operations to this time period.

This OLC has been formally removed from the SRBT SAR as of December 4, 2023, and will no longer be reported on in future annual compliance reports.

1.3.3 Tritium Processing – Precipitation

Tritium processing shall not occur during measurable periods of precipitation, as detected by the precipitation detection system or equivalent.

Tritium processing operations were only conducted during periods where measurable precipitation was not occurring during 2023.

Processing operations were ceased and equipment placed into a safe state when precipitation events occurred during operating hours.

1.3.4 Tritium Releases to Atmosphere – Tritium Oxide

SRBT shall not release in excess of $6.72\text{E}+13$ Bq of tritium oxide to atmosphere in any year.

The total amount of tritium oxide (HTO) released to atmosphere in 2023 was equal to $6.542\text{E}+12$ Bq (6,540 GBq), representing 9.7% of this licenced limit.

Please refer to section 4.3 'SCA – Environmental Protection' for more details.

1.3.5 Tritium Releases to Atmosphere – Tritium Oxide + Elemental

SRBT shall not release in excess of $4.48\text{E}+14$ Bq of total tritium as tritium oxide and tritium gas to atmosphere in any year.

The total amount of combined HTO and elemental tritium (HT) released to atmosphere in 2023 was equal to $2.05\text{E}+13$ Bq (20,520 GBq), representing 4.6% of this licenced limit.

Please refer to section 4.3 'SCA – Environmental Protection' for more details.

1.3.6 Minimum Differential Pressure Measurements for Tritium Processing

Tritium processing operations shall not occur unless the following differential pressures are achieved, as measured by the gauges on each of the active ventilation system stacks:

- Rig Stack: 0.27 inches of water column
- Bulk Stack: 0.38 inches of water column

These measurements correspond to an average effective stack height of 27.8 metres, assuming a wind speed of 2.2 m/s.

At no time did tritium processing occur during 2023 when the noted differential pressures were not being achieved, as measured daily prior to operations commencing.

1.3.7 Tritium Releases to Sewer – Water-soluble Tritium

SRBT shall not release in excess of $2.00\text{E}+11$ Bq of water-soluble tritium to the municipal sewer system in any year.

The total amount of water-soluble tritium released to the municipal sewer in 2023 was equal to $6.80\text{E}+08$ Bq, representing 0.34% of this licenced limit.

Please refer to section 4.3 'SCA – Environmental Protection' for more details.

1.3.8 PUTT Filling Cycles

Any pyrophoric uranium tritium trap (PUTT) base is limited to 30 complete bulk splitter filling cycles, after which it is no longer permitted to be used for further tritium processing.

All tritium processing in 2023 was conducted using PUTTs that had been cycled 30 times or less on the bulk splitter.

1.3.9 PUTT / Bulk Container Tritium Loading Limit

PUTTs are limited to less than 111,000 GBq of tritium loading at any time.

Bulk containers are limited as follows:

- SRBT shall request no more than 925,000 GBq per bulk container when submitting a purchase order to an approved supplier of tritium gas.
- No bulk container shall exceed 1,000,000 GBq of tritium loading at any time.

In 2023, no PUTT was loaded with more than 111,000 GBq of tritium.

No bulk container was used in the facility in excess of the 1,000,000 GBq loading limit.

1.3.10 Bulk Container Heating Limit

Bulk tritium containers are limited to a heating temperature of approximately 550°C, as measured by the thermocouple placed between the heating band and the container surface.

Brief and small exceedances of this value are tolerable so long as they are not sustained, and the temperature is returned below this value as soon as possible.

Bulk tritium container heating operations were conducted in compliance with this limit throughout 2023.

1.3.11 On-site Depleted Uranium Inventory

The on-site physical inventory of depleted uranium (virgin, in use and decommissioned bases) is limited to 10 kg.

The on-site inventory of depleted uranium did not exceed 10 kg in 2023.

Please refer to section 2.3, 'SCA – Operating Performance' for more details on inventory controls of depleted uranium in 2023.

1.3.12 Exceedances of Facility Action Levels

There were no exceedances of radiation protection or environmental protection action levels in 2023.

1.4 Production or Utilization

1.4.1 Tritium Processing

In 2023, a total of 23,202,623 GBq of tritium was processed. This represents a decrease of about 15% from the 2022 value of 26,940,372 GBq.

The following table is presented to illustrate the five-year history of tritium processing at SRBT.

TABLE 1: TRITIUM PROCESSED – FIVE-YEAR TREND

YEAR	2019	2020	2021	2022	2023
TRITIUM PROCESSED (GBq)	30,327,048	27,887,498	29,392,257	26,940,372	23,202,623

1.4.2 Tritium Possession

SRBT is restricted by licence to possess no more than 6,000 TBq of tritium in any form at the facility at any time.

Throughout 2023, this possession limit was not exceeded. The maximum tritium activity possessed at any time during 2023 was 4,960 TBq in December. The monthly average inventory of tritium in the facility was 2,752 TBq.

At all times, unsealed source material was stored on tritium traps or in the handling volumes of tritium processing equipment.

The monthly data of tritium activity on site during calendar year 2023 can be found in **Appendix A** of this report.

1.5 Changes in Management System Documentation

In 2023, SRBT revised several key program-level management system documents associated with our licensing basis, following the change control provisions of our Licence Conditions Handbook^[2]. These included the Fire Protection Program, Fire Safety Plan, Security Program, and Radiation Safety Program.

As well, the SRBT SAR^[6] was revised and updated, in line with the requirement to review this key licensing-basis document every five years.

In line with our mission and policy of continual improvement, process and procedure assessment and associated revision continued to be a managerial focus throughout the year.

In 2023, a total of 47 Engineering Change Requests were generated to control the revision and review of programs, procedures or forms, or to manage other changes in the facility structures, systems and components.

Specific details on the changes in documentation can be found in section 2.1, 'SCA – Management System'.

2. Management SCAs

2.1 SCA – Management System

Throughout 2023, the SRBT Management System was effectively and thoroughly implemented, ensuring that our nuclear substance processing facility operations continued to meet the requirements detailed in our LCH^[2], including key elements such as organization and responsibilities, capability of personnel, use of experience, work planning and control, process and change control, independent verification, non-conformance and corrective action.

A total of 40 non-conformance reports (NCR) and 33 opportunities for improvement (OFI) were raised in different areas of the company operations.

As of the end of 2023, 31 out of the 40 NCRs raised in 2023 had been addressed, reviewed for effectiveness and closed. The remaining 9 NCRs are still in progress due to the fact that they were raised in the later part of the year, or due to relative longer timeframes for the actions that are to be taken to resolve the issues identified.

For OFIs, 15 out of the 33 raised in 2023 have been addressed, reviewed for effectiveness and closed. The remaining 18 OFIs were either raised later in the year, and/or were assigned target completion due dates that have not yet been reached, and will be reviewed as per normal processes as they are addressed.

SRBT affirms that corrective actions and opportunities for improvement have been effective at resolving problems and promoting the concept of continual improvement within our management system in 2023.

Organizational Management Reviews were conducted in early 2023 by all program owners and responsible managers, including benchmarking and self-assessment activities. These reviews were focused on the 2022 calendar year. Reports were submitted to the Executive Assistant in preparation for the annual Management Review.

On August 15th, 17th and 23rd, the annual Management Review was conducted by way of a series of one-on-one meetings between key members of the Executive Committee and each of the individual program owners and responsible managers.

A follow-up meeting took place on September 7th, 2023 with all program owners and responsible managers in attendance. The group reviewed the summary of open actions listed in the Management Review meeting, and several topics were discussed.

The results of benchmarking and self-assessment activities performed for the previous calendar year were reviewed and discussed, and areas where improvements could be made in the various company safety programs were highlighted.

The management system was found to be effective at meeting the current requirements of the NSCA, associated regulations and the conditions of the operating licence, as well as ISO 9001:2015, and customer requirements.

The 2023 Organizational Management Reviews are scheduled to take place in the second quarter of 2024, followed by Senior Management meetings to discuss the outputs of the reviews with responsible managers, and the identification of any opportunities for improvements, actions required to mitigate risks, and compliance or performance issues.

2.1.1 Staffing and Organization

At the beginning of 2023, SRBT total staff complement stood at 40 employees.

Two new employees were hired during the year, and four employees left the employ of the company in 2023.


As of the end of 2023, the total working staff complement stood at 38 employees.

The organizational chart in Figure 1 represents the structure of the company, as of the end of 2023, that ensures SRBT meets *the Nuclear Safety and Control Act*, regulations and conditions of our operating licence.

FIGURE 1: ORGANIZATIONAL CHART

SRBT Organizational Structure

This chart depicts the relationships of our people.



Sixteen administrative employees and twenty-two production / technician-level employees work at SRBT at the conclusion of the year.

Administrative employees include the two members of Top Management:

- President has the overall responsibility for the facility and ensures that all licensing requirements are met.
- Vice President assumes the full duties of the President in his absence or otherwise assists the President's in his duties.

At the conclusion of 2023, the administrative employees also include nine individuals at the Organizational Management level:

- Quality Manager is mainly responsible for ensuring the quality of products and the satisfaction of customers. They also provide input ensuring that our management system meets the requirements of the ISO 9001 standard.
- Logistics Manager is mainly responsible for the shipment, receipt and inventory control of radioactive materials, as well as import and export activities.
- Executive Assistant is mainly responsible for providing administrative support to the President, and for ensuring meeting minutes are recorded.
- Production Control Manager is mainly responsible for all company purchasing and production planning activities, and the distribution of work packages.
- Project Engineer is mainly responsible for developing and maintaining product specifications and manufacturing procedures, product research and development, and oversight of the change control process.
- Account Manager is mainly responsible for all company accounting activities.
- Manager – Safety and Security is mainly responsible for ensuring staff health and safety and ensuring compliance with the health and safety provisions of the *Canada Labour Code*, the *Canada Occupational Health and Safety Regulations*, and support for the Security Program.
- Compliance Manager is mainly responsible for performing independent internal audits and further ensuring facility compliance with external and internal requirements.
- Manager of Health Physics and Regulatory Affairs is mainly responsible for oversight of all company Health Physics activities, as well as communicating with CNSC staff on regulatory matters.

Five employees provide program oversight and/or directly assist individuals at the management support level,

- Graphic Design Specialist is responsible for coordinating changes to the company website, and for the design and development of public information products and sales literature.
- IT Specialist manages and maintains the facility computer network and provides a wide range of technical and engineering support.
- Fire Protection Specialist ensures that facility fire safety procedures are implemented, and for coordinating with the PFD for drills, inspection and training. This individual is also responsible for the day-to-day management of maintenance activities in the facility.
- Inventory Control Assistant oversees the receipt of all materials, including quality evaluation where applicable, and for general stores and materials.
- Assistant Manager – Health Physics is responsible for the day-to-day implementation of company Health Physics-related programs and processes, including coordinating the activities of technician-level resources assigned to the department.

At the technician level, there are two technician-level organizational positions within the Health Physics department:

- Environmental Protection Technician is primarily responsible for performing duties relating to environmental protection and monitoring.
- Radiation Protection Technician performs duties relating primarily to radiation protection.
- *NOTE: as of the end of 2022 this position was unstaffed; all responsibilities are being shared between the Assistant Manager – Health Physics and the Environmental Protection Technician, under the oversight of the Manager – Health Physics and Regulatory Affairs.*

Twenty-one production-focused employees include six Production Supervisors:

- Glass Shop Supervisor is responsible for all the activities within the Glass Shop Department.
- Coating Supervisor is responsible for all the activities within the Coating Department.
- Rig Room Supervisor is responsible for all the activities within the Rig Room Department.

- Assembly Supervisor is responsible for all the activities within the Assembly Department.
- Machining and Molding Supervisor is responsible for all the activities within the Machining and Molding Department.

These supervisors oversee the work of fifteen Production Technicians, who are responsible for performing production activities in accordance with company manufacturing procedures.

Throughout 2023, all safety-significant positions in the organization were staffed with qualified workers, with the sole exception of the Radiation Protection Technician position, which remained vacant in 2023.

All safety-related responsibilities and work activities associated with this organizational position were shared through the year, primarily between the Environmental Protection Technician and the Assistant Manager – Health Physics, and supported where required by the Manager – Health Physics and Regulatory Affairs.

As well, a production technician was included in meetings of the Health Physics team, and formal training in various radiation protection-related processes was conducted with this worker throughout the year.

As of the end of 2024, this technician is fully qualified to carry out various duties associated with the Radiation Protection Technician position, under the oversight of the Health Physics Team.

2.1.2 Committees

In 2023, committees have continued to be instrumental in the development and refinement of company programs and procedures, identifying new safety initiatives and ensuring continuing effective communication at all organizational levels.

Committees use meeting results as an opportunity for improvement and make recommendations accordingly. In 2023, a total of 80 committee meetings took place at the company compared to 73 in 2022, 99 in 2021, and 77 in 2020.

Committee meetings continue to be a key force to improve all aspects of our operations, and safety in general.

See Table 2 for a breakdown of the meetings held in 2023.

TABLE 2: COMMITTEE MEETINGS

COMMITTEE	NUMBER OF MEETINGS
PRODUCTION COMMITTEE	44
WORKPLACE HEALTH AND SAFETY COMMITTEE	12
HEALTH PHYSICS COMMITTEE	5
FIRE PROTECTION COMMITTEE	4
MAINTENANCE COMMITTEE	3
TRAINING COMMITTEE	3
OTHER COMMITTEE / STAFF MEETINGS	2
MITIGATION COMMITTEE	2
EXECUTIVE COMMITTEE	2
WASTE MANAGEMENT COMMITTEE	1
PUBLIC INFORMATION COMMITTEE	1
SAFETY CULTURE COMMITTEE	1
TOTAL	80

2.1.3 Review of Quality Assurance and Management System Effectiveness

The SRBT management system is subject to both focused periodic reviews, as well as continuous review and improvement.

An internal audit of the SRBT management system is conducted annually. In 2023, this audit yielded no safety-significant findings.

Based upon the following factors, and the information presented in this report, it is concluded that the SRBT management system has been effective throughout the year:

- A very low frequency of lost-time injuries or incidents occurring in 2023,
- All workplace injuries were relatively minor in nature,
- Highest worker dose for 2023 is less than 1% of the regulatory limit,
- Maximum calculated public dose remains less than 1% of the regulatory limit for persons who are not nuclear energy workers,
- Continued low ratio of tritium released vs. processed,
- Gaseous tritium oxide releases were 9.7% of authorized limits, while combined oxide and elemental tritium releases were 4.6% of authorized limits,
- Tritium releases via liquid effluent were less than 0.5% of authorized limits,
- All conditions of our facility operating licence met throughout the year,
- Zero CNSC compliance actions as of the end of 2023,
- Continued improvement of several key programs and processes, and
- Continuous registered certification to the latest revision of the ISO 9001 standard.

2.1.4 Internally Conducted Audits

2.1.4.1 Internal Audits of Internal Programs and Processes

The goal of SRBT's internal auditing process is to ensure that all licensed activities and company safety programs and procedures are being adhered to. Internal audits are often specifically focused on the same SCAs applied by the CNSC.

The Compliance Manager implemented an audit schedule for 2023 that touched on several aspects of our operations. A total of eight internal audits were scheduled, with five being completed. Three scheduled audits were deferred due to competing priorities of the Compliance Manager, including a focus on the implementation and improvement of the external supplier audit process.

Internal audits were conducted in the following areas of our operations:

- Engineering Department
- Management System
- Quality Department
- Radiation Protection and Dosimetry Service, and
- Environmental Protection - Environmental Monitoring Program

Internal audits resulted in 3 non-conformances (NCR) and 7 opportunities for improvement (OFI) being identified in 2023. Actions have been established and tracked in each case in order to drive compliance and continuous improvement.

For 2024, a total of ten internal audits are included on the approved schedule.

2.1.4.2 Internal Audits of External Suppliers

In 2023, three external supplier audits were planned and carried out to ensure the acceptability of the management systems of key suppliers of goods and services.

These audits were completed through the Supplier Quality Audit Questionnaire process. No findings were identified through the conduct of these audits.

2.1.5 Externally Conducted Audits

During the year, there were a total of ten major inspections or audits conducted by stakeholders and external parties on our operations.

2.1.5.1 CNSC Inspections (2)

CNSC staff conducted compliance inspections at SRBT on two occasions in 2023.

In March, CNSC staff conducted a two-day general compliance which included assessments of the following Safety and Control Areas (SCA):

- Human Performance Management,
- Operating Performance,
- Radiation Protection,
- Conventional Health and Safety,
- Environmental Protection, and
- Waste Management.

The inspection team found SRBT to be in compliance with the inspection criteria, and no compliance actions or recommendations were raised^[4].

In September, CNSC staff conducted a three-day compliance inspection focused on the SCA of Fitness for Service.

The inspection team found SRBT to be in compliance with the inspection criteria, and no compliance actions or recommendations were raised^[5].

2.1.5.2 ISO Certification Audits (1)

On behalf of the International Organization for Standardization (ISO), BSI Management Systems conducted an audit of SRBT operations related to the quality management system on September 12 and 13, 2023, as part of the maintenance of SRBT's ISO 9001 certification.

Through the audit, SRBT was successful in maintaining continued certification. Four opportunities for improvement were identified.

2.1.5.3 Customer-Led Audits (1)

In October 2023, an external audit was executed by a major customer of our commercial safety signs. The audit was a product-focused quality audit of our facility. No findings were identified through this audit.

2.1.5.4 Underwriters Laboratories (4)

Underwriters Laboratories (UL) provides safety-related certification, validation, testing, inspection, auditing, advising and training services to a wide range of clients, including manufacturers.

UL performs quarterly visits of our facility. These visits are unannounced, and provide assurance that our UL-listed products are manufactured using the materials, procedures and testing parameters required under the specific UL listing.

In 2023, UL performed inspections on March 23, May 25, August 30 and November 27. No variations were identified as a result of these inspections.

2.1.5.5 Fire Protection Inspections (2)

Two focused facility inspections were conducted in 2023 relating to fire protection by parties other than SRBT.

The Pembroke Fire Department inspected the facility in September, with no violations being identified.

An external fire protection consultant (PLC) conducted a N393-compliant site condition inspection in October. The inspection report showed three findings and one opportunity for improvement, which were dispositioned accordingly.

Details on these inspections can be found in section 4.4, 'SCA – Emergency Management and Fire Protection'.

2.1.6 Benchmarking and Self-assessments

In 2023, individuals responsible for specific programs and procedures at SRBT regularly looked at process problems, corrective actions as well as trending and used this information to benchmark elsewhere in or out of the organization in order to improve the effectiveness of these programs and procedures and to help define where improvements could be made.

Benchmarking against other similar CNSC licensees is encouraged. Documents describing the performance of similar CNSC licensees are made available for review, including:

- Commission Member Documents
- Proceedings, Including Reasons for Decision
- Documents from other licensees, including annual compliance reports

Self-assessments are also performed by Organizational Managers to identify, correct and prevent problems that hinder the achievement of the company's vision, mission, goals, values and policy and to assess the adequacy and effectiveness of the Quality Management System.

Self-assessments were performed by review of:

- Analysis and trending of performance data against historical data
- Input from stakeholders (public, contractors, regulators, etc.)
- Workplace inspections or observations
- Routine communications with staff to determine whether expectations are understood
- Training and coaching results
- Corrective and preventive actions raised throughout the organization
- Internal audit results

Both Benchmarking and Self-assessment reports formed key inputs into the annual Management Review meetings conducted in August.

The scope of these meetings was to fully and critically review our operations, to develop actions to address identified issues and risks, and to take advantage of opportunities for improvement.

The 2023 Management Review cycle is scheduled to be completed in the first half of 2024.

2.1.7 Programs and Procedures

2.1.7.1 Programs and Major Licensing Documents

In 2023, several key licensing basis documents and management system programs, were revised in line with SRBT's mission of continuous improvement:

- A revised Security Program was implemented on March 30, 2023, which has been reviewed and accepted by CNSC staff.
- A revised Fire Protection Program and Fire Safety Plan was submitted to CNSC staff on March 28^[7]. These revised management system documents were then implemented by SRBT on May 1, in accordance with the change control requirements of the LCH^[2].
- A revised Radiation Safety Program was submitted to CNSC staff on November 3^[8], incorporating a number of minor administrative changes. The revised program document was reviewed and accepted by CNSC staff on December 18, 2023^[9].
- The SRBT Safety Analysis Report was reviewed and revised in 2023, in line with CNSC Regulatory Document (REGDOC)-2.4.4, *Safety Analysis for Class IB Nuclear Facilities*.

This revision was conducted as the final output of a comprehensive gap analysis and implementation plan between SRBT's processes for the conduct of safety analyses, the 2017 version of the SAR (Revision 4), and the requirements of REGDOC-2.4.4.

The initial version of Revision 5 of the SAR was submitted to CNSC staff on July 31, 2023^[10]. CNSC staff provided feedback and comments on the SAR on November 3, 2023^[11], which SRBT incorporated and addressed as part of a revised submission on December 1, 2023^[12].

CNSC staff accepted the SRBT Safety Analysis Report (Rev. 5 – December 2023) on December 11, 2023^[13]. The report^[6] was then posted to the SRBT public website.


2.1.7.2 SRBT Management System Document Hierarchy

Figure 2 illustrates the Management System document hierarchy in place as of the end of 2023.

FIGURE 2: MANAGEMENT SYSTEM DOCUMENTS

SRBT Management System Document Structure

This chart depicts the relationships of our key descriptive documents, programs, processes and procedures



2.1.7.3 Management System Changes

In 2023, a total of 47 Engineering Change requests (ECR) were filed relating to procedural or program changes in the SRBT management system.

The breakdown of program-related ECRs filed in 2023 is presented in Table 3 below:

TABLE 3: PROCEDURAL ECR SUMMARY

PROGRAM / AREA	NUMBER OF ECRs
ENGINEERING	10
QUALITY	6
CONVENTIONAL HEALTH AND SAFETY	5
MAINTENANCE	4
ENVIRONMENTAL MONITORING AND PROTECTION	4
MATERIALS / PRODUCTION	4
MANAGEMENT SYSTEM	3
WASTE MANAGEMENT	3
HEALTH PHYSICS	3
RADIATION SAFETY	2
FIRE PROTECTION	1
SHIPPING AND RECEIVING	1
SECURITY	1
TOTAL	47

Note that where appropriate, one ECR may encompass more than one procedural improvement.

Procedural or programmatic changes were implemented for a variety of purposes. Many improvements have been incorporated as a result of the continuing oversight provided by SRBT's internal audit processes, as well as a dedicated managerial focus on improvement initiatives in each area.

2.2 SCA – Human Performance Management

Throughout the course of 2023, SRBT ensured the programs that manage human performance were implemented effectively, and the interfaces between these programs and other aspects of our management system were maintained and executed. At all times a sufficient number of qualified workers were available to carry out licenced activities in a safe manner, and in accordance with regulatory requirements and SRBT safety programs.

In 2023, SRBT employed a total of 42 staff members, including one seasonal employee. Two new employees were hired in 2023, while four left the company (including the seasonal employee). By the end of 2023 there were a total of 38 employees.

At the end of 2023 the average experience of our workforce stands just under 15 years, with an average age of just under 44 years old.

The Health Physics Team, comprised of five members possesses a combined 91 years of work experience with the company, while production supervisors average just over 25 years of experience with SRBT.

Careful consideration continues to be taken when appointing new staff to ensure continued nuclear safety. The activities of four work areas (marked in yellow in Table 4) do not involve tasks that affect nuclear safety.

TABLE 4: NUCLEAR SAFETY TASKS PERFORMED PER WORK AREA

WORK AREA	AVERAGE EXPERIENCE (IN YEARS)	RESPONSIBLE FOR PROGRAMS AND PROCEDURES THAT AFFECT NUCLEAR SAFETY	PROCESS TRITIUM	HANDLE SEALED TRITIUM SOURCES
ADMINISTRATION	20.42	✓	-	-
ASSEMBLY	17.73	-	-	✓
GLASS SHOP	17.25	-	-	-
MACHINING AND MOLDING	16.85	-	-	-
RIG ROOM	12.28	-	✓	✓
SHIPPING	10.58	-	-	-
COATING	6.09	-	-	-

Generally, employees hired as Production Technicians are first appointed to one of these four work areas. These positions do not in any way impact the company's ability to ensure that the requirements of the *Nuclear Safety and Control Act*, Regulations and conditions of the licence^[1] and LCH^[2] are met.

The Rig Room is the work area where tritium gas is processed into GTLS. The average work experience of the staff within this department is just over 12 years. The Supervisor in this department has over 32 years of experience and performs or oversees all activities that involve tritium processing or handling of tritium sources.

The Assembly Department is where tritium sources are handled by staff for assembly into products or for packaging. The tritium is contained in the source at this stage and the possibility of tritium exposure is low. The Supervisor in this department has over 32 years of experience, and performs or oversees all activities of other staff members.

The overall performance of the human performance program implemented by SRBT was satisfactory throughout 2023, and several improvements made will serve to continually increase its effectiveness.

2.2.1 Training

2.2.1.1 Annual All-Staff Training Session

Traditionally, once per calendar year, SRBT shuts down all manufacturing operations in order to conduct an all-day, all-staff training session.

The agenda for this training typically incorporates a wide variety of aspects of our operations. The majority of the day is dedicated to a refresher course in radiation protection, specifically oriented at the unique type of hazard present at SRBT.

This training was conducted in two separate groups of trainees over the course of consecutive days in late November 2023, and was focused on information with respect to anticipated health effects from radiation exposure, tritium, proper handling of tritium throughout the facility, and equipment for personal radiation protection purposes. All trainees successfully challenged the associated written test for this training.

As well, training segments focused on Conventional Health and Safety, Fire Safety and Emergency Preparedness, Supervisory Awareness Program, and the SRBT Management System were also conducted with all staff.

Finally, a survey on Safety Culture was administered to all staff by the Safety Culture Committee, the results of which will help to continue to maintain and improve a healthy safety culture at the facility.

Based on course evaluation data, the annual all-staff training session provides an excellent opportunity for workers to refresh their training and knowledge on several of the safety-related aspects of working at SRBT.

2.2.1.2 Fire Extinguisher Training

Fire extinguisher training is typically conducted annually for all SRBT employees. The PFD provided this training in November 2023.

2.2.1.3 Fire Protection Specialist Training

The Fire Protection Specialist continues to serve as a volunteer firefighter for a local fire department, and receives fire protection training from this department. In 2023, this individual achieved Firefighter 1 certification.

2.2.1.4 TDG Training

Transportation of Dangerous Goods (TDG) training for Shipping department staff is scheduled every two years. The training is conducted by an outside agency with expertise in the transport of dangerous goods.

A TDG training session was conducted on February 13, 2023. Five employees successfully underwent this training at that time, and were TDG-certified.

In line with the schedule of this training, the next TDG training session will be held in February 2025.

2.2.1.5 Health and Safety Training

The following training took place in 2023:

- The Manager – Safety and Security as well as another member of the SRBT H&S Committee attended an off-site conference in June. Training topics covered included *Reimagining Your Office Ergonomics and MSD Prevention Program*, *Key Legislative Updates for Federally-Regulated Employees*, and *Machine Safety – CSA Z432 Standard Highlights*.
- All SRBT employees attended annual training that included Workplace Hazardous Materials Information Systems (WHMIS) and a new procedure for handling chemical spills in November.

2.2.2 Systematic Approach to Training Program

SRBT continues to implement a systematic approach to training (SAT) as part of our overall training program, and the Training Committee actively ensures that the processes described in the SRBT Training Program Manual are managed effectively and improved on an ongoing basis.

Three meetings of the Training Committee were held in 2023, with the annual program evaluation being held in January, the annual SAT-analysis review taking place in May, and the annual review of the qualification of SAT-based trainers being conducted in November.

There were six instances where new or modified activities or equipment were brought to the Training Committee for a categorization decision during the year. Five of these were determined to be eligible for management as Category 1 training activities (non-SAT based), and were assigned to the responsible manager to ensure that training is performed as needed.

One categorized activity was assigned as Category 2, and will be trained in accordance with a systematic approach. The implementation of Fire Protection Program procedure FPP-020, *Hot Works* requires training that meets the criteria to be designed, developed and implemented systematically. The development of this training has been completed, and it will be implemented beginning in 2024.

Qualification management processes continue to ensure that SAT-qualified staff members maintain their skills through frequency of performance requirements, and that the qualification of SAT-based trainers continues to be evaluated periodically.

The following table compiles information on the number of qualified workers assigned tasks that are trained in accordance with a SAT-based method at the end of 2023.

TABLE 5: WORKER QUALIFICATION IN SAT-BASED ACTIVITIES

SAT WORK ACTIVITY	FULLY QUALIFIED WORKERS	WORKERS PROGRESSING TOWARD FULL QUALIFICATION
SAT-HP-01: ADVANCED HEALTH PHYSICS INSTRUMENTATION	2	1
SAT-HP-02: LIQUID EFFLUENT MANAGEMENT AND CONTROL	3	0
SAT-HP-03: WEEKLY STACK MONITORING	3	0
SAT-HP-04: BIOASSAY AND DOSIMETRY	3	1
SAT-OP-01: TRITIUM PROCESSING – FILLING AND SEALING LIGHT SOURCES	7	0
SAT-OP-02: BULK SPLITTER OPERATIONS	5	1
SAT-OP-03: HANDLING PUTTS	4	2
SAT-SHP-01: IMPORT AND EXPORT PROCESSES	4	0
SAT-FPP-020: HOT WORKS	1	4

Refresher training modules were provided on several occasions, including the annual refresher training for certain infrequently performed work tasks that score high on the difficulty and importance scale (as part of SAT-based task analysis).

The training needs analysis (TNA) process was implemented on eight occasions in response to procedural / program changes, or for new or modified facility equipment.

The frequent use of this documented TNA process has been very helpful at ensuring a level of appropriate training is provided to SRBT staff when required, and in maintaining human performance-related issues very low.

2.3 SCA – Operating Performance

SRBT has continued to operate the facility safely and in compliance with our operating licence^[1] throughout 2023.

Our programs and processes have continued to evolve to meet or exceed regulatory requirements and expectations, with safety as an overriding priority in all aspects of our licensed activities.

A summary of compliance with operational limits and conditions can be found under section 1.3 of this report, while a summary of annual production / utilization data can be found in section 1.4 of this report.

A description of the internal and external audits conducted relating to licensed activities can be found under sections 2.1.4 and 2.1.5 of this report.

2.3.1 Ratio of Tritium Released to Processed

In 2023 our team continued to strive to minimize the amount of tritium released to the environment for every unit of tritium processed – we refer to this as the ‘released to processed’ ratio. This ratio is an excellent indicator of the overall effectiveness of our emission reduction initiatives.

The following table illustrates how this ratio has trended over the past five years.

TABLE 6: TRITIUM RELEASED TO PROCESSED RATIO FIVE-YEAR TREND (2019-2023)

DESCRIPTION	2019	2020	2021	2022	2023
TOTAL TRITIUM RELEASED TO ATMOSPHERE (GBq/YEAR)	31,769	25,186	28,729	26,590	20,520
TRITIUM PROCESSED (GBq/YEAR)	30,327,048	27,887,498	29,392,257	26,940,372	23,202,623
RELEASED / PROCESSED (%)	0.10	0.09	0.10	0.10	0.09
CHANGE IN RATIO INCREASE (+) / REDUCTION (-)	-9%	-10%	+10%	NC	-10%

The ratio of tritium released to processed has remained very low and relatively stable for several years, which is indicative of continued safe processing operations.

2.3.2 Objectives and Targets

SRBT performance against key objectives and targets for 2023 is tabled below.

TABLE 7: 2023 PERFORMANCE TARGETS

DESCRIPTION	2023 TARGET	2023 PERFORMANCE
MAXIMUM DOSE TO NUCLEAR ENERGY WORKER	≤ 0.50 mSv	0.39 mSv
AVERAGE DOSE TO NUCLEAR ENERGY WORKER	≤ 0.055 mSv	0.038 mSv
CALCULATED DOSE TO MEMBER OF THE PUBLIC	≤ 0.0040 mSv	0.0020 mSv
WEEKLY AVERAGE TRITIUM RELEASES TO ATMOSPHERE	≤ 625 GBq / week	395 GBq
RATIO OF TRITIUM EMISSIONS VS. PROCESSED	≤ 0.11	0.09%
TOTAL TRITIUM EMISSIONS EFFLUENT PATHWAY	≤ 8 GBq	0.68 GBq
ACTION LEVEL EXCEEDANCES ENVIRONMENTAL	≤ 1	0
ACTION LEVEL EXCEEDANCES RADIATION PROTECTION	≤ 1	0
CONTAMINATION CONTROL FACILITY-WIDE PASS RATE	≥ 95.5%	96.9%
LOST TIME INJURIES	0	0
MINOR INJURIES REPORTABLE TO WSIB	≤ 5	0
MINOR INCIDENTS / FIRST AID INJURIES (NON-REPORTABLE)	≤ 15	11

Target values are set at the outset of each calendar year by various committees. Data is tracked and trended throughout the year in order to ensure that appropriate measures can be taken where appropriate, in an effort to ensure a high level of safety performance.

Where targets are missed, specific actions are documented and tracked to improve performance where feasible; however, in some cases production considerations can result in effects that were not anticipated when the annual targets were set.

No targets were missed for calendar year 2023.

2.3.3 Reportable Events

SRBT did not experience any events that met the regulatory criteria for unplanned event reporting in 2023. Event reporting is governed by the SRBT Regulatory Reporting Program.

2.3.4 Inventory Control Measures

2.3.4.1 Tritium

SRBT has continuously possessed, transferred, used, processed, managed and stored all nuclear substances related to the operation of our facility in compliance with the requirements of our licence.

A number of inventory control measures are in place to ensure that tritium on site does not exceed the possession limit prescribed by our operating licence.

The maximum amount of tritium possessed by SRBT at any one time during 2023 was 4,960 TBq, which represents 82.7% of the facility possession limit. The average monthly inventory on site was 2,752 TBq.

Tritium on site is found in:

- Bulk containers and tritium traps,
- New light sources,
- New product that contain light sources,
- Work in progress,
- Waste,
- Expired light sources taken out of product,
- Products that contain expired light sources, and
- Non-conforming product.

Refer to **Appendix A** for additional details on tritium inventory in 2023.

2.3.4.2 Depleted Uranium

SRBT possessed a reported 8.721 kg of depleted uranium in metallic form at the beginning of 2023.

This material is used in tritium ‘traps’ as storage media for tritium gas on our processing equipment, a well-understood and widely-used strategy for manipulating and storing tritium in its gaseous, elemental state.

By using depleted uranium in this fashion, we can ensure that the quantity of gaseous tritium being used during any given processing operation is restricted. This helps to ensure that the consequences of any unplanned event are minimized with respect to radiation and environmental protection, by ensuring that any release of tritium is limited.

In July, the material on hand underwent an annual physical inventory process. All materials were accounted for, and unused material reweighed. As a result of this process, a total of 22 grams of material were added to the administrative record of inventory (+19 grams in container 1, +3 grams in container 2). These discrepancies are not safety-significant, and are due to uncertainties in the physical weighing of the materials, and any rounding that takes place when building new tritium traps.

At the conclusion of 2023, the mass of depleted uranium on site is 8.743 kg. A limit of 10 kg of this material in inventory is applied as part of the operating limits and conditions in the SAR.

The breakdown of this inventory at the conclusion of 2023 is as follows:

TABLE 8: DEPLETED URANIUM INVENTORY BREAKDOWN AT THE END OF 2023

QTY	DESCRIPTION	DEPLETED URANIUM IN EACH (GRAMS)	TOTAL DEPLETED URANIUM (GRAMS)
1	LOOSE FORM – CONTAINER 1	N/A	1,048
1	LOOSE FORM – CONTAINER 2	N/A	4,978
9	ACTIVE P.U.T.T.	30 +/- 5 grams	287
16	NON-ACTIVE P.U.T.T.	30 +/- 5 grams	510
6	AMERSHAM CONTAINERS	320	1,920
		TOTAL	8,743

2.3.5 Liquid Scintillation Quality Assurance and Control

2.3.5.1 Routine Performance Testing

As a component of SRBT's Dosimetry Services Licence, Routine Performance Testing is performed on both liquid scintillation counters on a quarterly basis, as required by CNSC REGDOC-2.7.2, *Dosimetry, Volume II, Technical and Management System Requirements for Dosimetry Services*^[14].

These quality assurance tests are performed to demonstrate that liquid scintillation counting assays in support of the dosimetry service are operated in a predictable and consistent way.

This testing was carried out every 3 months as required throughout 2023 on each of the two 'TriCarb 2910' units, with no failures reported.

2.3.5.2 Weekly LSC Performance Check

SRBT quality assurance requirements for liquid scintillation counting include weekly instrument performance checks using National Institute of Standards and Technology (NIST) traceable standards of a blank, H-3 and C-14 standards.

All tests have been performed on both TriCarb 2910 Liquid Scintillation Counting (LSC) units, and included an assessment of the instrument efficiency for tritium measurement, the figure of merit, the tritium background measurement, and a chi-square test. An instrument must meet acceptability criteria on a weekly basis, or the unit is removed from service pending corrective maintenance or actions.

2.3.5.3 Assay Quality Control Tests

Reference standards traceable to NIST are prepared in-house, and are analyzed and checked against quality control acceptance criteria with every batch of liquid scintillation counting samples being analyzed.

All tests were performed as required with every assay throughout 2023, in order to ensure quality control of LSC laboratory processes.

3. Facility and Equipment SCAs

3.1 SCA – Safety Analysis

The overall safety case for SRBT continues to be effectively validated and maintained through the implementation of our management system.

Preventive measures and strategies for potential hazards are built into our programs and processes. Key safety processes include independent verification, frequent internal audit and oversight, and management by designated committees.

3.1.1 Operating Limits and Conditions - SAR

Please refer to section 1.3 of the report for a complete assessment of SRBT compliance against the Operating Limits and Conditions in the SAR.

Operating practices and management system processes in 2023 have continued to be conducted in full alignment with the latest version of SRBT's SAR. There were no significant changes to the facility or our operations that had any direct bearing on the safety analysis in 2023.

3.1.2 REGDOC-2.4.4 and Revising the SRBT SAR

The SRBT Safety Analysis Report^[6] was reviewed and revised in 2023, in line with CNSC Regulatory Document (REGDOC)-2.4.4, *Safety Analysis for Class IB Nuclear Facilities*^[15].

As outlined in the 2022 Annual Compliance and Performance Report^[16], this revision was conducted as the final output of a comprehensive gap analysis and implementation plan between SRBT's processes for the conduct of safety analyses, the 2017 version of the SAR (Revision 4), and the requirements of REGDOC-2.4.4.

CNSC staff accepted Revision 5 (December 2023) of the SRBT SAR on December 11, 2023^[13]. The report has been published on the SRBT website.

3.2 SCA – Physical Design

As a manufacturing company, SRBT owns and operates several pieces of equipment, many of which constitute structures, systems and components which have a bearing on safety and our licensed activities.

Such equipment includes the active ventilation systems and associated emissions monitoring equipment, fire detection and suppression systems, tritium processing rigs, tritium-in-air monitors, and liquid scintillation counters.

The overall facility design is also a key aspect of our operations, and must be managed and controlled safely. The SRBT change control process helps to ensure that modifications are controlled, reviewed, accepted, and recorded using an Engineering Change Request.

Modifications to structures, systems and components associated with our licensed activities are conducted in accordance with these change control processes and overall management system.

No significant changes in physical design of production- or safety-related facility systems or components took place in 2023. There were no changes to the self-luminous tritium light source production capacity of the facility.

All minor and non-safety significant modifications to structures, systems and components were conducted in accordance with our change control processes.

3.3 SCA – Fitness for Service

All equipment, including all safety-related equipment, is kept in a condition that is fit for service through the implementation of the Maintenance Program. The facility and equipment associated with the facility were effectively maintained and operated within all manufacturer requirements.

Note that, although the Maintenance Program incorporates several program elements associated with nuclear power plants as best practice (such as critical spares, master equipment lists, etc.), aging management is not an element that is formally included as a specific strategy.

Documented maintenance meetings were initiated and held by the Maintenance Committee throughout 2023. As part of management review processes, an annual review of 2023 activities will be conducted in 2024, including data pertaining to equipment failures, maintenance activity success rates, non-conformances, procedural revisions, and audit findings.

Maintenance records are kept on file including completed work orders of preventative maintenance activities. A maintenance schedule is created and managed by the Fire Protection Specialist, which effectively captures all safety-significant planned preventative maintenance activities, whether performed by SRBT personnel or an approved contractor, and includes maintenance inspections as required by the Fire Protection Program.

As well, corrective maintenance was tracked, trended and reviewed to assess the performance of equipment, and to identify any preventative activities which may improve performance.

Preventative maintenance was scheduled and performed in 2023 on key facility equipment as per **Appendix B** of this report.

The Safety and Control Area of Fitness for Service was the focus of an inspection by CNSC staff in September 2023. The inspection found SRBT to be in compliance with the inspection criteria, and no compliance actions or recommendations were raised^[5].

3.3.1 Ventilation

The ventilation of the facility is such that the air from the facility flows to the area with greatest negative pressure in Zone 3 which has the highest potential for tritium contamination where all tritium processing takes place. This area and part of Zone 2 are kept at high negative pressure with the use of two air handling units which provide a total airflow of approximately 10,000 cubic feet per minute.

The air handling units are connected to a series of galvanized stainless-steel ducts. In addition to providing ventilation for the facility these air handling units also provide local ventilation to a number of fume hoods which are used to perform activities that have a potential for tritium contamination and exposure.

All ventilation systems were maintained fit for service throughout 2023. Corrective and preventative maintenance was identified and performed according to the requirements of the Maintenance Program and operational procedures. Key equipment is maintained either on a quarterly or semi-annually basis, with technical equipment maintenance being performed by fully licensed and certified heating, ventilation and air conditioning contract providers.

A listing of the ventilation equipment maintained in 2023 can be found in **Appendix C** of this report.

3.3.2 Stack Flow Performance

Stack maintenance is performed by a third party, in order to ensure effective performance of the ventilation system and minimize airflow reductions from the beginning to the end of the maintenance cycle to ensure accuracy of results.

Pitot tubes that were installed in the stacks are maintained by a third party to ensure stack airflows are at design requirements. This essentially allows for daily stack flow verification in addition to more detailed annual stack flow verification performed by a third party.

The annual stack flow performance verification was performed on September 11, 2023 by a third party. The inspection confirmed that the stacks continue to perform to design requirements. SRBT continues to monitor and trend the results of the annual stack performance verification.

3.3.3 Liquid Scintillation Counters

The two TriCarb 2910 LSC units were subjected to an annual preventive maintenance procedure between June 28-29, 2023. No significant concerns or issues were identified during the maintenance activity.

There were no instances where corrective maintenance was required on either LSC unit in 2023.

Both systems will continue to be preventively maintained and calibrated on an annual basis by a qualified service representative from the manufacturer of the equipment, to ensure their functionality, accuracy and reliability.

3.3.4 Portable Tritium-in-Air Monitors

Portable tritium-in-air monitors are maintained and made available throughout the facility. The portable units are used to investigate potential sources of tritium leakage, and for personnel protection.

As of the end of 2023, SRBT owns a total of eight portable monitors, as well as an additional unit that is used by our sister company in North Carolina.

Seven of these monitors are used at the facility (two in Zone 1, two in Zone 2 and three in Zone 3), and an eighth is kept on standby at the Pembroke Fire Hall as part of an emergency preparedness kit.

As required by our Radiation Safety Program, all in-service tritium-in-air monitors were calibrated and maintained at least once during 2023, with all records of the maintenance kept on file.

3.3.5 Stationary Tritium-in-Air Monitors

The ambient air in selected key areas of the facility is continuously monitored using stationary tritium-in-air monitors.

There continues to be five stationary tritium-in-air monitors deployed for continuous airborne tritium monitoring at the facility, with two spare units available if needed.

The in-service monitors operate 24 hours a day to ensure that any upset conditions are identified and addressed quickly.

Three monitors are strategically located in Zone 3; one in the Rig Room where gaseous tritium light sources are filled and sealed; one in the Laser Room where a laser is used to cut and seal small gaseous tritium light sources, and light

sources are inspected; and one in the Tritium Laboratory where tritium is transferred from bulk supply containers to filling containers.

One stationary tritium-in-air monitor is located in Zone 2 in the Assembly Area, where gaseous tritium light sources are pre-packed in preparation for shipping or installed into device housings.

A stationary tritium-in-air monitor is located in the Shipping area in order to provide an early warning signal of a problem should a light or device be damaged during packaging activities.

As required by our Radiation Safety Program, all tritium-in-air monitors were calibrated and preventively maintained at least once during 2023. All facility monitors functioned effectively and continuously throughout the year, with all records of maintenance retained on file.

3.3.6 Stack Monitoring Equipment

Stack monitoring equipment is incorporated for each of two main air-handling units. For each air-handling unit, the monitoring equipment includes:

- A tritium-in-air monitor connected to a real-time recording device,
- An alarming remote display unit (RDU) in Zone 3,
- A bubbler system for discriminately collecting HTO and HT in the sampled stream of effluent,
- A flow measurement device with elapsed time, flow rate and volume of the sampled stream of effluent, and
- A dedicated back-up power supply servicing the monitors, bubbler systems and flow meters, capable of providing several hours of uninterrupted power to the equipment during a power failure.

Each tritium-in-air monitor is connected to a real-time recording device (electronic datalogger), and was calibrated and preventively maintained as required in 2023.

The tritium monitors, datalogger and RDUs are included in calibration verification activities on a quarterly basis.

Bubbler systems (and spare systems) were also maintained throughout the year, with a bi-monthly maintenance cycle being implemented on all in-service stack monitoring equipment. As a preventive maintenance measure, the batteries in the back-up power supply were changed with new replacement units in October.

3.3.7 Stack Monitoring Verification Activities

The annual verification activity for the bubbler systems was completed in February 2023, where independent third-party measurements provided validation that SRBT bubblers continue to effectively measure weekly gaseous tritium emissions (both HTO and HT).

The acceptance criterion for deviation between the assessed measurements of gaseous emissions is +/- 30%. In 2023, all verification results met this acceptance criteria.

3.3.8 Weather Station

Maintenance of the weather station is performed as per the manufacturer's recommendation, every two years, with batteries being replaced every four years. Preventative maintenance of the weather station was completed on September 6, 2023.

The next preventative maintenance of the weather station is due in 2025, including battery replacement.

3.3.9 Air Compressor

Process tasks at SRBT require the use of a compressed air system. The air compressor is subject to quarterly preventative maintenance activities, and semi-annual belt changes, all of which were carried out throughout 2023. During periods of high usage rates, additional maintenance is performed on the compressor as an extra precaution to ensure ideal performance.

During preventative maintenance of the main compressor motor, the backup compressor is brought online to minimize production downtime. Once the maintenance is completed on the main compressor, the backup is then inspected and maintained by the contractors to ensure it will perform as intended should any problems arise with the main compressor.

4. Core Control Processes SCAs

4.1 SCA – Radiation Protection

4.1.1 Dosimetry Services

Pursuant to our Dosimetry Service Licence^[17], SRBT assesses the radiation dose to its employees and to contract workers who may have exposure to tritium.

SRBT implements a dedicated Dosimetry Service Program in support of compliance with the requirements of this licence. The assessment of dose to personnel, due to tritium uptake, is performed in accordance with CNSC REGDOC-2.7.2, *Dosimetry, Volume II, Technical and Management System Requirements for Dosimetry Services*^[14].

All dosimetry results were submitted on a quarterly basis to Health Canada in a timely fashion for input into the National Dose Registry. A final annual report was also submitted as required.

SRBT participated in the annual Tritium Urinalysis Performance Test sponsored by the National Calibration Reference Centre for Bioassay, Radiation Surveillance and Health Assessment Division, Radiation Protection Bureau of Health Canada. The participation is a regulatory requirement for Dosimetry Service Providers.

SRBT received the Certificate of Achievement for successful participation in the Tritium Urinalysis Performance Test from the National Calibration Reference Centre for Bioassay and In Vivo Monitoring for the year 2023^[18].

As required by the licence, SRBT has submitted the 2023 Annual Compliance Report to CNSC staff for the Dosimetry Service Licence^[19].

4.1.2 Staff Radiation Exposures and Trends

All SRBT staff members are classified as Nuclear Energy Workers and participate in the dosimetry program.

Those who work in Zones 1 and 2 provide bioassay samples for tritium concentration assessment on a bi-weekly frequency due to the very low probability of uptake of tritium. Those assigned to work in Zone 3 provide bioassay samples on a weekly frequency due to the higher probability of chronic uptake of tritium.

There were no occurrences of any personnel contamination events in 2023.

The maximum effective dose received by any person employed by SRBT in 2023 was 0.39 mSv, a value which is well within the regulatory limit for a nuclear energy worker of 50.0 mSv per calendar year.

The average effective dose for all staff was calculated to be 0.038 mSv, while the collective dose for all workers was measured as 1.56 person·mSv.

The tables found in **Appendix D** of this report provide the radiological dose data for workers at SRBT for 2023, as well as a comparison of dosimetry results for the preceding five years.

4.1.3 Action Levels for Dose and Bioassay Level

Dose and bioassay tritium concentration action levels are defined in SRBT's *Licence Limits, Action Levels and Administrative Limits* document.

Radiation protection-related action levels were last reviewed and revised in 2019, in line with the requirements of the LCH. They are next due for review in June 2024.

The current radiation protection-related action levels are as follows:

TABLE 9: ACTION LEVELS FOR RADIATION PROTECTION

PERSON	PERIOD	ACTION LEVEL
NUCLEAR ENERGY WORKER	CALENDAR QUARTER	1.0 mSv
	1 YEAR	3.0 mSv
	5 YEAR	10.0 mSv
PREGNANT NUCLEAR ENERGY WORKER	BALANCE OF THE PREGNANCY	0.5 mSv

PARAMETER	ACTION LEVEL
BIOASSAY RESULT	1,000 Bq / ml FOR ANY PERIOD

In 2023 there were no exceedances of an action level for dose or bioassay tritium concentration at SRBT.

4.1.4 Administrative Limits for Dose and Bioassay Level

Dose and bioassay tritium concentration administrative limits are also defined in SRBT's *Licence Limits, Action Levels and Administrative Limits* document.

Radiation protection-related administrative limits are as follows:

TABLE 10: ADMINISTRATIVE LIMITS FOR RADIATION PROTECTION

PERSON	PERIOD	ADMINISTRATIVE LIMIT
NUCLEAR ENERGY WORKER	CALENDAR QUARTER	0.67 mSv
	1 YEAR	2.00 mSv
	5 YEAR	8.50 mSv

PARAMETER	ADMINISTRATIVE LIMIT
BIOASSAY RESULT	500 Bq / ml FOR ANY PERIOD IN ZONE 3 100 Bq / ml FOR ANY PERIOD IN ZONE 1 OR 2.

In 2023, there was one instance of an exceedance of an administrative limit for dose or bioassay tritium concentration at SRBT. In May, the bioassay result for a worker in Zone 2 exceeded 100 Bq/ml as a result of a light breakage. A non-conformance report was raised, with a set of corrective and mitigative actions completed to resolve the issue and prevent recurrence.

4.1.5 Contractor Dose

In 2023, SRBT did not employ contract staff to perform work that presented a significant radiological hazard.

Five screening bioassay samples were obtained and measured from contracted tradespersons who provided maintenance support in areas other than Zone 1.

None of these samples exceeded our internal screening criteria requiring the calculation of effective dose.

To summarize, no contractor received a recordable dose due to activities performed at the SRBT facility in 2023.

4.1.6 Discussion of Significance of Dose Control Data

A tabular summary of effective dose metrics for 2023 is provided in **Appendix D**.

4.1.6.1 Maximum Dose

The maximum effective dose to any staff member in 2023 was 0.39 mSv. This individual works in Zone 3 and performs tritium processing operations in Zone 3 as their primary duty.

In 2022, the maximum dose to a staff member was 0.46 mSv; the 2023 value of 0.39 mSv thus represents a 15% decrease in the maximum dose to a worker from the previous year.

A maximum dose of 0.39 mSv represents the achievement of our internal target for 2023 of less than 0.50 mSv. This supports the conclusion that the Radiation Safety Program and the Health Physics Team are achieving a high level of performance, and that workers are properly and adequately trained in safely conducting activities that may pose a radiation hazard.

The maximum individual dose for the current five-year dosimetry period (January 1, 2021 – December 31, 2025) is 1.18 mSv (0.34 mSv in 2021 + 0.46 mSv in 2022 + 0.38 mSv in 2023).

SRBT continuously strives to lower the maximum dose to workers by using several strategies, including training, contamination monitoring, frequent and routine use of portable tritium-in-air monitors during processing operations, and the continuous oversight of the Health Physics Team during key activities on the shop floor.

The maximum worker dose over the past five years is trended in Figure 3 for comparison, as well as a distribution chart in Figure 4 for worker doses in 2023.

FIGURE 3: MAXIMUM ANNUAL WORKER DOSE (2019-2023)





FIGURE 4: WORKER DOSE DISTRIBUTION (2023)




4.1.6.2 Average Dose

The average dose to workers at SRBT in 2023, including those workers whose dose value was zero, was 0.038 mSv. In 2022, the average dose to workers was 0.048 mSv.

The average dose to all nuclear energy workers (NEW) at SRBT over the past five years is trended in Figure 5 for comparison.

FIGURE 5: AVERAGE ANNUAL WORKER DOSE – ALL NEW (2019-2023)




A total of 23 workers incurred effective doses of less than 0.01 mSv in 2023 (i.e. zero dose).

Taking into consideration only 'non-zero' doses, the average effective dose was 0.084 mSv in 2023.

The average dose to all workers at SRBT incurring 'non-zero' doses over the past five years is trended in Figure 6 for comparison.

FIGURE 6: AVERAGE ANNUAL WORKER DOSE – NON-ZERO DOSES (2019-2023)




4.1.6.3 Collective Dose

The collective dose to all workers at SRBT in 2023 was 1.56 person·mSv. In 2022, the collective dose was 2.01 person·mSv.

The collective dose to all workers at SRBT over the past five years is trended in Figure 7 for comparison.

FIGURE 7: COLLECTIVE DOSE (2019-2023)



4.1.6.4 Dose to Members of the Public

The effective dose to members of the public is discussed extensively in section 4.3.5 of this report.

4.1.7 Contamination Control and Facility Radiological Conditions

Tritium contamination control is maintained by assessment of non-fixed tritium contamination levels throughout the facility by means of swipe method and liquid scintillation counting of the swipe material. SRBT has in place the following administrative surface contamination limits:

TABLE 11: ADMINISTRATIVE LIMITS FOR SURFACE CONTAMINATION

ZONE	SURFACES	ADMINISTRATIVE SURFACE CONTAMINATION LIMITS
1	ALL SURFACES	4.0 Bq/cm ²
2	ALL SURFACES	4.0 Bq/cm ²
3	ALL SURFACES	40.0 Bq/cm ²

An overview of contamination monitoring results for 2023 has been tabulated and is included in **Appendix E** of this report.

A total of 8,184 routine contamination assessments were performed in 2023:

- 612 swipes were taken in Zone 1 resulting in a pass rate of 97.2% of assessments being measured below the administrative level of 4 Bq/cm².
- 1,716 swipes were taken in Zone 2 resulting in a pass rate of 97.0% of assessments being measured below the administrative level of 4 Bq/cm².
- 5,856 swipes were taken in Zone 3 resulting in a pass rate of 96.8% of assessments being measured below the administrative level of 40 Bq/cm².

All swipe results are reported to the area supervisors. The area supervisor and the Health Physics Team reviews the results to determine where extra cleaning effort is necessary.

A comparison of the data for the last five years is presented in the table below:

TABLE 12: PASS RATE FOR CONTAMINATION ASSESSMENTS (2019-2023)

ZONE	2019	2020	2021	2022	2023
1	96.5%	96.4%	97.1%	98.2%	97.2%
2	93.1%	96.7%	97.5%	98.0%	97.0%
3	93.5%	96.1%	95.6%	97.0%	96.8%

Overall, routine contamination measurements conducted throughout the facility in 2023 fell below the administrative limits 96.9% of the time, achieving the internal target of $\geq 95.5\%$.

The Health Physics Team continues to track and trend all facility contamination control data throughout the year, with a focused quarterly review to identify areas for improvement.

One routinely monitored area failed to meet the applicable acceptance criteria at least 70% of the time in a calendar quarter:

- In the first quarter of 2023, the Rig Room Barrier area in Zone 1 met the acceptance criterion of less than 4.0 Bq/cm² (averaged over 100 cm²) on nine occasions, and failed to meet this criterion four times, resulting in a pass rate of 69%. The area also failed its assessment on April 4.

The Health Physics Team noted this trend in their meeting of April 4 (prior to processing the results of the assessment conducted that day). A greater attention to the daily cleaning regimen at this area was requested of workers assigned those duties.

After April 4, this area met the acceptance criteria 100% of the time for the remainder of 2023.

With respect to the monitoring of airborne tritium contamination throughout the facility, SRBT's Radiation Safety Program includes several processes that measure and control airborne tritium hazards in our facility:

- Stationary tritium-in-air monitors are strategically located throughout the facility, with audible alarms triggered at conservative tritium concentrations.
- All staff are trained in the use of portable tritium-in-air monitors for self-protection purposes; these are also strategically located in the facility for quick use when needed.
- A series of passive air samplers are distributed throughout the facility, allowing for weekly averaging of tritium concentrations in key areas.
- The Health Physics Team logs all stationary tritium-in-air monitor alarm events, in order to track and trend frequency of occurrence, to facilitate radiological assessments and/or investigations, and to drive improvements in process safety.

Zone alarm cause / frequency and passive air sampling data is routinely assessed by the Health Physics Team in order to identify any areas of concerns or trends.

The frequency of zone alarms decreased in 2023 when compared to 2022; a total of 31 alarms were experienced throughout the facility in 2023, compared to 45 during the previous year.

A comparison of the data for the last five years is presented in the table below:

TABLE 13: ZONE ALARMS (2019-2023)

ZONE	2019	2020	2021	2022	2023
1	4	0	3	2	1
2	62	71	52	31	25
3	69	40	17	12	5
All	135	111	72	45	31

4.1.8 Discussion on the Effectiveness of Radiation Protection Program

Based upon the following factors and the overall evidence presented in this report, it is concluded that the SRBT's radiation protection program has been effective throughout the year.

Key points:

- The highest worker dose for 2023 was 0.39 mSv, or 0.78% of the regulatory limit of 50 mSv.
- For the ninth consecutive year, every SRBT (NEW) incurred an effective dose of far less than 1 mSv (which represents the annual regulatory limit defined in the Radiation Protection Regulations for a person who is not a NEW).
- Collective dose and average dose remain low in relation to production levels, with both of these data points decreasing compared to the previous year. Improvement measures have been effective at helping to reverse the trend of minor increases in these data points.
- Contamination control data demonstrates a high level of control and a low rate of contamination in excess of administrative limits. The internal target of a pass-rate of 95.5% or greater was achieved.
- There were no personnel contamination events at the facility in 2023.
- The frequency of airborne contamination events (zone alarms) continued to decrease in 2023.
- Radiation protection equipment issues are minimal, with a continuing investment in new equipment leading to an excellent track record of maintenance and fitness for service.
- Radiation protection training results demonstrate that staff has a good appreciation and knowledge of how to protect themselves from hazards.

4.1.9 Occupational Dose Targets

As described in the 2022 annual compliance report, the occupational dose targets for 2023 were set as 0.50 mSv (maximum dose to staff member) and 0.055 mSv (average dose to all staff).

The maximum dose to any worker was 0.39 mSv (target met). The average dose to all workers was 0.038 mSv (target met). There were no action level exceedances.

SRBT projects that in 2024, the maximum and average doses to workers should remain low and relatively stable.

With these considerations, the occupational dose targets for calendar year 2024 have been set as follows:

- Maximum dose: ≤ 0.50 mSv (no change)
- Average dose: ≤ 0.050 mSv (lowered)
- Collective dose: ≤ 2.50 p-mSv (lowered)
 - *Informal target set as 2.60 p-mSv in 2023; first time formally including in ACR*
- Action level exceedances: No more than 1 instance (no change)

4.1.10 Summary of Radiation Protection Training and Effectiveness

All new staff members receive introductory training in radiation safety, even if they are not expected to handle nuclear substances as part of their responsibilities.

In 2023, two new employees were hired and were provided with this initial training that is required for declaration as a NEW; each passed the associated test and were declared as NEWs.

Over the course of two days in November, SRBT held its annual all-staff training session, which includes a comprehensive training presentation specifically regarding radiation protection concepts and requirements, specifically tailored to the type of hazard at SRBT. Open dialogue is always encouraged with a question-and-answer session, and a closed-book written test is provided to all participants.

In 2023, all trainees successfully challenged the test, averaging a score of 97.9% on the ten-question multiple choice test, against a performance benchmark of 75%. Any incorrect answer on the test was discussed in detail with each employee individually to ensure full understanding following the completion of the training.

4.1.11 Summary of Radiation Protection Equipment Performance

In 2023, all equipment associated with radiation protection at SRBT performed acceptably, and all key maintenance activities, such as instrument calibration, were performed as required.

Radiation protection equipment includes liquid scintillation counters, portable tritium-in-air monitors, stationary tritium-in-air monitors and portable radiation detectors ('RadEye' type alpha/beta/gamma detectors).

There were no instances of corrective maintenance required for the liquid scintillation counters or tritium-in-air monitors in 2023.

The rate of the need for corrective maintenance on all radiation protection equipment remains acceptable, and SRBT owns and maintains spare instruments that remain ready to be put into service should the need arise.

4.1.12 Summary of Radiation Protection Improvements

SRBT's Radiation Safety Program provides an effective level of radiological protection to our workers, and continues to be improved over time.

In 2023, the following improvements were implemented:

- The Radiation Safety Program was revised to incorporate certain administrative improvements in order to align the program document with SRBT management system format and content requirements.
- New sliding-style 'Rayonnement – Danger – Radiation' trefoil signs were placed in areas where items containing tritium are transiently stored, such as the staging area for packaging and shipping of new products that have been taken out of the Assembly area after completion. Such areas frequently have items that will be stored for a brief period of time. The signs allow for an easy way to adequately post the presence of radioactive material by simply sliding the sign one way to reveal the hazard sign. When the material is not present, the slide is shifted the other way to cover the hazard sign.

4.2 SCA – Conventional Health and Safety

4.2.1 Jurisdiction

SRBT is subject to federal jurisdiction thus, the *Canada Labour Code Part II* (CLC Part II) and the *Canada Occupational Health and Safety Regulations*.

4.2.2 Conventional Health and Safety Program

Being under federal jurisdiction in 2023, the Health and Safety Policy for the SRBT facility was compliant with the requirements of the CLC Part II, and the *Canada Occupational Health and Safety Regulations*.

4.2.3 Workplace Health and Safety Committee

In accordance with Section 135 (1) of the CLC Part II, SRBT maintains a Workplace Health and Safety Committee (WHSC).

The Committee is comprised of four representatives. Under section 135(10) of the CLC Part II the Committee is required to meet no less than 9 times per year.

The Committee met a total of 12 times in 2023, with all meeting minutes kept on file.

4.2.4 Inspections, Audits and Reviews

The following inspections, audits and reviews were conducted in 2023:

- Twelve monthly facility-wide safety inspections, conducted by members of the WHSC. These inspections identified only minor issues that were immediately corrected.

An internal audit of the SRBT Health and Safety program was not conducted in 2023. The next scheduled internal audit of the program is scheduled to be completed in March 2024.

4.2.5 Minor Incidents

There were 11 minor incidents that met internal reporting criteria in 2023. A breakdown of the type of minor incidents occurring in 2023 is provided:

- Slip or Trip – 3
- Burn – 3
- Minor Cuts – 2
- Foreign Matter in Eye – 2
- Impact – 1

None of these minor incidents required a visit to the hospital, nor a report to the Workplace Safety and Insurance Board.

4.2.6 Lost Time Incidents

In 2023, no lost time incidents (LTI) occurred.

The following table summarizes the frequency of occurrence of LTIs over the past five years:

TABLE 14: LOST TIME INCIDENTS FIVE-YEAR TREND (2019-2023)

DESCRIPTION	2019	2020	2021	2022	2023
LOST TIME INCIDENTS	0	0	0	0	0

SRBT’s continuing goal is to have zero LTIs each year; the fact that this goal was achieved in 2023 speaks to the effectiveness of our conventional health and safety program.

4.2.7 Health and Safety Performance Targets

SRBT sets programmatic targets that are tracked by responsible safety committees throughout the year. Actions are taken that are intended to help the organization reach safety goals / objectives / targets, as well as when they may be missed.

In 2023, SRBT set the following targets for the area of Conventional Health and Safety:

- Zero lost time incidents (experienced zero – goal achieved)
- Less than or equal to 5 workplace injuries classified as **reportable** to Workplace Safety and Insurance Board (experienced zero – goal achieved)
- No more than 15 minor incidents (11 were recorded – goal achieved)

These three conventional health and safety targets remain unchanged for 2024.

4.2.8 Reporting

In accordance with Section 15.10 (1) of Part XV of the *Canada Occupational Health and Safety Regulations*, the Employer's Annual Hazardous Occurrence Report was submitted to Employment and Social Development Canada prior to March 1, 2023, as required.

In accordance with Section 9 of the *Policy Committees, Work Place Committees and Health and Safety Representatives Regulations*, the Work Place Committee Report was submitted to the Regional Safety Officer at Canada Labour prior to March 1, 2023, as required.

4.2.9 Health and Safety Training

The following training took place in 2023:

- The Manager – Safety and Security as well as another member of the SRBT H&S Committee attended an off-site conference in June. Training topics covered included: *Reimagining Your Office Ergonomics and MSD Prevention Program, Key Legislative Updates for Federally-Regulated Employees, and Machine Safety – CSA Z432 Standard Highlights.*
- All SRBT employees attended annual training that included Workplace Hazardous Materials Information Systems (WHMIS) and a new procedure for handling chemical spills in November.

4.2.10 Health and Safety Initiatives and Improvements

In 2023, the following health and safety initiatives and improvements were implemented:

- Two new health and safety procedures were created:
 - HAS-020, *Spill Response*
 - HAS-021, *Compressed Gas Cylinders*
- An additional spill kit was purchased specifically for Hydrofluoric Acid spills.

4.3 SCA – Environmental Protection

This section of the report will provide environmental protection compliance information, including results from environmental, effluent and groundwater monitoring, an assessment of compliance with any licence limits, historical trending where appropriate, and quality assurance/quality control results for the monitoring.

As part of SRBT's overall Environmental Protection Program, and as an input into the design of the environmental, effluent and groundwater monitoring programs, a conceptual site model (CSM) can provide a valuable representation of the factors and elements that are considered for monitoring within the boundaries of the program.

SRBT has been in operation since 1990, and has performed extensive monitoring of effluent, the environment and groundwater over the course of operations since then. In 2007, a comprehensive analysis was performed of the operations of the facility (including historical practices) in order to identify the sources of tritium that could affect the environment and the groundwater.

As well, in 2008 the significant environmental aspects of facility operation were initially established, and have been reviewed periodically since then in order to identify if there are other processes or operations that have been introduced that could lead to an impact on the environment.

These analyses, coupled with decades of operational experience, leads to the establishment of a simplified CSM that shows the significant pathways and environmental interactions pertaining to the release of the sole radiological contaminant of potential concern – tritium.

A pictographic representation of these source – receptor pathways is provided below in Figure 8, and should be consulted when considering the information provided in the next three subsections of this report.

On April 22, 2021, CNSC staff accepted SRBT's Environmental Risk Assessment^[20] (ERA), after comments and feedback had been addressed by SRBT^[21].

The ERA complies with the requirements of CSA Standard N288.6-12, *Environmental risk assessments for Class I nuclear facilities and uranium mines and mills*.

Human and ecological conceptual models of tritium interactions with the environment near the site are described within the ERA, and are included in Figures 9, 10, 11 and 12. Species included are conservatively representative of the local flora and fauna.

FIGURE 8: CONCEPTUAL SITE MODEL

Conceptual Site Model – SRBT Environmental Protection Program




FIGURE 9: HUMAN EXPOSURE PATHWAYS (HTO/T2, GASEOUS SOURCES)




FIGURE 10: HUMAN EXPOSURE PATHWAYS (HTO/T2, LIQUID SOURCES)




FIGURE 11: CONCEPTUAL ECOLOGICAL MODEL - TERRESTRIAL





FIGURE 12: CONCEPTUAL ECOLOGICAL MODEL - AQUATIC / RIPARIAN



As part of ensuring compliance with the reporting requirements of several N288-series of standards, SRBT has committed to ensuring that the information required by each applicable in-force standard to be reported annually pertaining to the Environmental Monitoring Program (EMP), Effluent Monitoring Program (EffMP) and Groundwater Monitoring Program (GMP) is included our annual compliance report.

A summary of the requirements of each of the applicable standards is provided here.

N288.4-10: Environmental monitoring programs at Class I nuclear facilities and uranium mines and mills: Section 11.2.2 – “The report shall include”:

TABLE 15: REPORTING REQUIREMENTS (N288.4-10)

	REQUIREMENT	REPORT SECTION
a	The results of the EMP, including measurements of the monitored hazardous and/or nuclear substances, physical stressors, and physical and biological parameters, including their statistical analyses (i.e. assessment of changes through space and time).	4.3.1 Appendices F through M
	Radiation doses calculated as doses to receptors where this is required.	4.3.5 Appendix R
	An assessment of the EMP results compared with the previous performance indicator targets.	4.3 Reference is made to previous years for performance indication.
	Documentation and justification of any deviations from field sampling, and analytical and data management procedures.	4.3.1.9 4.3.1.10
b	A summary and assessment of the field and laboratory QA/QC results including any non-conformances.	4.3.1.11
c	A summary of the audit and review results and subsequent corrective actions.	4.3.7
d	A summary of any proposed modifications to the EMP.	4.3.8
e	Documentation, assessment and review of any supplementary studies that have been initiated, completed, or both.	4.3.1.12

N288.5-11: Effluent monitoring programs at Class I nuclear facilities and uranium mines and mills: Section 11.2.2 – “The report shall include the results of the effluent monitoring program, including at least”:

TABLE 16: REPORTING REQUIREMENTS (N288.5-11)

	REQUIREMENT	REPORT SECTION
a	The amount or concentration of radioactive nuclear substances and hazardous substances released, as required to demonstrate compliance with regulatory limits and performance with respect to any other release target (e.g., action levels).	4.3.2 Action levels and other targets: 4.3.2.2, 4.3.2.4 and 4.3.2.5 Appendices O and P
b	The characteristics of the effluents.	4.3.2
c	The results of any toxicity testing conducted (if required).	Not applicable
d	A summary and assessment of the field and laboratory QA/QC results, including any non-conformance.	4.3.2.6
e	A statement of uncertainties inherent in the monitoring results and any dose estimates derived from them.	4.3.2.7 Dose estimates are derived using EMP data
f	A summary of the audit and review results and subsequent corrective actions.	4.3.7
g	A summary of any proposed modifications to the effluent monitoring program.	4.3.8
h	Documentation, assessment, and review of any supplementary studies that have been initiated or completed, or both.	4.3.2.8

N288.7-15: Groundwater protection programs at Class I nuclear facilities and uranium mines and mills: Section 11.1 – “A facility should prepare annual monitoring reports documenting the GWMP, which include the following”:

TABLE 17: REPORTING REQUIREMENTS (N288.7-15)

	REQUIREMENT	REPORT SECTION
a	The results of the GWMP including i) completeness of monitoring activities (identify if all planned activities were accomplished); ii) measurements of the monitored substances, biological, and hydrogeological parameters based on program objectives; and iii) data analysis and interpretations.	4.3.3 Appendix N
b	Relevant groundwater and hydrogeological characteristics.	4.3.3 Appendix Q
c	Doses calculated for the identified receptors (if doses have been calculated to aid in interpreting GWMP results).	Not applicable: GMP data does not contribute to dose calculations (residential wells fall within scope of EMP)
d	A summary and assessment of the field and laboratory QA results, including any non-conformances.	4.3.3.3
e	A statement of uncertainties inherent in the monitoring results and any dose estimates derived from them (where applicable).	4.3.3.4 4.3.5
f	Documentation of any supplementary studies that have been initiated, completed, or both (with references to the original studies).	4.3.3.5
g	An overall statement of data quality and discussion of results in terms of data performance and acceptance criteria.	4.3.3.6
h	Discussion of monitoring results in terms of program objectives and the conceptual site model.	4.3.3.7
Note 1	A summary of any audits performed, their results, and any corrective actions taken as a result of the audit’s findings may also be included in the reporting.	4.3.7

4.3.1 Environmental Monitoring

SRB Technologies (Canada) Inc. implements a comprehensive EMP that provides data for site-specific determination of tritium concentrations along the various pathways of exposure to the public due to the activities of the operations.

4.3.1.1 Passive Air Monitoring

A total of 40 passive air samplers (PAS) are deployed in the environment near the SRBT facility.

Air at each location is sampled over the course of a month, and an average air concentration for that period is derived based on the concentration of tritium in the sampling liquid, and known air sample exchange rates. Minimum detectable activities achieved throughout the year were less than 0.83 Bq/m³.

Thirty-five of these samplers are located within a two-kilometer radius from the SRBT facility, in eight sectors, ranging in stepped distances of 250, 500, 1,000, and 2,000 meters. The remaining five samplers are much further from the facility, and are intended to assess areas not expected to be impacted by routine SRBT processing operations.

Several duplicate samplers are included for quality assurance purposes. A number of samplers are also located specifically to provide data for assessment of the defined critical group members.

EMP PAS results for 2023 can be found in the table in **Appendix F** of this report, along with maps of the position of each sampler in the array. The table shows the average HTO concentrations for the samplers located in each of the eight compass sectors for the given sampling period.

Average tritium oxide in air concentrations for each month of 2023 are graphically represented for each of the eight compass sectors, and for each sampled distance from the facility, in **Appendix G** of this report.

The PAS array represents the tritium exposure pathways for inhalation and skin absorption; results are used in the calculations for effective dose to representative persons (members of the public) for 2023.

The sum of the average concentration for the passive air samplers in 2023 was 53.32 Bq/m³, a value that reflects a decrease of 12% from that observed in 2022 (60.54 Bq/m³).

Gaseous tritium oxide releases in 2023, as measured as part of the Effluent Monitoring Program, were 6,540 GBq, a value that reflects a decrease of 25.8% from that measured in 2022 (8,816 GBq).

Tritium oxide emissions, overall tritium emissions (oxide + elemental), and the sum of the average concentrations of all passive air samplers each showed a notable decrease compared to the previous year.

The decreases in these key metrics is primarily due to an overall reduction in the amount of tritium processed during the year, in particular during the summer months of 2023.

4.3.1.2 Precipitation Monitoring

Eight precipitation monitors are installed near existing air monitoring stations that are located approximately 250 m from the facility. Precipitation is collected as an aggregate sample over the course of each month, and then analyzed for tritium concentration.

Typically, SRBT's analysis of precipitation samples results in a minimum detectable activity (MDA) of between 19 - 21 Bq/L, a value which can identify significant concentrations of tritium in precipitation, and provides the resolution needed to determine the level of risk to the public and the environment.

Results in 2023 ranged between values that were below the MDA (54.2% of all samples obtained), up to a maximum of 227 Bq/L (sampler 18P for the Nov. 30, 2023 – Jan. 3, 2024 sample). The average tritium concentration for all eight precipitation monitors in 2023 was 38 Bq/L.

Table 18 summarizes the five-year trends for the average and maximum concentrations of collected precipitation samples for each calendar year.

TABLE 18: PRECIPITATION MONITORING FIVE-YEAR TREND (2019-2023)

DESCRIPTION	2019	2020	2021	2022	2023
AVERAGE CONCENTRATION DURING YEAR (Bq/L)	33	34	46	36	38
MAXIMUM CONCENTRATION DURING YEAR (Bq/L)	200	518	560	682	227

The geographic distribution of the sample collectors, coupled with any given meteorological conditions during and shortly after tritium processing, is expected to yield some variations in the data year-to-year.

Precipitation monitoring results for 2023, along with maps showing locations, and five-year trends for each sampling location, can be found in **Appendix H** of this report.

4.3.1.3 Muskrat River Monitoring

Samples of the Muskrat River downstream from SRBT are collected and analyzed monthly, in duplicate, as part of the EMP.

Typically, SRBT's analysis of Muskrat River samples results in an MDA of around 10 Bq/L, a value which can identify significant or abnormal concentrations of tritium in the river, and provides the resolution needed to determine the level of risk to the public and the environment.

All obtained samples of the river water in 2023 fell below the MDA for tritium concentration.

Muskkrat River monitoring results are trended in **Appendix I** of this report, along with a map showing the location where the sampling is routinely performed.

4.3.1.4 Downspout Runoff Monitoring

Tritium concentrations are measured in all facility downspouts (DS). The samples were collected periodically by SRBT for tritium concentration assessment. Runoff from downspouts was collected during three precipitation events during 2023, with a total of 34 samples being assessed.

The complete set of data for 2023 can be found in **Appendix J**, along with a map of the sample points around the building housing the facility.

The average tritium concentration for all downspouts / facility runoff samples in 2023 was 662 Bq/L; in 2022, this value was 182 Bq/L. Excluding sample results that were less than the MDA the average result in 2023 was 979 Bq/L.

The highest value measured was from heavy rainfall draining through DS-5 on September 18 (10,483 Bq/L), while the lowest values measured were 11 individual measurements that were less than the MDA of between 37 - 42 Bq/L.

Table 19 summarizes the five-year trends for the average and maximum concentrations of collected downspout runoff samples for each calendar year.

TABLE 19: DOWNSPOUT RUNOFF MONITORING FIVE-YEAR TREND (2019-2023)

DESCRIPTION	2019	2020	2021	2022	2023
AVERAGE CONCENTRATION DURING YEAR (Bq/L)	432	1,030	58	182	662
MAXIMUM CONCENTRATION DURING YEAR (Bq/L)	1,857	6,766	678	1,118	10,483

Downspout monitoring was originally initiated as part of the efforts to characterize sources of tritium impacting the groundwater aquifer beneath the SRBT facility in the mid-2000s. The practice of monitoring the water that is shed from the building rooftop drainage systems represents only a very brief snapshot in time of the conditions at the time of sampling.

There is no significant environmental risk from tritium present in downspout water, as demonstrated by the continuing decrease in groundwater tritium concentrations over the past several years.

It is important to recognize that there are several independent factors that influence the measured tritium concentration in any given sample, including:

- Significant rainfall after periods of time with elevated gaseous tritium-oxide releases tend to result in higher downspout concentrations being measured.
- How long it has been since a significant rainfall event has occurred – drier periods with high rates of tritium processing, followed by a significant rainfall tend to result in higher measured concentrations.
- The overlap between the time the rainfall event began and was detected, and the time it took to put tritium processing operations into a safe state. On occasion, quick onset of a heavy rainfall event can result in probable deposition from entrainment of any released tritium as processing operations are shut down.
- The time between the onset of precipitation and the act of obtaining the samples – the longer amount of time between these events, the lower the concentration of tritium is expected to be.

- Higher rainfall rates can lead to lower concentrations due to the sheer volume of water being drained; however, higher rates of rain can also cause rooftop ponding which will entrain surface tritium that may not have otherwise been taken up by a less intense rainfall.
- Weather factors during processing can influence deposition patterns. Rainfall that occurs quickly after periods of processing where west to east wind patterns dominate have a greater impact on downspout results, as opposed to other wind directions, since the active ventilation system effluent plume will drift over the facility.

The samples obtained on September 18 were at the very beginning of the first significant rain event in several weeks. For the months of August and September in particular, very dry conditions were observed (as compared to normal historical trends in precipitation for these months).

Between August 30 – September 17, the SRBT weather station measured a total of 6.2 mm of rain in total, occurring over few very short periods (i.e. no significant accumulation on the facility roof taking place). Under these abnormally dry conditions, deposition of tritium on the roof is not unexpected, particularly during stagnant conditions with respect to wind velocity.

A second factor contributing to the September 18 downspout measurements is that the previous operating week (Week 36 – Sep. 5-12, 2023) saw the highest weekly value of total gaseous tritium releases (1,068 GBq oxide + elemental) for the year.

Given these environmental and operational factors, and the immediacy with which the first samples were obtained relative to the beginning of the heavy rain event, elevated concentrations of tritium in the samples of this magnitude are not unexpected.

It is also important to note that **90 minutes after the first set of samples were obtained** on September 18, the second set of samples were taken. For DS-5, where at 0800h measurements of tritium in the runoff was 10,483 Bq/L (the maximum for the year), at 0930h this had fallen to 45 Bq/L. This illustrates the transient nature of these measurements.

The second-highest value measured in any of the three days where runoff water was monitored was 1,216 Bq/L (at DS-6 on June 26) – a value that is much more in line with historically observed values.

4.3.1.5 Produce Monitoring

Produce from a local produce stand and from three local residential gardens were sampled in 2023. Two residences whose gardens historically participated in our annual sampling campaigns no longer maintain those gardens, and thus did not participate in the campaign in 2023.

Produce samples were analyzed by a third-party laboratory to establish free-water tritium concentration, as well as an assessment of organically-bound tritium (OBT) in specific samples (produce sample minimum detectable activity = approximately 1.4 Bq/L of sample water measured; MDA per kilogram dependent on water content ratio of a given sample type).

The official results were compiled and reported to the participating members of the public, and are also posted on our website. This data is used in the calculations for annual estimated dose to the public for 2023.

The average free water tritium concentration in all produce offered by local residents in 2023 was 38 Bq/kg, compared to the 2022 value of 17 Bq/kg.

The maximum measured value in 2023 was 461 Bq/kg measured in a sample of green onions; this measurement represents less than 0.5% of the SRBT benchmark value, as well as the CNSC Independent Environmental Monitoring Program screening value for free water tritium in fresh produce.

At this same address, a cucumber sample was measured to be 99 Bq/kg, giving an average produce measurement at this location of 280 Bq/kg.

The average free water tritium concentration in locally-grown produce offered by commercial entities was measured as 3.8 Bq/kg, a measurement that is very close to the 3.0 Bq/kg obtained in 2022 from the same commercial farm gate.

For OBT, samples of tomatoes and cucumbers from a nearby residential garden were measured at a concentration of 2 Bq OBT/kg, while tomatoes from the commercial garden were also measured at 0 Bq OBT/kg.

Produce monitoring results and maps showing produce sampling locations for calendar year 2023 can be found in **Appendix K** of this report, along with graphs comparing the five-year trends of each location.

4.3.1.6 Milk Monitoring

Milk from both a local producer and from a local distributor is sampled every six months. The samples were collected and analyzed for tritium concentration by a qualified third-party laboratory. This data is also used in the calculations for critical group annual estimated dose for 2023.

Tritium concentrations in milk remained very low; all assayed samples were reported by the third-party laboratory to have measured less than the MDA of 4 Bq/L.

Milk monitoring results for 2023 can be found in **Appendix L** of this report.

4.3.1.7 Weather Data

A weather station near the facility collects data on a continuous basis.

Weather data is primarily used as part of the continuous meteorological characterization of the site over time, in support of the establishments of Derived Release Limits and the Environmental Risk Assessment.

See weather data for 2023 in **Appendix M**.


4.3.1.8 Residential Drinking Water

Several nearby local residences permit SRBT to acquire samples of drinking water during the year, to provide additional data for our program. A qualified, independent third-party laboratory collects and analyzes residential drinking water samples (MDA = approximately 3 – 4 Bq/L).

In 2023, the highest residential well tritium concentration value was measured as 39 Bq/L (in March at RW-3), a value that is well below the Ontario Drinking Water Quality Standard of 7,000 Bq/L.

Figure 13 illustrates the trend in maximum sampled tritium concentration in all sampled residential wells, since the program of monitoring began in 2006.

FIGURE 13: RESIDENTIAL WELL TRITIUM CONCENTRATION TREND (2006-2023)



Derived public dose values attributed to residential well water consumption have decreased since the inception of the monitoring program as a direct result of our efforts to minimize our environmental impact.

Residential well monitoring results for 2023 can be found in **Appendix N** of this report.

4.3.1.9 Deviations from Field Sampling Procedures

In 2023, there were no noted occurrences of deviations from field sampling procedures.

SRBT performs field sampling activities in accordance with internal procedures for the following sample types:

- EMP passive air sampling
- Precipitation
- Muskrat River
- Facility downspouts

Qualified independent service providers continue to sample and/or analyze the following sample types:

- Produce
- Milk
- Residential drinking water
- Sludge cake from the Pembroke Pollution Control Centre

4.3.1.10 Deviations from Analytical and Data Management Procedures

In 2023, there were no noted occurrences of deviations from analytical and data management procedures.

SRBT routinely analyzes the following sample types, in accordance with internal procedures:

- EMP passive air sampling
- Precipitation
- Muskrat River
- Facility downspouts

Qualified independent service providers continue to analyze the following sample types:

- Produce
- Milk
- Residential drinking water
- Sludge cake from the Pembroke Pollution Control Centre

SRBT manages all EMP data in accordance with controlled procedures; there were no deviations from these procedures in 2023.

4.3.1.11 Field and Laboratory QA/QC Results and Non-conformances

Field and laboratory EMP operations include several quality assurance and quality control (QA/QC) activities. Field QA/QC activities include duplicate sampling of five passive air sampler stations, duplicate sampling of the Muskrat River, and the use of trip / method blanks for samples obtained in the field.

Laboratory QA/QC activities include duplicate samples and blanks, as well as laboratory reference standards. Sample QC is tested using spike recovery and relative percent difference (RPD) tests.

The following table illustrates the five-year trend in pertinent QA/QC acceptance criteria data for the EMP:

TABLE 20: EMP QUALITY CONTROL DATA (2019-2023)

CALENDAR YEAR	2019	2020	2021	2022	2023
BENCHMARK VALUE EXCEEDANCES	0	0	0	0	0
DUPLICATE RPD EXCEEDANCES	4	10	7	1	0
REFERENCE STANDARD ACCURACY EXCEEDANCES	0	0	0	0	0
BLANK SAMPLE COUNT RATE > MAX ACCEPTABLE	0	0	0	0	0
SAMPLE ACQUISITION SUCCESS RATE	98.5%	98.5%	98.6%	99.5%	99.2%
QC CHECK PASS RATE	98.3%	96.6%	99.2%	99.9%	99.2%

In 2023, 627 of 632 (99.2%) of planned and routine environmental samples were successfully obtained. Samples not successfully obtained included:

- One PAS sample was lost during sample preparation for counting,
- Two homeowners who have traditionally participated in our residential produce sampling campaigns, but now no longer maintain a garden, or grow any harvestable produce at their residence.
- One residential well sample that could not be obtained due to the absence of the homeowner at the time of sampling, and
- One downspout (DS-1) did not drain sufficient water for sampling during a rain event in April.

A total of 881 of 888 (99.2%) of EMP acceptance criteria / QC checks / benchmark value comparisons passed their check. Most importantly, no measured EMP sample exceeded established benchmark values in 2023.

The seven checks that did not initially meet established criteria all related to the derivation of an RPD greater than 40% between two duplicate sample results for passive air sampling, where one sample was lower than the MDA for the analysis, while the duplicate was just slightly above that value.

In each case, the values of activity were re-verified by performing an RPD assessment of the raw sample results from liquid scintillation counting. These checks confirmed that in each case, the difference in counted activity between duplicate samples was negligible, and there were no quality control issues with the sampling and analysis process.

4.3.1.12 Supplementary Studies

The special annual sampling campaign (SASC) was conducted for the third consecutive year, focused on environmental media that had not been traditionally sampled as a matter of routine under the SRBT EMP prior to the ERA process having been completed in 2021.

The data collected as a result of the SASC will be used as input into future revisions of the ERA.

The sample types obtained in 2023 included:

- Muskrat River water, sediment and both riparian and aquatic vegetation, where the Boundary Road bridge crosses the river about 430 metres southeast of the SRBT facility,
- Organically-bound tritium in sampled milk,
- Average tritium concentration in air at the Pembroke Pollution Control Centre,
- Sampling of various plants that are culturally or economically significant to the Algonquins of Pikwakanagan First Nation (AOPFN).

In 2021, SRBT sampled culturally significant plants within the community of Pikwakanagan. The following year, similar types of plants were sampled at various distances on a geographic line between the SRBT facility and the community of Pikwakanagan.

For 2023, SRBT sampled sumac berries in and around Pembroke at three locations – on Paul Martin Drive, on Drive In Road, and at Riverside Park. This sample plan was designed to continue to add to the data on the concentration of tritium in plants that are important or culturally significant to the AOPFN community, and growing within their traditional territory, but not in the main community itself.

This strategy was chosen to acknowledge that AOPFN harvest activities take place throughout their traditional territory, not solely within the community itself. The AOPFN raised this specifically as an issue of concern in their intervention^[22] during the 2022 licence renewal process, when describing their assessment of the original ERA sample campaign:

“AOPFN membership use all our traditional territory to practice our rights, and this “collaborative sampling campaign” did not account for any rights-based activities that AOPFN members may engage in closer to the facility.”

(CMD 22-H8.8, page 17)

The maximum tritium concentration measured in sumac berries measured as part of this campaign were 23 Bq HTO/kg fresh and 13 Bq OBT/kg fresh weight, both from the samples obtained on Paul Martin Drive (coordinates: 45°48'00.4"N, 77°06'44.1"W).

The traditional use of these plants by Indigenous communities would not reasonably result in any significant risk to persons or the environment.

The data collected as part of the SASC will serve as a key input into the next iteration of the ERA, scheduled to be completed in 2026.

4.3.2 Effluent Monitoring

SRBT monitors two main effluent streams from the facility for tritium as part of our Effluent Monitoring Program (EffMP).

Tritium releases via the gaseous effluent pathway (active ventilation) are monitored in real time using 'bubbler' capture systems, with integrated measurements being conducted weekly to determine total emissions and verify compliance with licence limits and action levels.

Liquid effluent is retained in batches and analyzed for tritium concentration prior to being released to sewer.

4.3.2.1 Gaseous Effluent

In 2023, SRBT operated well within release limits to atmosphere that are described in the Licence Conditions Handbook associated with NSPFL-13.00/2034.

A summary of the releases of tritium oxide and total tritium in 2023 is tabled below:

TABLE 21: GASEOUS EFFLUENT DATA (2023)

NUCLEAR SUBSTANCE AND FORM	ANNUAL LIMIT (GBq)	2023 RELEASED (GBq)	% LIMIT	WEEKLY AVERAGE (GBq)	HIGHEST WEEKLY RELEASE (GBq)
TRITIUM AS TRITIUM OXIDE (HTO)	67,200	6,540	9.73%	126	289 (Oct. 10-17)
TOTAL TRITIUM AS TRITIUM OXIDE (HTO) AND TRITIUM GAS (HT)	448,000	20,520	4.58%	395	1,068 (Sep. 5-12)

Please refer to **Appendix O** for a complete data set on tritium releases to atmosphere in 2023.

Details on the past five years of gaseous effluent data are provided in the following table for ease of trend analysis:

TABLE 22: GASEOUS EFFLUENT FIVE-YEAR TREND (2019-2023)

NUCLEAR SUBSTANCE AND FORM	2019 (GBq)	2020 (GBq)	2021 (GBq)	2022 (GBq)	2023 (GBq)
TRITIUM OXIDE (HTO)	11,858	9,755	8,387	8,816	6,540
TOTAL TRITIUM AS TRITIUM OXIDE (HTO) AND TRITIUM GAS (HT)	31,769	25,186	28,729	26,590	20,520

When analyzing the operation's performance at reducing emissions it is important to assess the releases to atmosphere against the amount of tritium the facility processed. This provides an indication of how effective emission reduction initiatives have been successful in reducing emissions.

The following table defines the ratio of tritium released to atmosphere against tritium processed in the past five years:

TABLE 23: TRITIUM RELEASED TO ATMOSPHERE vs PROCESSED (2019-2023)

YEAR	TRITIUM RELEASED TO ATMOSPHERE (GBq/YEAR)	TRITIUM PROCESSED (GBq/YEAR)	% RELEASED TO PROCESSED	% INCREASE (+) REDUCTION (-)
2019	31,769	30,327,048	0.10	-10%
2020	25,186	27,887,498	0.09	-10%
2021	28,729	29,392,257	0.10	+11%
2022	26,590	26,940,372	0.10	No change
2023	20,520	23,202,623	0.09	-10%

In 2023, the ratio of tritium released versus processed remained stable compared to 2022. SRBT was able to achieve our internal target for this metric of $\leq 0.11\%$ for the year.

4.3.2.2 Air Emission Targets

SRBT set an annualized total tritium emission target at the beginning of 2023 of ≤ 625 GBq / week (averaged over the year), and was successful in meeting this target (395 GBq / week).

For calendar year 2024, SRBT has lowered the tritium emission target to a value of ≤ 600 GBq / week, on average, based upon projected production rates and the value achieved in 2023.

The 2023 targeted tritium released to processed ratio of $\leq 0.11\%$ was achieved (0.09%). The 2024 target has been kept set at $\leq 0.11\%$.

4.3.2.3 Liquid Effluent

In 2023, SRBT operated well within release limit to sewer that are described in the Licence Conditions Handbook associated with NSPFL-13.00/2034.

TABLE 24: LIQUID EFFLUENT DATA (2023)

NUCLEAR SUBSTANCE AND FORM	LIMIT (GBq/YEAR)	RELEASED (GBq/YEAR)	% OF LIMIT
TRITIUM – WATER SOLUBLE	200	0.68	0.34%

Total liquid effluent releases in 2023 decreased when compared to 2022 values (0.68 GBq in 2023 vs. 1.49 GBq in 2022).

Details on the past five years of liquid effluent data are provided in the table below for ease of trend analysis:

TABLE 25: LIQUID EFFLUENT FIVE-YEAR TREND (2019-2023)

NUCLEAR SUBSTANCE AND FORM	2019 (GBq)	2020 (GBq)	2021 (GBq)	2022 (GBq)	2023 (GBq)
TRITIUM – WATER SOLUBLE	13.67	5.56	3.07	1.49	0.68

Please refer to **Appendix P** for a complete data set of liquid effluent releases to sewer in calendar year 2023.

4.3.2.4 Liquid Effluent Target

SRBT set a total tritium release target at the beginning of 2023 of ≤ 8 GBq for the year, a target that was achieved. SRBT has set the total liquid effluent release target at 6 GBq for 2024.

4.3.2.5 Action Level Exceedances

In 2023, there were no instances of an action level exceedance related to gaseous or liquid effluent monitoring at SRBT.

4.3.2.6 Summary of Field and Laboratory QA/QC

Effluent monitoring activities include several procedural steps that ensure acceptable quality assurance and control, including duplicate / triplicate sample acquisition and measurement, the use of process blanks, and the measurement of known reference standards as part of the assay of activity in collected sample media.

All EffMP QA/QC results obtained in 2023 were acceptable with no identified non-conformances.

4.3.2.7 Statement of Uncertainties Inherent in Monitoring Results

Uncertainties associated with effluent monitoring at SRBT may be present at several points in the process.

For gaseous effluent, such uncertainties include: sampling representativeness, total airflow collected, catalytic efficiency of HT to HTO conversion, capture efficiency of sample media, standard measurement errors associated with liquid scintillation counting, sample acquisition errors such as volume of drawn sample for analysis, and errors in stack flow rate and differential pressure measurement.

For liquid effluent, such uncertainties include: sample volume, liquid effluent volume, standard measurement errors associated with liquid scintillation counting, and sample acquisition errors such as volume of drawn sample for analysis.

In order to ensure that the uncertainties inherent in monitoring results are kept acceptably low, SRBT ensures that a third-party laboratory conducts independent verification procedures of effluent monitoring processes on an annual basis. The acceptance criterion for deviation between the assessed measurements is +/-30%.

The first intercomparison exercise was conducted on February 28, with results showing the SRBT evaluation of the sample material to be 69.3% of that measured by the independent third-party laboratory.

An investigation was conducted, which determined that the sample analysis by SRBT was performed immediately after a quantity of heavily turbid wash water had been added to a collection barrel, resulting in a subsample that was highly quenched when counted on the SRBT liquid scintillation counter. This resulted in a far lower 'count rate' than would have been measured if the sample was allowed to settle rather than being counted immediately.

The third-party sample was allowed to settle before analysis, leading to a more accurate activity measurement, and ultimately the discrepancy between the two laboratories.

NCR-923 was raised to track the actions taken to remedy the problem. These included:

- Changing the procedure to ensure that collected water is given time to allow suspended solids to settle to the bottom of the barrel before obtaining liquid effluent samples.
- Introducing a data acceptance criterion for a minimum 'tSIE' quench indication parameter for any measured liquid effluent sample.
- A review of the past two years of data for any similar quenched samples that may have been measured lower than the true activity (only one instance found of a relatively low activity batch of effluent – no impact on safety or compliance).
- A repeat of the intercomparison exercise to confirm effectiveness of the actions taken (March 10 = SRBT result well within +/-30% of third-party results for effluent batch).

It has been concluded that the actions taken to address this problem have been effective.

The QA/QC processes associated with SRBT effluent monitoring contribute to the confidence in the results. As well, the data gathered from the EMP is assessed against the data from the gaseous effluent monitoring process on a frequent basis to verify that results are relatively consistent with each other.

The inherent uncertainties associated with effluent monitoring are well within acceptable bounds when contrasted against the measured releases, and the licenced limits for releases by each pathway.

4.3.2.8 Supplementary Studies

In 2023, no supplementary studies were conducted relating to effluent monitoring at SRBT, other than the investigation into the aforementioned exceedance of acceptance criterion for the third-party laboratory intercomparison exercise for liquid effluent.

4.3.2.9 Hazardous Substance Releases

In 2023, SRBT continued to operate the facility under a Certificate of Approval (Air), number 5310-4NJQE2, issued by the Ontario Ministry of the Environment in accordance with section 9 of the Ontario Environmental Protection Act.

No hazardous non-radiological substances are released from the facility through either gaseous or liquid effluent pathways in any significant quantity.

4.3.3 Groundwater Monitoring

SRBT implements and maintains a comprehensive Groundwater Monitoring Program (GMP) as part of our Groundwater Protection Program.

Dedicated, engineered sampling wells are used to establish tritium concentrations in the groundwater each month at various depths and in differing geologic strata. Variations are trended over time to measure the response of historical contamination of the local aquifer.

Since the program was established, groundwater measurements and trends have been in very good agreement with established hydrogeological modelling predictions.

While most of the released tritium in the air is dispersed, some of it will reach the soil through dry and wet deposition. Infiltrated precipitation brings tritium into the groundwater below it. The deposition of tritium on and around the facility from air emissions and resulting soil moisture and standing water are the sole direct contributor to tritium found in groundwater. Groundwater is affected by the percolation of soil moisture and standing water from the surface.

Tritium concentrations in groundwater are expected to gradually decrease once all historical emissions have flushed through the system and/or decayed with some influence of higher concentrations in nearby wells from lateral underground water flow. This continues to be confirmed by routine monitoring of the existing network of wells. The rate at which this decrease occurs is dependent on the level and speed of recharge of the groundwater on and around the SRBT facility.

4.3.3.1 Groundwater Tritium Concentration

Groundwater monitoring well results for 2023 can be found in **Appendix N** of this report.

MW06-10: The highest average tritium concentration in any well remains in monitoring well MW06-10 which is directly beneath the area where the active ventilation stacks are located. As of the end of 2023, this represents the only well where tritium concentration exceeds the Ontario Drinking Water Guideline value of 7,000 Bq/L.

The average concentration of tritium measured in MW06-10 in 2023 was 26,220 Bq/L, a value that is nearly unchanged from the average measured in 2022 (26,163 Bq/L).

A graph trending the average annual concentration of tritium in MW06-10 since commissioning of the well is provided in Figure 14, while the five-year trend is highlighted in Figure 15 in red, along with trends of the maximum (green) and minimum (blue) monthly measurements each year.

FIGURE 14: MW06-10 AVERAGE TRITIUM CONCENTRATION TREND (2006-2023)





FIGURE 15: MW06-10 FIVE-YEAR TREND (2019-2023)




MW07-13: The average concentration of MW07-13 continues to fall; in 2023 the average measurement was 2,038 Bq/L. This well exhibits the highest tritium concentration of any monitoring well, other than MW06-10.

This well was the last monitoring well to have been measured above the provincial drinking water guideline value of 7,000 Bq/L (April 2018), other than MW06-10. The concentration of tritium at this location has continued to consistently trend downward over time.


A graph trending the average annual concentration of tritium in MW07-13 since commissioning of the well is Figure 16.

FIGURE 16: MW07-13 AVERAGE TRITIUM CONCENTRATION TREND (2007-2023)



The five-year trend is highlighted in Figure 17 in red, along with trends of the maximum (green) and minimum (blue) monthly measurements each year.

FIGURE 17: MW07-13 FIVE-YEAR TREND (2019-2023)



Looking back over the past several years, tritium concentrations in all monitoring wells have continued to decline.

The average annual concentration across all dedicated monitoring wells in 2023 is less than 40% of average in 2015. Well MW06-1 has shown the greatest change (90% decrease compared to 2015 conditions), while MW07-12 exhibited the smallest change (5% decrease).

In 2023, 24 out of 29 SRBT-installed groundwater monitoring wells exhibited an average tritium concentration that was lower than the previous year.

Table 26 compares the annualized average tritium concentration of the 29 dedicated, SRBT-installed groundwater monitoring wells for eight years, between 2015 through 2023.

Comparisons are made in the columns on the right-hand side of the table using a three-colour gradient, where green indicates decreasing concentrations, white indicating stable, and red indicating a relative increase for the years being compared.

TABLE 26: 2015-2023 AVERAGE TRITIUM CONCENTRATION IN MONITORING WELLS

Well ID	2023	2022	2021	2020	2019	2018	2017	2016	2015	2023/2022	2023/2021	2023/2020	2023/2019	2023/2018	2023/2017	2023/2016	2023/2015
	(Annualized average tritium Bq/L)									(%)							
MW06-1	424	456	651	762	1,045	1,334	1,946	2,753	4,338	93.1	65.2	55.7	40.6	31.8	21.8	15.4	9.8
MW06-2	489	609	736	877	1,031	1,160	1,166	1,467	1,965	80.3	66.4	55.8	47.5	42.2	42.0	33.4	24.9
MW06-3	141	166	199	244	367	469	683	1,029	1,218	85.3	71.1	57.9	38.6	30.2	20.7	13.7	11.6
MW06-8	475	507	550	579	679	724	780	848	906	93.7	86.4	82.0	70.0	65.7	60.9	56.0	52.5
MW06-9	1,044	1,127	1,366	1,527	1,774	1,952	2,224	2,476	2,731	92.6	76.4	68.4	58.8	53.5	46.9	42.2	38.2
MW06-10	26,220	26,163	30,153	29,513	34,592	40,208	33,520	48,189	51,635	100.2	87.0	88.8	75.8	65.2	78.2	54.4	50.8
MW07-11	759	811	858	924	1,053	1,122	1,099	1,344	1,521	93.5	88.5	82.1	72.0	67.6	69.0	56.5	49.9
MW07-12	438	416	435	422	425	468	467	469	463	105.2	100.6	103.9	103.1	93.6	93.8	93.3	94.5
MW07-13	2,038	2,574	3,527	4,406	5,647	6,937	8,642	10,576	13,237	79.2	57.8	46.2	36.1	29.4	23.6	19.3	15.4
MW07-15	990	1,004	1,076	1,262	1,399	1,505	1,617	1,810	1,680	98.6	92.0	78.4	70.8	65.8	61.2	54.7	58.9
MW07-16	624	685	897	1,003	1,240	1,433	1,649	1,879	2,188	91.1	69.6	62.2	50.3	43.6	37.9	33.2	28.5
MW07-17	237	267	296	272	338	359	335	602	780	89.0	80.2	87.4	70.2	66.1	70.9	39.4	30.4
MW07-18	649	842	1,102	1,494	2,000	2,192	2,739	3,690	5,491	77.1	58.9	43.4	32.5	29.6	23.7	17.6	11.8
MW07-19	650	665	959	1,198	1,468	1,889	1,926	2,500	3,222	97.8	67.8	54.3	44.3	34.4	33.8	26.0	20.2
MW07-20	222	244	296	326	438	498	571	670	775	91.0	75.1	68.1	50.7	44.6	38.9	33.2	28.7
MW07-21	289	351	363	393	545	778	879	1,009	1,121	82.3	79.5	73.5	53.0	37.1	32.9	28.6	25.8
MW07-22	611	639	729	783	921	974	1,023	1,131	1,171	95.5	83.8	77.9	66.3	62.7	59.7	54.0	52.1
MW07-23	908	1,013	1,147	1,252	1,443	1,572	1,743	1,929	2,206	89.7	79.2	72.6	62.9	57.8	52.1	47.1	41.2
MW07-24	1,226	1,340	1,511	1,644	1,839	1,928	2,022	2,206	2,314	91.5	81.1	74.6	66.6	63.6	60.6	55.6	53.0
MW07-26	238	291	421	514	697	904	1,190	1,491	1,941	81.8	56.4	46.2	34.1	26.3	20.0	15.9	12.2
MW07-27	1,131	1,439	1,696	1,994	2,683	3,136	3,589	4,292	4,869	78.6	66.7	56.7	42.1	36.1	31.5	26.3	23.2
MW07-28	444	520	670	705	843	1,017	1,063	1,311	1,446	85.3	66.2	62.9	52.6	43.6	41.7	33.8	30.7
MW07-29	667	760	1,075	1,485	2,058	2,415	2,472	3,395	3,950	87.8	62.1	44.9	32.4	27.6	27.0	19.6	16.9
MW07-31	255	240	325	182	352	407	186	440	756	106.4	78.5	140.2	72.5	62.6	137.2	57.9	33.7
MW07-32	44	42	54	59	75	70	76	155	128	105.4	80.5	74.2	58.3	62.9	57.6	28.3	34.2
MW07-34	753	908	1,153	1,297	1,526	1,889	2,291	2,822	3,312	83.0	65.3	58.1	49.4	39.9	32.9	26.7	22.7
MW07-35	1,076	1,297	1,550	1,898	2,256	2,637	3,015	3,448	3,945	82.9	69.4	56.7	47.7	40.8	35.7	31.2	27.3
MW07-36	1,112	1,105	1,154	1,468	1,716	2,008	2,109	2,618	2,892	100.7	96.4	75.8	64.8	55.4	52.8	42.5	38.5
MW07-37	658	677	717	763	821	830	871	989	1,009	97.2	91.7	86.3	80.1	79.3	75.5	66.6	65.2
AVERAGE	1,545	1,626	1,920	2,043	2,458	2,856	2,824	3,708	4,249	95.0	80.5	75.6	62.9	54.1	54.7	41.7	36.4
Average aquifer concentrations have decreased 63.6% since 2015.																	63.6

Several factors can influence the concentration of tritium in any given well, including the rate of precipitation accumulation, contaminant dispersion patterns, and the lateral and vertical migration of historical contaminant plumes. Measured concentrations may also be reflective of operational conditions from many years ago.

4.3.3.2 Groundwater Level Measurements

The water levels are measured in monitoring wells prior to purge and sampling. Analysis of this data shows consistent trends from year to year when comparing season to season.

A compilation of groundwater level measurements for 2023 can be found in **Appendix Q** of this report.

4.3.3.3 Summary of Field and Laboratory QA/QC

Field and laboratory operations pertaining to groundwater monitoring include several quality assurance and quality control activities.

Quality control activities include duplicate sampling of certain wells, duplicate laboratory subsampling, and the use of trip / method blanks during sampling campaigns.

As well, several quality control checks are performed as part of the liquid scintillation counting procedures employed by both the third party and SRBT.

In 2023, 114 samples of groundwater were successfully obtained and analyzed, with all planned groundwater monitoring activities being accomplished, except for one instance where MW06-8 was found to be frozen in March, and one instance where MW06-3 was found to be dry in September.

As such, 98.3% of all GMP samples were successfully obtained and measured in 2023, which is an excellent rate of sampling success.

There were no failures of field or laboratory quality control checks for GMP data during 2023.

SRBT's Groundwater Monitoring Program requires the completion of an inter-laboratory testing exercise on an annual basis. This exercise is typically completed during the June sampling period.

Five groundwater monitoring wells were sampled by SRBT in duplicate on June, and were subsequently analyzed for tritium concentration by both SRBT and a qualified, independent laboratory.

The results obtained fell well within the acceptance criteria of +/-20% relative difference, adding confidence in the quality and accuracy of the data generated by the program.

4.3.3.4 Statement of Uncertainties Inherent in Monitoring Results

Uncertainties associated with SRBT groundwater monitoring may be present at certain points in the process.

The main uncertainties relate to standard measurement errors associated with liquid scintillation counting, and sample acquisition errors such as volume of drawn sample for analysis.

In order to provide assurance of accuracy and precision, SRBT conducts an annual intercomparison sampling and analysis activity with our primary contracted third party in June, as required by the GMP.

Five wells were sampled and measured by SRBT concurrently with the third party, with good agreement between the results obtained in-house and those obtained by the contracted service provider.

The inherent uncertainties associated with groundwater monitoring are well within acceptable bounds when contrasted against the tritium concentrations that may present an unacceptable risk to the public.

4.3.3.5 Supplementary Studies

In 2023, no supplementary studies were conducted relating to groundwater monitoring at SRBT.

4.3.3.6 Data Quality, Performance and Acceptance Criteria

Overall, the quality of data gathered as part of SRBT groundwater monitoring activities is successful in ensuring a high level of performance in monitoring, and in demonstrating that acceptance criteria (such as the limits on dose to the public) continue to be met.

All trip blanks, field duplicates, laboratory duplicates and quality control checks during liquid scintillation counting met performance criteria throughout 2023.

4.3.3.7 Program Objectives and Conceptual Site Model

The main objective of the GMP implemented by SRBT is to provide information to assess risks from site-affected groundwater to human health and the environment, ultimately to determine if the risk to the environment and the public from SRBT operations remains acceptably low.

Only one well monitored on a regular basis exceeds the Ontario Drinking Water Guideline value of 7,000 Bq/L. This well is a dedicated, engineered groundwater monitoring well very near to the facility within a secured area, and is not available to be used as a source of water consumption.

With respect to the conceptual site model, the highest average concentration of potable groundwater obtained from a residential well continues to show a generally stable or decreasing trend over time (see discussion in section 4.3.1.8 earlier in this report).

SRBT concludes that the comprehensive array of groundwater monitoring activities conducted continue to meet program objectives, and adheres to the conceptual site model developed as part of the Environmental Management System, as illustrated earlier in this report in Figure 8.

4.3.4 Other Monitoring

On occasion SRBT conducts monitoring of other environmental media in order to provide continued assurance of the safety of our operations.

4.3.4.1 Soil Monitoring

No soil monitoring was conducted in 2023.

4.3.4.2 Sludge Monitoring

In March and September 2023, SRBT collected routine samples of sludge cake from the Pembroke Pollution Control Centre.

These samples are analyzed for the concentration of tritium in the free water contained within (expressed in Bq/L), as well as for organically-bound tritium in the dry mass of material (expressed in Bq/kg).

Sludge data does not factor into the calculation of public dose; however, given previously expressed stakeholder interest, SRBT has integrated sludge cake monitoring as part of the routine EMP activities.

All sludge samples are analyzed by an independent laboratory. The averaged annual results obtained for the past five years are tabled below.

TABLE 27: SLUDGE MONITORING (2019-2023)

NUCLEAR SUBSTANCE AND FORM	2019	2020	2021	2022	2023
FREE-WATER TRITIUM (Bq/L)	41	31	30	44	11
OBT FRESH WEIGHT (Bq/kg)	216	260	167	468	93

4.3.5 Public Dose

The calculation methods used to determine the dose to the representative persons as defined in the SRBT EMP are described in the program and in procedure EMP-014, *Interpretation and Reporting Requirements for EMP Data*.

All data and tables relating to the calculation of the dose to the public can be found in **Appendix R**.

For 2023, the dose has been calculated using the effective dose coefficients found in Canadian Standards Association (CSA) Guideline N288.1-14^[23].

TABLE 28: CSA GUIDELINE N288.1-14 EFFECTIVE DOSE COEFFICIENTS FOR H-3

AGE GROUP	EFFECTIVE DOSE COEFFICIENT – INHALATION (HTO) ($\mu\text{Sv/Bq}$)	EFFECTIVE DOSE COEFFICIENT – INGESTION (HTO) ($\mu\text{Sv/Bq}$)	EFFECTIVE DOSE COEFFICIENT – INGESTION (OBT) ($\mu\text{Sv/Bq}$)
INFANT	8.0E-5	5.3E-5	1.3E-4
CHILD	3.8E-5	2.5E-5	6.3E-5
ADULT	3.0E-5	2.0E-5	4.6E-5

NOTE: The dose coefficients listed for inhalation account for skin absorption, as per Table C.1 of N288.1-14.

The dose assessed for the group of representative persons is a summation of:

- Tritium uptake from inhalation and absorption through skin at the place of residence and/or the place of work, ($P_{(i)19}$ and $P_{(e)19}$), and
- Tritium uptake due to consumption of well water (P_{29}), and
- Tritium uptake due to consumption of produce (P_{49}), and
- Tritium uptake due to consumption of dairy products (P_{59}).

Dose due to inhalation

The closest residence to SRBT is located by passive air sampler NW250 approximately 240 meters from the point of release. The 2023 average concentration of tritium oxide in air at passive air sampler NW250 has been determined to be **1.87 Bq/m³**.

Three passive air samplers are located close to the SRBT facility and represent the tritium oxide in air ($P_{(i)19}$ and $P_{(e)19}$) concentrations for the representative person (adult worker) at samplers 1, 2, and 13.

The sampler indicating the highest tritium oxide in air concentration is used to calculate the P_{19} dose values while at work. The highest average result for 2023 between these samplers is **5.06 Bq/m³** at PAS # 1.

Inhalation rates for each of the three age groups from N288.1-14^[24] are as follows:

TABLE 29: CSA GUIDELINE N288.1-14 INHALATION RATES

AGE GROUP	INHALATION RATE (m ³ /a)
INFANT	2,740
CHILD	7,850
ADULT	8,400

Inhalation dose to adult workers is calculated using the inhalation rates found in CSA Guideline N288.1-14^[24], and assuming 2,080 hours (23.744%) of work per year with 6,680 hours (76.256%) at home (a total of 8,760 hours per year).

$P_{(i)19r}$: Adult worker dose due to HTO inhaled at residence

The average value for tritium oxide in air for the sampler taken as representing the place of residence for the defined representative person equals 1.87 Bq/m³.

$$\begin{aligned}
 P_{(i)19r} &= [H-3_{air}] \text{ (Bq/m}^3\text{)} \times \text{Resp. Rate (m}^3\text{/a)} \times \text{Occup. Factor} \times \text{DCF}_{H3} \text{ (}\mu\text{Sv/Bq)} \\
 &= 1.87 \text{ Bq/m}^3 \times 8,400 \text{ m}^3\text{/a} \times 0.76256 \times 3.0\text{E-}05 \mu\text{Sv/Bq} \\
 &= 0.359 \mu\text{Sv/a}
 \end{aligned}$$

$P_{(i)19w}$: Adult worker dose due to HTO inhaled at work

Taking the highest concentration between Passive Air Samplers #1, #2, and #13 is Passive Air Samplers #1 at 5.06 Bq/m³.

$$\begin{aligned}
 P_{(i)19w} &= [H-3_{air}] \text{ (Bq/m}^3\text{)} \times \text{Resp. Rate (m}^3\text{/a)} \times \text{Occup. Factor} \times \text{DCF}_{H3} \text{ (}\mu\text{Sv/Bq)} \\
 &= 5.06 \text{ Bq/m}^3 \times 8,400 \text{ m}^3\text{/a} \times 0.23744 \times 3.0\text{E-}05 \mu\text{Sv/Bq} \\
 &= 0.303 \mu\text{Sv/a.}
 \end{aligned}$$

$P_{(i)19}$: Adult resident dose due to HTO inhaled at residence

The average value for tritium oxide in air for the sampler representing the place of residence for the defined representative person equals 1.87 Bq/m³:

$$\begin{aligned}
 P_{(i)19} &= [H-3_{air}] \text{ (Bq/m}^3\text{)} \times \text{Resp. Rate (m}^3\text{/a)} \times \text{DCF}_{H3} \text{ (}\mu\text{Sv/Bq)} \\
 &= 1.87 \text{ Bq/m}^3 \times 8,400 \text{ m}^3\text{/a} \times 3.0\text{E-}05 \mu\text{Sv/Bq} \\
 &= 0.471 \mu\text{Sv/a}
 \end{aligned}$$

P_{(i)19}: Infant resident dose due to HTO inhaled at residence

The average value for tritium oxide in air for the sampler representing the place of residence for the defined representative person equals 1.87 Bq/m³:

$$\begin{aligned} P_{(i)19} &= [H-3_{air}] \text{ (Bq/m}^3\text{)} \times \text{Resp. Rate (m}^3\text{/a)} \times \text{DCF}_{H3} \text{ (}\mu\text{Sv/Bq)} \\ &= 1.87 \text{ Bq/m}^3 \times 2,740 \text{ m}^3\text{/a} \times 8.0\text{E-}05 \mu\text{Sv/Bq} \\ &= 0.410 \mu\text{Sv/a} \end{aligned}$$

P_{(i)19}: Child resident dose due to HTO inhaled at residence

The average value for tritium oxide in air for the sampler representing the place of residence for the defined representative person equals 1.87 Bq/m³:

$$\begin{aligned} P_{(i)19} &= [H-3_{air}] \text{ (Bq/m}^3\text{)} \times \text{Resp. Rate (m}^3\text{/a)} \times \text{DCF}_{H3} \text{ (}\mu\text{Sv/Bq)} \\ &= 1.87 \text{ Bq/m}^3 \times 7,850 \text{ m}^3\text{/a} \times 3.8\text{E-}05 \mu\text{Sv/Bq} \\ &= 0.558 \mu\text{Sv/a} \end{aligned}$$

Dose due to skin absorption

The dose due to skin absorption is wholly accounted for by the application of the inhalation dose conversion factors applied above. Please see CSA N288.1-14, Table C.1 footnotes for details on dose conversion factors and how they account for skin absorption.

Dose due to consumption of well water

The tritium uptake due to consumption of well water is calculated by taking the average tritium concentration of the water sampled.

Using the following annual consumption rates (at the 95th percentile) derived from information found in CSA Guideline N288.1-14^[25]:

TABLE 30: CSA GUIDELINE N288.1-14 WATER CONSUMPTION RATES

AGE GROUP	WELL WATER CONSUMPTION RATE (L/a)
INFANT	305.7
CHILD	482.1
ADULT	1,081.1

In 2023, the highest average concentration in a residential well used as the sole source of the drinking water was found in RW-3 at 183 Mud Lake Road, equal to **39 Bq/L**. This value will therefore be used in the calculation of the public dose.

P₂₉: Adult dose due to consumption of well water

$$\begin{aligned}
 P_{29} &= [H-3]_{\text{well}} \times M \times 2.0E-05 \text{ } \mu\text{Sv/Bq}; \\
 &= [39 \text{ Bq/L}] \times 1,081.1 \text{ L/a} \times 2.0E-05 \text{ } \mu\text{Sv/Bq} \\
 &= 0.843 \text{ } \mu\text{Sv/a}
 \end{aligned}$$

P₂₉: Infant dose due to consumption of well water

$$\begin{aligned}
 P_{29} &= [H-3]_{\text{well}} \times M \times 5.3E-05 \text{ } \mu\text{Sv/Bq}; \\
 &= [39 \text{ Bq/L}] \times 305.7 \text{ L/a} \times 5.3E-05 \text{ } \mu\text{Sv/Bq} \\
 &= 0.632 \text{ } \mu\text{Sv/a}
 \end{aligned}$$

P₂₉: Child dose due to consumption of well water

$$\begin{aligned}
 P_{29} &= [H-3]_{\text{well}} \times M \times 2.5E-05 \text{ } \mu\text{Sv/Bq}; \\
 &= [39 \text{ Bq/L}] \times 482.1 \text{ L/a} \times 2.5E-05 \text{ } \mu\text{Sv/Bq} \\
 &= 0.470 \text{ } \mu\text{Sv/a}
 \end{aligned}$$

Dose due to consumption of produce

The tritium uptake due to consumption of produce, both locally purchased and home grown is calculated by taking the average tritium concentration of produce purchased from the local market and assuming the consumption of 70% of the annual total of produce from this source, and by taking the average tritium concentration from local gardens and assuming the consumption of 30% of the annual total of produce from this source.

These fractions are based upon the site-specific survey previously conducted by SRBT, which determined that the home-grown fraction of plant products consumed by residents in the surrounding area was approximately 30% - a slightly higher value than that recommended in the generic guidance of N288.1-14 (20-25%).

Using the following annual consumption rates for produce derived using information found in CSA Guideline N288.1-14^[26]:

TABLE 31: CSA GUIDELINE N288.1-14 PRODUCE CONSUMPTION RATES

AGE GROUP	FRUIT CONSUMPTION RATE (Kg/a)	ABOVE-GROUND VEGETABLES CONSUMPTION RATE (Kg/a)	ROOT VEGETABLES CONSUMPTION RATE (Kg/a)	TOTAL CONSUMPTION RATE (Kg/a)
INFANT	76.6	36.1	12.1	124.8
CHILD	124.4	97.6	43.2	265.2
ADULT	149.2	192.3	71.8	413.3

The average tritium concentration in produce purchased from the sampled market in 2023 was **3.8 Bq/kg**, while the highest average concentration in produce from a local garden was **280 Bq/kg**.

P₄₉: Adult dose due to consumption of produce (HTO)

$$\begin{aligned}
 P_{49\text{HTO}} &= [[H_{\text{prod,market}}] + [H_{\text{prod,res}}]] \times 2.0\text{E-}05 \mu\text{Sv/Bq} \\
 &= [[H\text{-}3_{\text{veg}}] (\text{Bq/kg}) \times (\text{kg}) \times 0.7] + [H\text{-}3_{\text{veg}}] (\text{Bq/kg}) \times (\text{kg}) \times 0.3]] \times 2.0\text{E-}5 \mu\text{Sv/Bq} \\
 &= [[3.8 \text{ Bq/kg} \times 413.3 \text{ kg/a} \times 0.7] + [280 \text{ Bq/kg} \times 413.3 \text{ kg/a} \times 0.3]] \times 2.0\text{E-}5 \mu\text{Sv/Bq} \\
 &= 0.716 \mu\text{Sv/a}
 \end{aligned}$$

P₄₉: Infant dose due to consumption of produce (HTO)

$$\begin{aligned}
 P_{49\text{HTO}} &= [[H_{\text{prod,market}}] + [H_{\text{prod,res}}]] \times 5.3\text{E-}05 \mu\text{Sv/Bq} \\
 &= [[H\text{-}3_{\text{veg}}] (\text{Bq/kg}) \times (\text{kg}) \times 0.7] + [H\text{-}3_{\text{veg}}] (\text{Bq/kg}) \times (\text{kg}) \times 0.3]] \times 5.3\text{E-}5 \mu\text{Sv/Bq} \\
 &= [[3.8 \text{ Bq/kg} \times 124.8 \text{ kg/a} \times 0.7] + [280 \text{ Bq/kg} \times 124.8 \text{ kg/a} \times 0.3]] \times 5.3\text{E-}5 \mu\text{Sv/Bq} \\
 &= 0.573 \mu\text{Sv/a}
 \end{aligned}$$

P₄₉: Child dose due to consumption of produce (HTO)

$$\begin{aligned}
 P_{49\text{HTO}} &= [[H_{\text{prod,market}}] + [H_{\text{prod,res}}]] \times 2.5\text{E-}05 \mu\text{Sv/Bq} \\
 &= [[H\text{-}3_{\text{veg}}] (\text{Bq/kg}) \times (\text{kg}) \times 0.7] + [H\text{-}3_{\text{veg}}] (\text{Bq/kg}) \times (\text{kg}) \times 0.3]] \times 2.5\text{E-}5 \mu\text{Sv/Bq} \\
 &= [[3.8 \text{ Bq/kg} \times 265.2 \text{ kg/a} \times 0.7] + [280 \text{ Bq/kg} \times 265.2 \text{ kg/a} \times 0.3]] \times 2.5\text{E-}5 \mu\text{Sv/Bq} \\
 &= 0.574 \mu\text{Sv/a}
 \end{aligned}$$

SRBT directly monitored OBT concentrations in tomatoes and cucumbers in residential gardens, as well as from tomatoes from the commercial market garden.

The OBT concentration from the residential produce was measured as 2.0 Bq/kg, while for the commercial produce a value of 0.3 Bq/kg was measured.

P₄₉: Adult dose due to consumption of produce (OBT)

$$\begin{aligned}
 P_{49\text{OBT}} &= [[H_{\text{prod,market}}] + [H_{\text{prod,res}}]] \times 4.6\text{E-}05 \text{ } \mu\text{Sv/Bq} \\
 &= [[H\text{-}3_{\text{veg}}] (\text{Bq/kg}) \times (\text{kg}) \times 0.7] + [H\text{-}3_{\text{veg}}] (\text{Bq/kg}) \times (\text{kg}) \times 0.3]] \times 4.6\text{E-}5 \text{ } \mu\text{Sv/Bq} \\
 &= [[0.3 \text{ Bq/kg} \times 413.3 \text{ kg/a} \times 0.7] + [2.0 \text{ Bq/kg} \times 413.3 \text{ kg/a} \times 0.3]] \times 4.6\text{E-}5 \text{ } \mu\text{Sv/Bq} \\
 &= 0.015 \text{ } \mu\text{Sv/a}
 \end{aligned}$$

P₄₉: Infant dose due to consumption of produce (OBT)

$$\begin{aligned}
 P_{49\text{OBT}} &= [[H_{\text{prod,market}}] + [H_{\text{prod,res}}]] \times 1.3\text{E-}4 \text{ } \mu\text{Sv/Bq} \\
 &= [[H\text{-}3_{\text{veg}}] (\text{Bq/kg}) \times (\text{kg}) \times 0.7] + [H\text{-}3_{\text{veg}}] (\text{Bq/kg}) \times (\text{kg}) \times 0.3]] \times 1.3\text{E-}4 \text{ } \mu\text{Sv/Bq} \\
 &= [[0.3 \text{ Bq/kg} \times 124.8 \text{ kg/a} \times 0.7] + [2.0 \text{ Bq/kg} \times 124.8 \text{ kg/a} \times 0.3]] \times 1.3\text{E-}4 \text{ } \mu\text{Sv/Bq} \\
 &= 0.013 \text{ } \mu\text{Sv/a}
 \end{aligned}$$

P₄₉: Child dose due to consumption of produce (OBT)

$$\begin{aligned}
 P_{49\text{OBT}} &= [[H_{\text{prod,market}}] + [H_{\text{prod,res}}]] \times 6.3\text{E-}5 \text{ } \mu\text{Sv/Bq} \\
 &= [[H\text{-}3_{\text{veg}}] (\text{Bq/kg}) \times (\text{kg}) \times 0.7] + [H\text{-}3_{\text{veg}}] (\text{Bq/kg}) \times (\text{kg}) \times 0.3]] \times 6.3\text{E-}5 \text{ } \mu\text{Sv/Bq} \\
 &= [[0.3 \text{ Bq/kg} \times 265.2 \text{ kg/a} \times 0.7] + [2.0 \text{ Bq/kg} \times 265.2 \text{ kg/a} \times 0.3]] \times 6.3\text{E-}5 \text{ } \mu\text{Sv/Bq} \\
 &= 0.014 \text{ } \mu\text{Sv/a}
 \end{aligned}$$

Total dose due to consumption of produce:

P₄₉: Adult dose due to consumption of produce (HTO + OBT)

$$\begin{aligned}
 P_{49} &= P_{49\text{HTO}} + P_{49\text{OBT}} \\
 &= 0.716 \text{ } \mu\text{Sv/a} + 0.015 \text{ } \mu\text{Sv/a} \\
 &= 0.731 \text{ } \mu\text{Sv/a}
 \end{aligned}$$

P₄₉: Infant dose due to consumption of produce (HTO + OBT)

$$\begin{aligned}
 P_{49} &= P_{49\text{HTO}} + P_{49\text{OBT}} \\
 &= 0.573 \text{ } \mu\text{Sv/a} + 0.013 \text{ } \mu\text{Sv/a} \\
 &= 0.586 \text{ } \mu\text{Sv/a}
 \end{aligned}$$

P₄₉: Child dose due to consumption of produce (HTO + OBT)

$$\begin{aligned}
 P_{49} &= P_{49\text{HTO}} + P_{49\text{OBT}} \\
 &= 0.574 \text{ } \mu\text{Sv/a} + 0.014 \text{ } \mu\text{Sv/a} \\
 &= 0.588 \text{ } \mu\text{Sv/a}
 \end{aligned}$$

Dose due to consumption of local milk

The tritium uptake due to consumption of milk, from a local producer and distributor is calculated by taking the average tritium concentration of the milk sampled. Using the following annual milk consumption rates derived using information found in CSA Guideline N288.1-14^[27]:

TABLE 32: CSA GUIDELINE N288.1-14 MILK CONSUMPTION RATES

AGE GROUP	MILK CONSUMPTION RATE (kg/a)
INFANT	340.0
CHILD	319.6
ADULT	188.5

The average concentration in milk in 2023 was measured as 4.00 Bq/L; adjusting for the density of milk, a specific activity of 4.00 Bq/L x 0.97 L/kg = **3.880 Bq/kg** is calculated.

P₅₉: Adult dose due to consumption of milk

$$\begin{aligned}
 P_{59} &= [H-3]_{\text{dairy}} \times M \times 2.0E-05 \text{ } \mu\text{Sv/Bq}; \\
 &= [3.880 \text{ Bq/kg}] \times 188.5 \text{ kg/a} \times 2.0E-05 \text{ } \mu\text{Sv/Bq} \\
 &= 0.015 \text{ } \mu\text{Sv/a}
 \end{aligned}$$

P₅₉: Infant dose due to consumption of milk

$$\begin{aligned}
 P_{59} &= [H-3]_{\text{dairy}} \times M \times 5.3E-05 \text{ } \mu\text{Sv/Bq}; \\
 &= [3.880 \text{ Bq/kg}] \times 340.0 \text{ kg/a} \times 5.3E-05 \text{ } \mu\text{Sv/Bq} \\
 &= 0.070 \text{ } \mu\text{Sv/a}
 \end{aligned}$$

P₅₉: Child dose due to consumption of milk

$$\begin{aligned}
 P_{59} &= [H-3]_{\text{dairy}} \times M \times 5.3E-05 \text{ } \mu\text{Sv/Bq}; \\
 &= [3.880 \text{ Bq/kg}] \times 319.6 \text{ kg/a} \times 5.3E-05 \text{ } \mu\text{Sv/Bq} \\
 &= 0.031 \text{ } \mu\text{Sv/a}
 \end{aligned}$$

Representative persons annual dose due to tritium uptake based on EMP

Based on the EMP results and the coefficients and parameters taken or derived from N288.1-14^[24-27], the annual dose (P_{total}) due to tritium uptake from inhalation and skin absorption, consumption of local produce, local milk and well water equates to a conservatively-calculated maximum of **2.251 μ Sv** in 2023.

TABLE 33: 2023 REPRESENTATIVE PERSONS ANNUAL DOSE BASED ON EMP

DOSE CONTRIBUTOR		ADULT WORKER ANNUAL DOSE (μ Sv/A)	ADULT RESIDENT ANNUAL DOSE (μ Sv/A)	INFANT RESIDENT ANNUAL DOSE (μ Sv/A)	CHILD RESIDENT ANNUAL DOSE (μ Sv/A)
DOSE DUE TO INHALATION and ABSORPTION AT WORK	$P_{(I)19}$	0.359			
DOSE DUE TO INHALATION and ABSORPTION AT RESIDENCE	$P_{(I)19}$	0.303	0.471	0.410	0.558
DOSE DUE TO CONSUMPTION OF WELL WATER	P_{29}	0.843	0.843	0.632	0.470
DOSE DUE TO CONSUMPTION OF PRODUCE	P_{49}	0.731	0.731	0.586	0.588
DOSE DUE TO CONSUMPTION OF MILK	P_{59}	0.015	0.015	0.070	0.031
2023 PUBLIC DOSE	P_{TOTAL}	2.251	2.060	1.698	1.647

Statement of Uncertainties in Calculation of Public Dose:

All parameters taken from N288.1-14 are at the 95th percentile where available, which is a very conservative assumption. Actual ingestion and inhalation rates are likely to be lower for most of the population. Actual doses to persons are likely to be significantly lower than calculated doses presented here as a result.

Statement of Compliance with Regulatory Limit:


Based upon the analysis of the data from both the environmental and effluent monitoring programs, the maximum effective dose imparted in 2023 by SRBT, to persons who are not categorized as Nuclear Energy Workers (conservatively calculated as 0.002 mSv), falls well below the prescribed limit of 1 mSv. SRBT complies with this regulatory requirement.

Public Dose Trends

The calculated effective dose of **2.251 μ Sv** to the most-exposed representative person is comparable with the calculated effective doses over the past five years.

The five-year trend for the effective dose to members of the public is illustrated below in Figure 18, with the data compared on an axis with a maximum value of 10 μ Sv.

FIGURE 18: PUBLIC DOSE FIVE-YEAR TREND (2019-2023)



4.3.6 Program Effectiveness

The suite of SRBT environmental protection programs have continued to be effective in measuring tritium in the environment and at ensuring the prevention of unreasonable risk to the environment.

The Environmental Monitoring Program continues to be implemented effectively. The past year represents the seventh full year of operation since the program revision to comply with the requirements of CSA standard N288.4-10, and the program continues to be improved over time.

Our passive air sampling array is effective and provides a picture of the full extent of tritium concentrations in air resulting from the emissions from the facility, and in turn providing real data to accurately estimate the dose to representative persons resulting from the emissions from the facility.

Tritium concentrations in residential wells, and in milk and produce that are consumed by residents living near the facility are measured. This data is effective at providing the full extent of tritium concentrations in human food and potable water sources resulting from the emissions from the facility, and in turn providing data to reliably estimate the dose to representative persons resulting from the emissions from the facility.

The Effluent Monitoring Program continues to be implemented very effectively, achieving the defined objectives of the program, including confirming the adequacy of controls on releases from the source, providing high-quality data, and demonstrating adherence to licence limits.

The Groundwater Monitoring Program was highly effective at providing data on the full extent of tritium concentrations in groundwater resulting from the emissions from the facility, and demonstrating the effectiveness of operational changes that have taken place over the last several years.

4.3.7 Program Review and Audit Summary

All major elements of the Environmental Management System (EMS) are scheduled to be audited at least once every three years.

As part of this cycle, the Environmental Monitoring Program was internally audited in December. Two OFIs were put forth, both of which pertaining to administrative updates to procedures and forms used routinely as part of the implementation of the program. Both OFIs will be actioned and closed in early 2024.

All programs under the EMS were subject to a full review, including comprehensive self-assessment and benchmarking, in the first quarter of 2023. The results of these review exercises were included as input into the annual facility management review process, as per SRBT procedure MSP-008, *Management Review*.

4.3.8 Proposed Modifications to EMS Programs

There are no proposed significant major changes to the monitoring programs that comprise SRBT's EMS, including the EMP, EffMP and GMP.

4.4 SCA – Emergency Management and Fire Protection

As most potential hazards associated with the facility would result from fire, emergency management and response for the facility are addressed by an extensive Fire Protection Program supported by an Emergency Plan.

4.4.1 Fire Protection

Various measures were taken at the facility in 2023 to improve and maintain fire safety. These activities included but were not limited to the following:

- A qualified third-party contractor completed a Site Condition Inspection at the facility, and issued a detailed report.
- Fire safety training for all SRBT employees was conducted in November during the annual all-staff safety training sessions.
- A new revision of the SRBT Fire Protection Program was implemented,
- The PFD completed an inspection of the SRBT facility, and
- Continued enhanced training for one Fire Protection committee member.

4.4.1.1 Fire Protection Committee

In 2023, four formal Fire Protection Committee meetings were held which resulted in the implementation of several improvements for fire protection and life safety at the facility. All Fire Protection Committee meeting minutes are kept on file.

4.4.1.2 Fire Protection Program, Fire Safety Plan and Procedures

The SRBT Fire Protection Program (Rev. G) and Fire Safety Plan (Rev. F) documents were both revised once, in May 2023^[7].

A new stand-alone procedural document was implemented in February 2023, which describes the procedure to follow for any hot work activities carried out at the SRBT facility.

These requirements were previously captured in an appendix of the Fire Safety Plan, however after discussions between the Fire Protection Committee it was agreed a stand-alone procedure (FPP-020) would capture the requirements more effectively.

4.4.1.3 Fire Hazards Assessment

SRBT maintains a Fire Hazards Assessment (FHA), in accordance with CSA standard N393-13, *Fire protection for facilities that process, handle, or store nuclear substances*.

The FHA was last completed in 2020, where it was assessed that fire hazards at the SRBT facility are being controlled, that worst-case fire events would not be expected to result in an unacceptable release of radiological or hazardous materials, and that there are adequate fire protection and life-safety features. The FHA concluded that the performance goals, objectives and criteria of CSA N393-13 have been satisfied at the SRBT facility.

The FHA is reviewed and revised on a five-year cycle; it is next due for review in 2025.

4.4.1.4 Independent Audit of the Fire Protection Program

An independent audit of the Fire Protection Program is required every three years, as per CSA standard N393-13, *Fire protection for facilities that process, handle, or store nuclear substances*.

This audit was last conducted in 2021, and is next due for completion in 2024.

4.4.1.5 Maintenance of the Sprinkler System

In 2023, quarterly and annual maintenance was performed on the sprinkler system by a third party. In addition, a weekly check of various valves and line pressures were performed by trained SRBT staff.

4.4.1.6 Fire Protection Equipment Inspections

In 2023, in-house routine inspection, testing and maintenance was performed on all fire protection and life safety equipment at the SRBT facility on a daily, weekly, monthly and annual basis by trained staff.

Qualified third-party contractors also performed routine inspection, testing and maintenance of fire protection and life safety equipment at the SRBT facility. Annual inspection, testing and maintenance include fire extinguishers, emergency lighting, the fire panel and sprinkler system.

4.4.1.7 Fire Extinguisher Training

Fire extinguisher training is typically conducted annually for all SRBT employees. The PFD provided this training in November 2023.

4.4.1.8 Fire Protection Committee Member Training

The Fire Protection Specialist continues to serve as a volunteer firefighter for a local fire department, and receives fire protection training from this department. In 2023, this individual achieved Firefighter 1 certification.

4.4.1.9 Fire Alarm Drills

A total of seven in-house fire alarm drills were conducted in 2023, including a drill that tested fire response and mutual aid activation on September 28, 2023.

Following each fire drill, a member of the Fire Protection Committee visits each department to discuss the drill. If any employee has comments or concerns regarding the drill they are provided with a Fire Alarm Drill Report to complete. Each report was reviewed by the Fire Protection Committee, and actions were taken as required to enhance fire and life safety at the facility.

4.4.1.10 Fire Protection Consultant Inspection

In October, a qualified third party (PLC Fire Safety Solutions) was contracted to complete a Site Condition Inspection, in order to meet the requirements of CSA standard N393-13, *Fire protection for facilities that process, handle, or store nuclear substances*.

The scope of the inspection was to evaluate the SRBT facility for compliance with the applicable inspection, testing and maintenance requirements of our operating licence. The following codes and standards were reviewed for applicability to the specific systems at SRBT:

- NFCC-2015, *National Fire Code of Canada*
- NBCC-2015, *National Building Code of Canada*
- CSA standard N393-13, *Fire protection for facilities that process, handle, or store nuclear substances*

Following the inspection, PLC prepared and issued a Site Condition Inspection Report, where three findings and one opportunity for improvement were identified. The findings and opportunity for improvement have been addressed.

4.4.1.11 Pembroke Fire Department Inspection

The PFD conducted a facility inspection to confirm compliance with the Ontario Fire Code in September, with no violations being identified.

4.4.2 Emergency Preparedness

SRBT ensures that we are prepared for an emergency at our facility. Staff, equipment and infrastructure are in place and ready to respond to an emergency in accordance with documented procedures.

4.4.2.1 Emergency Plan

The SRBT Emergency Plan has been developed based on the probability and potential severity of emergency scenarios associated with the operation of the facility.

The plan includes preparing for, responding to, and recovering from the effects of accidental radiological and/or hazardous substance releases from the SRBT facility.

The plan was last revised in 2017, and remains up-to-date for the facility's current state. A revision to the plan is scheduled to be completed in mid-2024.

4.4.2.2 Emergency Exercises

SRBT did not conduct an emergency exercise in 2023. A full-scale emergency exercise was last conducted on October 26, 2021.

Section 7.10.1.1 of the SRBT Emergency Plan requires that an emergency exercise be conducted at least once every five years. The next full-scale emergency exercise at SRBT is expected to be conducted on or before October 26, 2026, pursuant to the requirements of the Emergency Plan and our operating licence.

4.5 SCA – Waste Management

SRBT implements a Waste Management Program (WMP) that is aligned with the applicable requirements and guidelines in the following CSA Standards:

- CNSC REGDOC-2.11.1, *Waste Management, Volume I: Management of Radioactive Waste*
- CSA N292.0:19, *General principles for the management of radioactive waste and irradiated fuel*
- CSA N292.3-14, *Management of low- and intermediate-level radioactive waste*
- CSA N292.5-11 (R2016), *Guideline for the exemption or clearance from regulatory control of materials that contain, or potentially contain, nuclear substances*
- CSA N292.8:21, *Characterization of radioactive waste and irradiated fuel*

4.5.1 Radioactive Consignments – Waste

Ten shipments of low-level waste (LLW) were made to Canadian Nuclear Laboratories (CNL) in 2023.

A total of 161 packages of expired gaseous tritium light sources, 4 drums of surface-contaminated materials, and 23 packages of crushed stub glass were generated and safely transferred to CNL for further management in 2023.

Four drums of waste liquid scintillation counting vials were also generated and transferred in two shipments to EnergySolutions for further management in 2023.

A total volume of 5.49 m³ of LLW in 192 packages was generated and shipped to waste management service providers in 2023.

The following table is provided as a summary of the low-level waste material that was generated and routed to licenced waste management facilities for further management in 2023.

TABLE 34: RADIOACTIVE WASTE CONSIGNMENTS (2023)

	Date of Shipment	Waste Description	Number of Packages	Waste Description	Total Weight (Kgs)	Total Activity H-3 (TBq)
CNL	Jan. 23, 2023	LLW	23	Expired light sources	93	281.540
			2	Crushed stub glass	42	0.018
	Feb. 27, 2023	LLW	21	Expired light sources	84	265.700
			2	Crushed stub glass	42	0.018
			1	Drum of LLW	70	0.010
	Mar. 20, 2023	LLW	17	Expired light sources	68	209.160
			2	Crushed stub glass	42	0.018
	Jun. 26, 2023	LLW	6	Crushed stub glass	126	0.054
			1	Drum of LLW	70	0.010
			26	Expired light sources	26	322.910
	Jul. 17, 2023	LLW				
	Aug. 14, 2023	LLW	21	Expired light sources	84	279.910
			3	Crushed stub glass	63	0.027
			1	Drum of LLW	70	0.010
Sep. 11, 2023	LLW	21	Expired light sources	84	266.870	
		2	Crushed stub glass	42	0.018	
Oct. 23, 2023	LLW	16	Expired light sources	64	207.660	
		2	Crushed stub glass	42	0.018	
		1	Drum of LLW	70	0.010	
Nov. 20, 2023	LLW	9	Expired light sources	36	113.392	
		2	Crushed stub glass	42	0.018	
Dec. 11, 2023	LLW	7	Expired light sources	28	88.712	
		2	Crushed stub glass	42	0.018	
ENERGY SOLNS	Jun. 13, 2023	LLW	2	Drums of LLW	209	0.010
	Oct. 18, 2023	LLW	2	Drums of LLW	209	0.010
TOTALS					1748	2036.12

4.5.2 Management of Radioactive Waste

Radioactive waste was generated and managed on-site, and inventory records of the waste were maintained throughout the year, as per the WMP.

4.5.2.1 Low-level Waste Interim Storage

Low-level waste is any waste assessed as possessing activity levels that exceeds conditional clearance limits (for tritium), or in excess of the exemption quantities established in the *Nuclear Substances and Radiation Devices Regulations* (for all other radionuclides). Typical examples of such wastes are tritium-contaminated equipment or components, crushed glass, contaminated filters, broken lights, and material used to decontaminate surfaces.

As required by the WMP, LLW was collected in dedicated receptacles, assessed and ultimately placed into approved containers in the Waste Storage Room within Zone 3. Once sufficient material was collected, it was prepared for transfer to a licensed waste handling facility (CNL), using approved processes.

TABLE 35: INTERIM STORAGE OF LOW-LEVEL WASTE (ZONE 3)

AMOUNT IN STORAGE AT YEAR END 2022	AMOUNT GENERATED THROUGHOUT 2023	TRANSFERRED OFF SITE 2023	AMOUNT IN STORAGE AT YEAR END 2023
1 x 200 L drum	4 x 200 L drums	4 x 200 L drums	1 x 200 L drum
0.01 TBq	0.04 TBq	0.04 TBq	0.01 TBq

As well, four drums of liquid scintillation counting vials were managed and stored in 2023, four of which were transferred to EnergySolutions for further management. One drum remained in interim storage for disposal once filled in early 2024.

4.5.2.2 Clearance-level Waste

Waste materials in Zone 2 and 3 that may be minimally contaminated and are likely to meet accepted clearance criteria are classified as very low-level waste (VLLW). This classification is temporary, as ultimately VLLW is assessed radiologically, and routed through one of three accepted disposal pathways – either as LLW or as clearance-level waste (CLW).

Examples of such materials include paper towels, gloves, disposable lab coats, shoe covers, and other such materials that are collected in dedicated

receptacles in the active areas of the facility. These materials are routed to landfill after they have been conditionally cleared.

As well, any metal that can be recycled once conditionally cleared is routed to a local metal recycling depot.

Finally, any cleared items that also have hazardous characteristics are routed via a local hazardous waste depot under an industrial, commercial and institutional small quantity waste generator agreement. Some examples of such materials are batteries, aerosol containers, fluorescent light tubes, paints and solvents, and empty propane cylinders

A total of 74 clearance assessment reports were completed in 2023, representing a total mass of approximately 2,010,500 grams of material, and a total activity of approximately 10,280 MBq.

The approved WMP clearance criteria is set at 0.15 MBq/g, up to a maximum of 5,000,000 g of cleared material per pathway.

All cleared waste met these conditions in 2023, with an average specific activity of 0.006 MBq/gram (average of 4% of CLW specific activity limit).

The mass and activity of CLW assessed in 2023 is tabulated below:

TABLE 36: CLEARANCE-LEVEL WASTE (2023)

TYPE OF MATERIAL	PATHWAY	MASS (g)	ACTIVITY (MBq)	MBq/g
GENERAL WASTE	LANDFILL	1,616,020	10,220	0.006
METAL	RECYCLER	373,000	60	0.000
HAZARDOUS WASTE	HAZARDOUS WASTE DEPOT	21,480	0	0.000
TOTAL		2,010,500	10,280	0.006

4.5.2.3 Subject Waste

SRBT routinely manages and ships two types of non-radiological 'subject' waste at the facility.

Phosphorescent (zinc sulfide) powder (classified as mild environmental contaminant) is collected and shipped to a licenced hazardous waste management contractor. In addition, waste liquids from the 3-D printing process are also collected and shipped when they are generated.

This waste is picked up quarterly, and managed by a qualified service provider in accordance with the requirements of the Ontario Ministry of Environment and Climate Change.

In 2023, 310 kg of zinc sulfide powder was safely disposed of through this program. No 3-D printing process waste was shipped in 2023.

4.5.2.4 Waste Minimization

SRBT continues to minimize the generation of radioactive waste materials as part of our overall approach to waste management.

The Waste Management Committee met once in 2023 to review and discuss initiatives that could ultimately minimize the amount of radioactive waste routed to licenced waste management facilities. As well, initiatives for the reduction of conventional waste materials and energy usage were also discussed.

Continued segregation of material prior to bringing items into active zones remains effective at reducing waste materials that require management.

The implementation of Conditional Clearance Levels for waste materials has continued to be successful in reducing the amount of waste material that is needlessly disposed of as radioactive waste.

4.5.2.5 Expired Product Management

SRBT continues to offer return and disposal services to customers who possess expired tritium-illuminated devices, such as 'EXIT' signs.

In 2023, a total of 11,027 expired (or otherwise removed from service) self-luminous safety 'EXIT' type signs were accepted by SRBT from Canadian and American sources, representing a total activity of 1,642.39 TBq of tritium.

For comparison, in 2022, 15,492 signs were processed representing 2,116.61 TBq of tritium.

As well, an additional 119.38 TBq of tritium was accepted from international origins (i.e. other than Canada and the United States) in the form of expired tritium illuminated devices, such as aircraft signs, dials, gauges and other smaller equipment. These were also processed for shipment to a licenced waste management facility.

Expired signs are disassembled safely and the light sources removed, in order to ensure that the volume of low-level radioactive waste that is generated is minimized.

The expired lights are then packaged and shipped to a licenced radioactive waste management service provider.

A small number of these signs were evaluated as being fit for service in other applications, or having light sources that could be reused in other self-luminous devices.

This practice is the only re-use of the lights and the tritium associated with these lights, and would represent a very small fraction of the total light sources managed.

4.6 SCA – Security

SRBT implements an accepted Facility Security Program for the facility, in accordance with CNSC regulatory requirements and expectations.

SRBT did not experience any security-related events in 2023.

New staff members are required to qualify for a Facility Access Security Clearance (FASC), even if they are not expected to handle nuclear substances as part of their responsibilities.

Individuals and contractors that visit the facility are required to also have an FASC or be escorted at all times by a staff member with a valid FASC.

All staff receive both initial and annual refresher training in SRBT's Supervisory Awareness Program, for the purposes of ensuring compliance with section 48 of the *Nuclear Security Regulations*.

Maintenance of the physical facility security system is performed by a qualified, independent third party at least every 6 months.

The SRBT Security Program document underwent review and revision in 2023. CNSC staff reviewed and accepted the revised program, which was implemented on March 30.

4.7 SCA – Safeguards and Non-proliferation

SRBT possesses, uses, stores and manages a small quantity of depleted uranium under International Atomic Energy Agency (IAEA) exemption approval certificate EU\01\CN-2\D\ZZ00211.

This material is used as storage media for tritium gas on our processing equipment, a well-understood and widely-used strategy for manipulating and storing tritium in its gaseous, elemental state. By using depleted uranium in this fashion, we can ensure that the quantity of gaseous tritium being used during any given processing operation is restricted. This helps to ensure that the consequences of any unplanned event are minimized with respect to radiation and environmental protection, by ensuring that any release of tritium is limited.

SRBT possessed a reported 8.721 kg of depleted uranium in metallic form at the beginning of 2023. The inventory of material changed once in 2023; an adjustment to the recorded mass on hand was implemented based upon a physical inventory and weighing of the material.

In total, twenty-two grams of material was added administratively to the inventory. At the conclusion of 2023, the mass of depleted uranium on site is 8.743 kg. A limit of 10 kg of this material in inventory is applied as part of the operating limits and conditions in the SAR.

4.8 SCA – Packaging and Transport of Nuclear Substances

SRBT prepared, packaged and shipped all manufactured products containing nuclear substances in accordance with the *Packaging and Transport of Nuclear Substances Regulations*.

For the purpose of packaging and offering for transport, shipments of product designated as dangerous goods, SRBT must comply with the requirements of:

- CNSC
- International Atomic Energy Agency (IAEA)
- International Air Transport Association (IATA)
- Transport Canada

The procedures used at SRBT are based on regulations and practices found in the following publications:

- Packaging and Transport of Nuclear Substances Regulations
- IAEA Safety Standards Series - No. SSR-6
- IATA Dangerous Goods Regulations
- The TDG Compliance Manual: Clear Language Edition (Carswell)

Staff members involved with the packaging, offering for transport and receipt of dangerous goods are given TDG training in accordance with the applicable regulations and are issued certificates by the employer.

4.8.1 Outgoing Shipments

In total, 739 consignments were safely shipped to various customers located in 15 countries around the world, including Canada. A table is provided comparing the number of outgoing shipments of our products over the past five years.

TABLE 37: OUTGOING SHIPMENTS OF PRODUCT FIVE-YEAR TREND (2019-2023)

YEAR	2019	2020	2021	2022	2023
NUMBER OF SHIPMENTS*	949	827	811	761	739
NUMBER OF COUNTRIES	20	19	28	21	15

*Note – SRBT often ships single palletized shipments of safety signs to the US which subsequently get broken down into multiple sub-consignments. These types of shipments are counted as a single consignment for the purposes of this table.

All outgoing shipments were conducted in compliance with all regulatory requirements pertaining to the transport of dangerous goods and / or nuclear substances. Packages were assessed for surface contamination prior to being offered for transport as required by SRBT procedures.

Information pertaining to the number of monthly outgoing shipments containing radioactive material for 2023 can be found in **Appendix S** of this report.

4.8.2 Incoming Shipments

In total, 187 consignments of radioactive shipments were received from various customers located in 12 countries around the world, including Canada. These returns held a total activity of 1,762 TBq of tritium.

The vast majority of the returned, expired devices were in the form of expired 'EXIT' signs that are to have the expired lights removed and sent for future management at a licenced waste management facility.

A table is provided comparing the amount of incoming shipments of radioactive products that have been made over the past five years.

TABLE 38: INCOMING SHIPMENTS OF PRODUCT FIVE-YEAR TREND (2019-2023)

YEAR	2019	2020	2021	2022	2023
NUMBER OF SHIPMENTS	484	272	165	161	187
NUMBER OF COUNTRIES	8	8	10	9	12

All incoming shipments were received safely and in acceptable condition. Incoming packages containing nuclear substances are assessed for tritium leakage upon receipt.

Information pertaining to the number of monthly received shipments containing radioactive material for 2023 can be found in **Appendix T** of this report.

4.8.3 Reportable Events

No packaging and transport-related reportable events or dangerous occurrences occurred in 2023.

5. Other Matters of Regulatory Interest

5.1 Public Information and Disclosure

This section of the report will provide public information initiatives taken in 2023.

5.1.1 Direct Interaction with the Public

Historically, almost all public inquiries occur during re-licensing. In 2023, there were no public local or non-local inquiries received.

In 2023, water was sampled from a number of wells belonging to the public, in line with our Environmental Monitoring Program. Sampling for tritium concentrations were performed twice in 2023, in March and September.

Participating members of the public are provided with a report of their sample results, along with the anticipated radioactive exposure due to tritium from consuming either the water or produce. We provide members of the public a comparison of this exposure against the CNSC limit and against radioactive exposure from other known sources, such as cosmic radiation, x-rays, etc. No questions or comments were received in 2023.

Plant tours have proven to be a useful tool for SRBT to reach the public. In 2023, we provided plant tours to 19 members of the general public (compared to 7 in 2022, and 4 in 2021) who had expressed interest in our facility. As the restrictions from the pandemic have slowly been lifting, SRBT has been able to provide more facility tours to the general public.

In 2023 we provided plant tours to local representatives of:

- Ontario Provincial Police,
- The City of Pembroke, and
- Pembroke Fire Department,

In 2023 as part of conducting our business in Pembroke we have also provided plant tours to local employee representatives of our existing and prospective suppliers of goods and/or services, including:

- Baker Tilly
- UL
- Harrington Mechanical, and
- Professional Loss Control (PLC)

In 2023, we provided a plant tour to an existing customer:

- Betalight BV

TABLE 39: FACILITY TOURS (2023)

	2022
GENERAL PUBLIC	19
LOCAL INSTITUTIONS	3
LOCAL SUPPLIERS	4
CUSTOMERS	1
TOTAL	27

A public meeting was held by the CNSC on December 14, 2023 regarding the annual regulatory oversight report.

Several questions were asked to each licensee to answer: what are their thoughts on their performance ranking by the AOPFN, how do the licensees support AOPFN's Guardian Program, how do they incorporate climate change into their environmental risk assessment and do they measure discharges to the sewer systems.

Two questions were asked directly to SRBT: what is the cause of tritium releases and how did tritium get into the groundwater. Questions were answered to the satisfaction of the Commission during the meeting.

In 2023, SRBT made presentations to members of the public:

- The President of SRBT is a member and chair of the Community Improvement Plan, attending meetings and discussing SRBT on occasion. The Mayor of Pembroke is also on the Committee.
- The President of SRBT is also a member and chair of the Ontario River Energy Solutions, attending meetings and discussing SRBT on occasion. Pembroke's Deputy Mayor is also a member of this committee.
- The President of SRBT is a member and vice chair of the Ottawa River Power Corporation, attending meetings and discussing SRBT on occasion. Two Pembroke City Councillors are also members of this committee.

5.1.2 Program Revision

Revision A, dated September 15, 2021 of SRBT's Public Information Program (PIP) continues to demonstrate SRBT's commitment to openness and transparency.

5.1.3 Program Audit

There were no internal audits conducted on the Public Information Program in 2023. The next internal audit is scheduled to take place in August 2025.

5.1.4 Public Information Committee

The Public Information Committee held one formal meeting in 2023, focused on outreach to the Algonquins of Pikwakanagan Indigenous community, SRBT brochure and pamphlet, and environmental monitoring results to residents

5.1.5 Website and Social Media

SRBT continues to operate a website at www.srbt.com, which continues to provide current environmental monitoring data, information about tritium, content on emergency preparedness, the safe transport of tritium to the facility and products from the facility, how to safely dispose of products, and both our Operating Licence and LCH.

The main page provides a number of possible information sources for the public on tritium and radiation exposure.

The following information and documentation were added to our website in 2023:

- CNSC Compliance Inspection Report 2022-02,
- CNSC Compliance Inspection Report 2023-01,
- CNSC Compliance Inspection Report 2023-02,
- Updated pamphlet and brochure,
- SRBT Annual Compliance Report, 2022, including addenda,
- Updated environmental and groundwater monitoring results,
- CNSC staff's Regulatory Oversight Report, 2022,
- SRBT Safety Analysis Report – Revision 5 – December 2023

With respect to social media, SRBT also maintains Facebook, Instagram, Twitter, LinkedIn, Reddit and TikTok accounts, all of which are updated periodically.

Our Facebook account has a total of 1,152 followers, with a total of 19 posts in 2023. The account has received no reviews and 0 page likes in 2023.

SRBT's Instagram account has a total of 376 followers, with a total of 1 post in 2023. The account received an average of 12 likes per post in 2023.

SRBT's X (Twitter) account has a total of 90 followers. A total of 1 post has been made in 2023, receiving 0 likes but 13 views.

SRBT's LinkedIn account has a total of 73 followers and has posted a total of 1 post in 2023 receiving a total of 18 impressions.

SRBT's Reddit account only has two followers but has no posts posted in 2023.

SRBT's TikTok account has 34 followers but has no posts posted in 2023.

5.1.6 Community Support

SRBT continues to support the local community by providing support to various organizations and causes.

During the Christmas season, SRBT once again supported the Christmas Angels gift collection for children in the area, aimed at supporting families who couldn't afford gifts at Christmas.

SRBT is a member of the Upper Ottawa Valley Chamber of Commerce and the Canadian Nuclear Association. The Manager – Health Physics and Regulatory Affairs is a member of the Advisory Committee for the Applied Nuclear Science and Radiation Safety program at Algonquin College.

SRBT also sponsors a local softball team, a local baseball team, a local hockey team and a local youth basketball team. SRBT was a gold sponsor for a local memorial softball tournament.

SRBT supports the Pembroke Fire Department Chili Fest which raises money to support local charities, two local fishing derbies and the Deep River Karate Club.

SRBT also supports Festival Hall (Pembroke's local community theater), the Renfrew County Regional Science and Technology Fair, and The Robbie Dean Family Counselling Center.

SRBT is a member of the Canadian Council for Aboriginal Business.

5.1.7 Indigenous Engagement

On August 4, 2023, SRBT sent an e-mail to AOPFN, to clarify a possible misunderstanding noted during the December 16, 2022 meeting of the Commission.

SRBT clarified that they understand and agree with AOPFN's expectations that all costs of engagement with proponents seeking to work (or continue to work) in unceded Algonquin territory should be covered by the party working on AOPFN's traditional territory.

SRBT further clarified that any activity must be planned, quoted and approved by SRBT prior to being spent. SRBT asked that a quote be provided in advance for any engagement activities that AOPFN undertake for SRBT, and to ensure AOPFN receive written approval by SRBT before conducting such activities.

SRBT noted the AOPFN will be contacted in the near future to propose and plan environmental sampling activities in and around the AOPFN community and therefore a quote will be required, and once approved (dependent on SRBT's financial capabilities), will be paid once the work is completed.

SRBT concluded the e-mail noting at the conclusion of the sampling activities, discussion for future engagement including cultural awareness training for any new employees will take place.

As of the end of 2023 no reply has been received. In 2024 SRBT will make further attempts to contact AOPFN.

5.1.8 Media Coverage

SRBT is not aware of any significant media coverage received in 2023.

5.1.9 Public Opinion Analysis

No public feedback was received in 2023 through polling, surveys, or by direct communication from individuals or groups.

5.2 Preliminary Decommissioning Plan and Financial Guarantee

The SRBT Preliminary Decommissioning Plan (PDP) last underwent a significant revision in 2019, and was accepted by CNSC staff on February 3, 2020^[28], while the Commission accepted SRBT's revised Financial Guarantee (FG) amount of \$727,327.00 on December 8, 2020^[29].

The SRBT FG is a fully-funded cash fund held in escrow, and does not rely on any letters of credit, bonds, insurance or other expressed commitments.

Interest accrued on the funds deposited remain held in escrow over time; as a result, at the end of 2023 the FG is over-funded to \$772,629.49, a level that exceeds the required amount by \$45,302.49.

Details on our PDP and FG, and the CNSC's hearing and decision on these aspects of our licensing basis are available on our website.

Both the PDP and FG are next due for review, revision and updating in 2024.

6. Improvement Plans and Forecast

6.1 Emission Reduction Initiatives

SRBT continues to explore ways toward reducing tritium emissions from the facility in all forms, as per our continuing commitment to environmental protection and the 'as low as reasonably achievable' philosophy.

In early 2024, SRBT will be researching options in vacuum pump technologies in partnership with our supplier, in order to determine if there may be improvement opportunities with other pump designs. Improved quality of vacuum on processing rigs is one of several factors that impact operating emissions from the facility.

We expect that the changes introduced to the manufacturing and leak testing of miniature light sources should continue to keep the rate of generation of tritium-contaminated liquid effluent very low in 2024.

Continued, systematically developed training of employees who process tritium and handle light sources will continue to impact our gaseous and liquid emissions in a positive way.

6.2 Safety Performance Targets for 2024

For the coming year, our safety committees, in consultation with SRBT Senior Management, have approved a set of performance targets which will be tracked and reported on as part of the 2024 ACR.

The following table documents the safety performance targets for SRBT in 2024:

TABLE 40: SAFETY AND PERFORMANCE TARGETS FOR 2024

PARAMETER	2024 TARGET
MAXIMUM WORKER DOSE	≤ 0.50 mSv
AVERAGE WORKER DOSE	≤ 0.050 mSv
COLLECTIVE WORKER DOSE	≤ 2.50 p-mSv
CALCULATED DOSE TO MEMBER OF THE PUBLIC	≤ 0.0040 mSv
TOTAL TRITIUM EMISSIONS TO ATMOSPHERE (PER WEEK AVERAGE)	≤ 600 GBq / week
RATIO – TRITIUM EMISSIONS VS. PROCESSED	≤ 0.11
TOTAL TRITIUM EMISSIONS – LIQUID EFFLUENT PATHWAY	≤ 6 GBq
ACTION LEVEL EXCEEDANCES – ENVIRONMENTAL	≤ 1
ACTION LEVEL EXCEEDANCES – RADIATION PROTECTION	≤ 1
CONTAMINATION CONTROL – FACILITY-WIDE PASS / FAIL RATE	≥ 95.5%
LOST TIME INJURIES	0
MINOR INJURIES REPORTABLE TO WSIB	≤ 5
MINOR INCIDENTS / FIRST AID INJURIES (NON-REPORTABLE)	≤ 15

6.3 Planned Modifications and Foreseen Changes

The upcoming year of operation is not expected to involve significant modifications to the facility or our licensed activities, and production levels are expected to remain stable.

SRBT will be continuing to pursue and explore opportunities to improve our operations and our safety performance, and remain committed to ensuring that our environmental impacts are as low as reasonably achievable.

7. Concluding Remarks

Throughout the year, the management and staff of SRBT complied with all regulatory requirements and the conditions of our operating licence.

Our management system remains effective at achieving our operational and safety-related goals, and ensuring effective control of our operations. We continue to adjust and improve our processes in support of the safe and effective operation of our facility, and we continue to use operating experience to continuously improve the system.

Our facility remains within its designed safety basis, and continues to be fit for service. Key structures, systems and components have continued to be maintained diligently and effectively throughout 2023 through the implementation of our Maintenance Program.

Exposures to ionizing radiation to both workers and members of the public continue to remain low, and are far less than the regulatory limits prescribed.

The local environment has remained protected, and the already low level of impact of our operations continues to be reduced over time, as we continue to implement best practices each and every day. Licence limits for our nuclear substance effluent streams continue to be respected with significant margin.

Our conventional health and safety program has continued to ensure our workers are safe, and the security of the facility and all nuclear substances was maintained at all times.

The facility remains well protected from fire hazards, and we have maintained an accepted plan should an emergency condition arise.

Our Public Information Program fully satisfies the requirements of the CNSC. We continue to look for new ways to reach out into our local community in a positive and constructive fashion, and to provide information and data that is of interest to stakeholders and Indigenous communities.

Our website continues to provide the public with a wealth of easy-to-access information on our operations and our safety programs, including a very wide variety of environmental data and safety analyses.

We continue to effectively manage all forms of waste generated by our operations, and continue to look to minimize the amount of waste that must be managed and controlled.

Our decommissioning responsibilities are documented and accepted, and our financial guarantee is fully funded. Although we plan on operating the facility for at least the next

two decades, if not longer, having a complete, self-funded financial guarantee is an important consideration with respect to our regulatory standing, as well as our commitment of being a good community partner.

Safety and excellence in operations shall always remain as the number one overall priority in everything we do, and 2023 was a direct reflection of the success at achieving these goals.

We will always continue to improve our operations and minimize our impact on people and the environment as our company continues to sustainably grow over the coming years.

8. References

- [1] Nuclear Substance Processing Facility Licence NSPFL-13.00/2034, valid from July 1, 2022 to June 30, 2034. [Link](#)
- [2] Licence Conditions Handbook – SRB Technologies (Canada) Inc. Nuclear Substance Processing Facility Licence NSPFL-13.00/2034 (CNSC e-Doc 6668496 (Rev. 0)). [Link](#)
- [3] CNSC REGDOC-3.1.2, Version 1.1, *Reporting Requirements, Volume I: Non-Power Reactor Class I Nuclear Facilities and Uranium Mines and Mills*. [Link](#)
- [4] CNSC Compliance Inspection Report SRBT-2023-01, May 9, 2023. [Link](#)
- [5] CNSC Compliance Inspection Report SRBT-2023-02, November 1, 2023. [Link](#)
- [6] SRBT Safety Analysis Report – Revision 4 [Link](#) and Revision 5 [Link](#).
- [7] Letter from J. MacDonald (SRBT) to L. Posada (CNSC), *Revised Fire Protection Program and Fire Safety Plan*, dated March 28, 2023.
- [8] Letter from J. MacDonald (SRBT) to L. Posada (CNSC), *Revised Radiation Safety Program*, dated November 3, 2023 (e-Doc 7160644).
- [9] Letter from L. Posada (CNSC) to J. MacDonald (SRBT), *CNSC Staff Review of SRB Technologies (Canada) Inc.'s Revised Radiation Safety Program (Rev. O)*, dated December 18, 2023 (CNSC e-Doc 7188445).
- [10] Letter from J. MacDonald (SRBT) to L. Posada (CNSC), *Submission of SRBT Safety Analysis Report (Rev. 5)*, dated July 31, 2023 (CNSC e-Doc 7097936).
- [11] Letter from L. Posada (CNSC) to J. MacDonald (SRBT), *CNSC Staff's Review of SRB Technologies (Canada) Inc.'s Safety Analysis Report Revision 5*, dated November 3, 2023 (CNSC e-Doc 7158339).
- [12] Letter from J. MacDonald (SRBT) to L. Posada (CNSC), *Response to CNSC Staff Review of SRBT Safety Analysis Report (Rev. 5)*, dated December 1, 2023 (CNSC e-Doc 7178979).
- [13] Letter from L. Posada (CNSC) to J. MacDonald (SRBT), *CNSC Staff's Review of SRB Technologies (Canada) Inc.'s Disposition of CNSC Comments on the Safety Analysis Report, Revision 5*, dated December 11, 2023 (CNSC e-Doc 7181035).
- [14] CNSC REGDOC-2.7.2, Volume II, *Dosimetry, Volume II: Technical and Management System Requirements for Dosimetry Services*. [Link](#)
- [15] CNSC REGDOC-2.4.4, *Safety Analysis for Class IB Nuclear Facilities*. [Link](#)
- [16] SRBT Annual Compliance and Performance Report: January 1 – December 31, 2022. [Link](#)
- [17] CNSC Dosimetry Service Licence 11341-3-28.5 (expiry May 31, 2028).
- [18] Letter from M. Tremblay (Health Canada) to J. MacDonald (SRBT), *Certificate of Achievement*, dated June 26, 2023.

- [19] Email and attached report from J. MacDonald (SRBT) to cns.cacr-rac.ccsn@canada.ca, *2023 Annual Compliance Report – 11341-3-28.5*, dated January 16, 2024.
- [20] Letter from L. Posada (CNSC) to S. Levesque (SRBT), *CNSC Staff Follow-up Review of SRB Technologies (Canada) Inc.'s Environmental Risk Assessment*, dated April 22, 2021 (e-Doc 6539968).
- [21] Letter from S. Levesque (SRBT) to L. Posada (CNSC), *SRBT Response to CNSC Staff Comments on ERA*, dated April 12, 2021.
- [22] CMD 22-H8.8, *AOPFN Written Submission on Request for Issuance of a Class IB Licence Renewal to SRB Technologies (Canada) Inc. for Operation of its Existing Tritium Processing Facility*, date submitted March 14, 2022. [Link](#)
- [23] CSA standard N288.1-14, *Guidelines for calculating derived release limits for radioactive material in airborne and liquid effluents for normal operation of nuclear facilities*
- [24] CSA standard N288.1-14, *Guidelines for calculating derived release limits for radioactive material in airborne and liquid effluents for normal operation of nuclear facilities*, Tables C.1, C.2.
- [25] CSA standard N288.1-14, *Guidelines for calculating derived release limits for radioactive material in airborne and liquid effluents for normal operation of nuclear facilities*, Table 19.
- [26] CSA standard N288.1-14, *Guidelines for calculating derived release limits for radioactive material in airborne and liquid effluents for normal operation of nuclear facilities*, Table 21.
- [27] CSA standard N288.1-14, *Guidelines for calculating derived release limits for radioactive material in airborne and liquid effluents for normal operation of nuclear facilities*, Table G.9c.
- [28] Letter from L. Posada (CNSC) to S. Levesque (SRBT), *CNSC Staff Review of SRB Technologies (Canada) Inc.'s Revised Preliminary Decommissioning Plan – 2019*, dated February 3, 2020 (CNSC e-Doc 6111181).
- [29] CNSC Record of Decision DEC 20-H105. [Link](#)

9. Appendices

DESCRIPTION	LETTER
Tritium Inventory / Possession.....	A
Equipment Maintenance Information.....	B
Ventilation Maintenance Information.....	C
Radiological Dose Data.....	D
Contamination Assessment Data.....	E
Monthly Average Concentrations of Tritium in Air in Environment.....	F
Wind Direction Information.....	G
Precipitation Monitoring Data.....	H
River Water Monitoring Data.....	I
Downspout / Facility Runoff Monitoring Data.....	J
Produce Monitoring Data.....	K
Milk Monitoring Data.....	L
Weather Data.....	M
Groundwater Monitoring Data.....	N
Gaseous Effluent Data.....	O
Liquid Effluent Data.....	P
Groundwater Monitoring Well Level Data.....	Q
Public Dose Data.....	R
Summary of Outgoing Shipments Containing Radioactive Material.....	S
Summary of Incoming Shipments Containing Radioactive Material.....	T


APPENDIX A

Tritium Inventory / Possession

Tritium Inventory / Possession

Month	Month-end H-3 Activity On-Site (TBq)	Percent of Licence Limit (%)
January	2,043	34.1
February	1,953	32.6
March	2,179	36.3
April	2,595	43.2
May	2,888	48.1
June	2,636	43.9
July	2,935	48.9
August	2,270	37.8
September	2,381	39.7
October	2,425	40.4
November	3,760	62.7
December	4,960	82.7
2023 Monthly Average	2,752	45.9

Note: Tritium possession limit = 6,000 TBq.



APPENDIX B

Equipment Maintenance Information

Equipment Maintenance Information for 2023

Semi-Annual maintenance on HVAC equipment: Contract: Black and McDonald	Apr. 26, 2023 Sep. 26, 2023
Quarterly maintenance on Rig & Bulk stack units: Contract: Black and McDonald	Mar. 2, 2023 Jun. 23, 2023 Sep. 26, 2023 Dec. 22, 2023
Annual stack verification by third party on Rig & Bulk stack units: Contract: Tab Inspection	Sep. 11, 2023
Sprinkler System quarterly maintenance by a third party: Contract: Drapeau Automatic Sprinkler Corp	Mar. 16, 2023 Jun. 15, 2023 Sep. 21, 2023 Dec. 21, 2023
Emergency Lighting & Fire Extinguisher annual inspection by a third party: Contract: Layman Fire and Safety	Mar. 23, 2023
Fire panel annual inspection by a third party: Contract: Layman Fire and Safety	Jan. 12, 2023
Sprinkler System inspection by SRBT:	Weekly
Fire Alarm Components inspection by SRBT:	Weekly
Fire Separation doors inspection by SRBT:	Weekly
Fire Extinguisher inspection by SRBT:	Monthly
Emergency Lights inspection by SRBT:	Monthly
Exit Doors inspected by SRBT:	Weekly
Quarterly maintenance carried out on the compressor: Contract: Valley Compressor	Mar. 16, 2023 Jun. 13, 2023 Sep. 19, 2023 Dec. 18, 2023
Fume Hood Inspections by SRBT:	Monthly
Tritium-in-Air Sample Collector Bubblers maintenance:	Bi-monthly
Tritium-in-Air Sample Collector Bubblers third party annual verification: Contract: Canadian Nuclear Laboratories	Feb. 14-28, 2023
Liquid Scintillation Counters third party annual maintenance: Contract: PerkinElmer	Jun. 28-29, 2023
Real-time Stack Monitoring system verification by SRBT:	Mar. 8, 2023 Jun. 12, 2023 Sep. 1, 2023 Dec. 18, 2023
Monitoring well inspection by SRBT:	Mar. 21, 2023 Jun. 14, 2023 Sep. 19, 2023 Dec. 11, 2023
Annual IT maintenance inspection by SRBT:	Sep. 18, 2023
Non-active air filter inspection by SRBT:	Monthly

Equipment Maintenance Information for 2023 (continued)

Annual Zone Differential Pressure Test by SRBT:	Dec. 19, 2023
UV printer maintenance by SRBT:	Monthly
Molding machine maintenance by SRBT:	Mar. 31, 2023 Jun. 28, 2023 Sep. 28, 2023 Dec. 21, 2023
3D printer maintenance by SRBT**:	Sep. 21, 2023 Dec. 20, 2023
Fork-crane maintenance by SRBT:	May 31, 2023
Forklift maintenance by a third party: Contract: Hyster	May 3, 2023
Report of any weakening or possible major failure of any components:	None

All ventilation systems were maintained at a high fitness for service. Corrective maintenance was performed as required. Ventilation equipment maintenance was performed under contract with a fully licensed maintenance and TSSA certified local HVAC contract provider.

All process equipment is serviced and maintained by qualified staff and through contract with companies that specialize in process control systems. All process equipment has been maintained in fully operational condition.

Corrective maintenance is performed on equipment as required, and recorded and tracked over time.

***Note – 3D printer out of service until September 2023 before the appropriate parts came in to remedy its issues (tracked in accordance with the corrective maintenance procedure). Once the printer was returned to service regular maintenance continued as usual.*

APPENDIX C

Ventilation Maintenance Information

Ventilation Equipment Maintained In 2023

#	TYPE	ZONE SERVICED	LOCATION OF UNIT
1	Gas Furnace	1	Front office / server hallway
1	Mid efficient gas furnace	1	Receiving area
1	Mid efficient gas furnace & central air	1	Stores
1	Mid efficient gas furnace	1	Back bay
1	Heat Recovery unit	1	Receiving area
1	HRV with reheat	2	Coating
2	Makeup air units	1 & 2	Coating room
3	Unit heaters	1 & 3	Rig room, Glass shop, Receiving area
2	A/C wall unit	1	Glass shop, Receiving area
4	Exhaust fans	1 & 2	Coating, Assembly, Glass room, Paint Booth
1	Electric furnace with central air	1	Front office
1	Bulk stack air handling unit	3	Compound
1	Rig stack air handling unit	3	Compound
2	Rig and Bulk stack air handling units pitot tubes	3	Compound
1	Gas furnace with central air	1	Milling / molding

APPENDIX D

Radiological Dose Data

Radiological Dose Data

Rolling five-year effective dose data (2019 - 2023)

ANNUAL DOSE (mSv)	2019	2020	2021	2022	2023	FIVE YEAR AVERAGE
Maximum Dose	0.57	0.43	0.36	0.46	0.39	0.44
Average Dose (all records)	0.065	0.077	0.056	0.048	0.038	0.057
Average Dose (excluding <0.01)	0.115	0.093	0.090	0.082	0.084	0.093
Collective Dose	2.95	3.30	2.35	2.01	1.56	2.43

EFFECTIVE DOSE RANGE (mSv)	2019	2020	2021	2022	2023	FIVE YEAR AVERAGE
< 0.01 ('zero dose')	20	8	16	18	23	17
0.01 – 0.05	10	18	16	16	11	14
0.05 – 0.10	6	7	3	2	2	4
0.10 – 0.25	5	6	3	3	3	4
0.25 – 0.50	3	4	4	3	2	3
0.50 – 1.00	1	0	0	0	0	0
>1.00	0	0	0	0	0	0
Number of Workers Monitored	45	43	42	42	41	43

APPENDIX E

Contamination Assessment Data

Contamination Assessment Data

Q1 2023 Routine Contamination Assessment Summary - Zone 3

Zone 3 Areas	Assessments	Pass	Pass Rate
Rig 7 Floor	63	55	87.30%
Rig 7	63	61	96.83%
Rig 1 Floor	63	61	96.83%
Rig 1	63	63	100.00%
Flr @ Rig 6	63	60	95.24%
Rig 6	63	60	95.24%
Floor @ Rig 8	63	58	92.06%
Rig 8	63	63	100.00%
Floor @ Rig 5	63	60	95.24%
Rig 5	63	62	98.41%
Waste Room Door	57	57	100.00%
Faucet	57	57	100.00%
Flr @ Barrier	63	62	98.41%
Chairs	57	57	100.00%
Laser Room Floor	63	61	96.83%
EIP Area	63	63	100.00%
Laser Rm F/H	63	60	95.24%
Laser Stock Cabinet	63	62	98.41%
Trit Lab Flr random	63	58	92.06%
Disassembly Fumehood	63	57	90.48%
Bulk Fume hood	63	48	76.19%
Trit Lab desk	63	57	90.48%
Disassembly PPE	57	55	96.49%
Portable TAM Handles	57	56	98.25%
Waste Room Wall	6	6	100.00%
Scint Table	6	5	83.33%
Table at Barrier	6	6	100.00%
Operations Log	6	5	83.33%
Computer Peripherals	6	6	100.00%
TOTAL	1,512	1,441	95.30%

Q1 2023 Routine Contamination Assessment Summary - Zone 2

Zone 2 Areas	Assessments	Pass	Pass Rate
Floor at Barrier	37	36	97.30%
Work Area Floors	37	34	91.89%
Work Counters	37	36	97.30%
Work Counter 2	34	34	100.00%
Door Knobs	37	35	94.59%
WIP Cabinets	37	37	100.00%
Shelf in Silk Screen	37	36	97.30%
Exterior of Shoe Cover Drawers	34	34	100.00%
Bubbler Fume hood	37	34	91.89%
Inspection Room Table	37	36	97.30%
Inspection Room Floor	34	32	94.12%
Insp. Prep. Counter	37	37	100.00%
Work Area Floor #2	3	3	100.00%
Photometer Room	3	3	100.00%
Liquid Effluent Barrel	3	3	100.00%
TOTAL	444	430	96.85%

Q1 2023 Routine Contamination Assessment Summary - Zone 1

Zone 1 Areas	Assessments	Pass	Pass Rate
Lunch Room	13	12	92.31%
Lunch Room Hallway	11	11	100.00%
LSC Room	13	13	100.00%
LSC Lab Doorknob	11	11	100.00%
RR Ante Rm	13	13	100.00%
RR Barrier	13	9	69.23%
Assy Barrier	13	13	100.00%
Faucet @Barrier	11	11	100.00%
Disassembly Table	13	13	100.00%
Disassembly Cabinet	13	13	100.00%
Disassembly PPE	13	11	84.62%
Shipping Floor	13	13	100.00%
TOTAL	156	149	95.51%

Q2 2023 Routine Contamination Assessment Summary - Zone 3

Zone 3 Areas	Assessments	Pass	Pass Rate
Rig 7 Floor	61	58	95.08%
Rig 7	61	60	98.36%
Rig 1 Floor	61	61	100.00%
Rig 1	61	61	100.00%
Flr @ Rig 6	61	61	100.00%
Rig 6	61	60	98.36%
Floor @ Rig 8	61	61	100.00%
Rig 8	61	61	100.00%
Floor @ Rig 5	61	61	100.00%
Rig 5	61	61	100.00%
Waste Room Floor	60	58	96.67%
Muffle Fumehood	60	60	100.00%
Flr @ Barrier	61	61	100.00%
Testing Oven	60	60	100.00%
Laser Room Floor	61	56	91.80%
EIP Area	61	61	100.00%
Laser Rm F/H	61	54	88.52%
Laser Stock Cabinet	61	61	100.00%
Trit Lab Flr random	61	59	96.72%
Disassembly Fumehood	61	53	86.89%
Bulk Fume hood	61	59	96.72%
Trit Lab desk	61	59	96.72%
Liquid Nitrogen Equip	60	60	100.00%
Trit Lab Chairs	60	60	100.00%
Waste Room Door	1	1	100.00%
Faucet	1	1	100.00%
Chairs	1	1	100.00%
Disassembly PPE	1	1	100.00%
Portable TAM Handles	1	1	100.00%
TOTAL	1,464	1,431	97.75%

Q2 2023 Routine Contamination Assessment Summary - Zone 2

Zone 2 Areas	Assessments	Pass	Pass Rate
Floor at Barrier	36	35	97.22%
Work Area Floors	36	35	97.22%
Work Counters	36	36	100.00%
Assembly Chairs	35	35	100.00%
Door Knobs	36	36	100.00%
WIP Cabinets	36	36	100.00%
Light Stock Cabinet	35	35	100.00%
Sonic Welding Area	35	34	97.14%
Bubbler Fume hood	36	35	97.22%
Inspection Room Table	36	34	94.44%
Inspection Room Floor	36	35	97.22%
Insp. Prep. Counter	36	36	100.00%
Work counters 2	1	1	100.00%
Silk Screen Rack	1	1	100.00%
Shoe Cover Drawer	1	1	100.00%
TOTAL	432	425	98.38%

Q2 2023 Routine Contamination Assessment Summary - Zone 1

Zone 1 Areas	Assessments	Pass	Pass Rate
Lunch Room	13	13	100.00%
Zone 1 Printer/shredder	13	13	100.00%
LSC Room	13	13	100.00%
RR Doorknob	13	13	100.00%
RR Ante Rm	13	13	100.00%
RR Barrier	13	12	92.31%
Assy Barrier	13	12	92.31%
Shipping Storage Area	13	13	100.00%
Disassembly Table	13	11	84.62%
Disassembly Cabinet	13	12	92.31%
Disassembly PPE	13	11	84.62%
Shipping Floor	13	13	100.00%
TOTAL	156	149	95.51%

Q3 2023 Routine Contamination Assessment Summary - Zone 3

Zone 3 Areas	Assessments	Pass	Pass Rate
Rig 7 Floor	61	59	96.72%
Rig 7	61	59	96.72%
Rig 1 Floor	61	61	100.00%
Rig 1	61	61	100.00%
Flr @ Rig 6	61	61	100.00%
Rig 6	61	60	98.36%
Floor @ Rig 8	61	60	98.36%
Rig 8	61	60	98.36%
Floor @ Rig 5	61	61	100.00%
Rig 5	61	61	100.00%
Waste Room Wall	58	58	100.00%
Expired Light Source Cans	58	58	100.00%
Flr @ Barrier	61	60	98.36%
Scint Table	58	57	98.28%
Scint Bins	58	57	98.28%
Scint Bin Storage	58	58	100.00%
Laser Room Floor	61	59	96.72%
EIP Area	61	61	100.00%
Laser Rm F/H	61	59	96.72%
Trit Lab Flr random	61	58	95.08%
Disassembly Fumehood	61	56	91.80%
Bulk Fume hood	61	53	86.89%
Trit Lab desk	61	60	98.36%
Liquid Nitrogen Equip	61	60	98.36%
Laser Stock Cabinet	3	3	100.00%
Muffle Fumehood	3	3	100.00%
Testing Oven	3	3	100.00%
Trit Lab Chairs	3	3	100.00%
Waste Room Floor	3	3	100.00%
TOTAL	1,464	1,432	97.38%

Q3 2023 Routine Contamination Assessment Summary - Zone 2

Zone 2 Areas	Assessments	Pass	Pass Rate
Floor at Barrier	36	35	97.22%
Work Area Floors	36	32	88.89%
Work Counters	36	35	97.22%
Work Counter 2	35	34	97.14%
Glue-in Counter	35	35	100.00%
Light Storage Cabinet	35	35	100.00%
Dark Room	35	35	100.00%
Sonic Welding Area	36	36	100.00%
Bubbler Fume hood	36	35	97.22%
Inspection Room Table	36	35	97.22%
Inspection Room Floor	36	35	97.22%
Insp. Prep. Counter	36	36	100.00%
Assembly Chairs	1	1	100.00%
Door Knobs	1	1	100.00%
WIP Cabinets	1	1	100.00%
TOTAL	432	422	97.69%

Q3 2023 Routine Contamination Assessment Summary - Zone 1

Zone 1 Areas	Assessments	Pass	Pass Rate
Lunch Room	13	13	100.00%
Bathrooms	12	12	100.00%
Stores	12	12	100.00%
LSC Room	13	13	100.00%
RR Ante Rm	13	13	100.00%
RR Barrier	13	13	100.00%
Assy Barrier	13	13	100.00%
Disassembly Table	13	11	84.62%
Disassembly Cabinet	13	13	100.00%
Disassembly PPE	13	13	100.00%
Main Entrance Crash-Bar	12	12	100.00%
Shipping Floor	13	13	100.00%
Zone 1 Printer/shredder	1	1	100.00%
RR Doorknob	1	1	100.00%
Shipping Storage Area	1	1	100.00%
TOTAL	156	154	98.72%

Q4 2023 Routine Contamination Assessment Summary - Zone 3

Zone 3 Areas	Assessments	Pass	Pass Rate
Rig 7 Floor	59	55	93.22%
Rig 7	59	59	100.00%
Rig 1 Floor	59	58	98.31%
Rig 1	59	59	100.00%
Flr @ Rig 6	59	57	96.61%
Rig 6	59	58	98.31%
Floor @ Rig 8	59	58	98.31%
Rig 8	59	59	100.00%
Floor @ Rig 5	59	55	93.22%
Rig 5	59	59	100.00%
Waste Room Door	52	52	100.00%
Waste Room Exit Door	52	52	100.00%
Flr @ Barrier	59	59	100.00%
Scint Table	59	58	98.31%
Scint Cup Storage	52	52	100.00%
Laser Room Desk	52	50	96.15%
Laser Room Floor	59	53	89.83%
EIP Area	59	59	100.00%
Laser Rm F/H	59	59	100.00%
Trit Lab Flr random	59	51	86.44%
Disassembly Fumehood	59	53	89.83%
Bulk Fume hood	59	54	91.53%
Trit Lab desk	59	56	94.92%
Storage Room Floor	52	44	84.62%
Waste Room Wall	7	7	100.00%
Expired Light Source Cans	7	7	100.00%
Scint Bins	7	7	100.00%
Scint Bin Storage	7	7	100.00%
Liquid Nitrogen Equip	7	7	100.00%
TOTAL	1,416	1,364	96.33%

Q4 2023 Routine Contamination Assessment Summary - Zone 2

Zone 2 Areas	Assessments	Pass	Pass Rate
Floor at Barrier	34	30	88.24%
Work Area Floors	34	31	91.18%
Work Counters	34	32	94.12%
Work Counter 2	34	34	100.00%
Silk Screening Floor	30	26	86.67%
Insp. Prep. Floor	30	28	93.33%
Sonic Welding Area 1	30	30	100.00%
Sonic Welding Area 2	34	34	100.00%
Bubbler Fume hood	34	33	97.06%
Inspection Room Table	34	31	91.18%
Inspection Room Floor	34	32	94.12%
Insp. Prep. Counter	34	34	100.00%
Glue-in Counter	4	4	100.00%
Light Storage Cabinet	4	4	100.00%
Dark Room	4	4	100.00%
TOTAL	408	387	94.85%

Q4 2023 Routine Contamination Assessment Summary - Zone 1

Zone 1 Areas	Assessments	Pass	Pass Rate
Lunch Room	12	12	100.00%
Carts	10	10	100.00%
Scint Fluid Pumps	10	10	100.00%
LSC Room	12	12	100.00%
RR Ante Rm	12	12	100.00%
RR Barrier	12	12	100.00%
Assy Barrier	12	12	100.00%
Disassembly Table	12	12	100.00%
Disassembly Cabinet	12	12	100.00%
Disassembly PPE	12	11	91.67%
Shipping Countertops	10	10	100.00%
Shipping Floor	12	12	100.00%
Bathrooms	2	2	100%
Stores	2	2	100%
Main Entrance Crash-Bar	2	2	100%
TOTAL	144	143	99.31%

Overall Facility Summary

Facility Zone	Assessments	Pass	Pass Rate
ZONE 3	5,856	5,668	96.8%
ZONE 2	1,716	1,664	97.0%
ZONE 1	612	595	97.2%
2023 ALL ZONES	8,184	7,927	96.9%

APPENDIX F


Monthly Average Concentrations of Tritium in Air in Environment

Monthly Average Concentrations of Tritium in Air in Environment

2023 Environment Monitoring Program Passive Air Sampling System																
Sampler No.	Sampler ID	Location	Dist. to SRBT	(Bq/m ³)												Average
				Jan 04-Jan	Feb 01-Feb	Mar 01-Mar	Apr 06-Apr	May 03-May-23	Jun 31-May-23	Jul 28-Jun	Aug 02-Aug	Sep 30-Aug-23	Oct 04-Oct-23	Nov 01-Nov-23	Dec 30-Nov-23	
Minimum Detectable Activity (Bq/m³)				0.54	0.67	0.67	0.52	0.69	0.67	0.68	0.67	0.83	0.52	0.67	0.63	0.65
1	N250	N 45° 48.486' W 077° 07.092' Elev. 137m	322m	1.94	1.96	1.36	0.52	0.69	0.67	0.68	0.67	0.83	2.17	5.68	3.17	1.70
2	N500	N 45° 48.572' W 077° 07.008' Elev. 134m	493m	0.80	0.67	0.67	0.52	0.69	0.67	0.68	0.67	0.96	1.66	1.29	6.83	1.34
3	N1000	N 45° 48.869' W 077° 06.997' Elev. 135m	1040m	0.80	0.67	0.67	0.52	0.70	0.67	0.75	0.67	0.83	0.97	0.82	0.66	0.73
4 (PAS #4)	NW250	N 45° 48.412' W 077° 07.189' Elev. 137m	222m	1.89	1.04	0.75	0.86	1.37	0.67	1.75	1.20	1.79	1.80	5.00	4.28	1.87
5	NW500	N 45° 48.577' W 077° 07.382' Elev. 134m	615m	0.91	0.79	0.67	0.52	0.69	0.67	0.68	0.71	0.83	0.57	1.46	0.97	0.79
6 (PAS # 8)	NW1000	N 45° 48.754' W 077° 07.599' Elev. 130m	1050m	0.77	0.93	0.67	0.52	0.69	0.67	0.68	0.67	0.83	0.60	1.50	1.14	0.81
7	NW2000	N 45° 49.141' W 077° 08.090' Elev. 139m	2000m	0.54	1.00	0.67	0.52	0.69	0.67	0.68	0.67	0.83	0.91	0.67	1.21	0.76
8	W250	N 45° 48.300' W 077° 07.323' Elev. 138m	297m	1.77	1.29	0.82	0.52	1.78	0.67	1.89	0.67	0.83	1.86	0.67	0.63	1.12
9	W500	N 45° 48.288' W 077° 07.393' Elev. 137m	389m	1.06	0.71	0.68	0.52	0.69	0.67	1.25	0.67	0.83	1.34	1.43	0.90	0.90
10	W1000	N 45° 48.306' W 077° 07.630' Elev. 134m	691m	0.94	0.67	1.00	0.52	0.69	0.67	1.14	0.67	0.83	0.77	0.86	0.63	0.78
11	SW250	N 45° 48.247' W 077° 07.206' Elev. 140m	183m	1.23	0.96	0.67	0.52	0.69	0.67	1.04	0.91	1.54	1.43	0.67	0.63	0.91
12	SW500	N 45° 47.896' W 077° 07.307' Elev. 148m	839m	0.54	0.67	0.67	0.52	0.69	0.67	0.68	0.67	0.83	0.69	0.67	0.66	0.66
13	SW1000	N 45° 47.599' W 077° 07.543' Elev. 149m	1470m	0.54	0.67	0.67	0.52	0.69	0.67	0.68	0.67	0.83	0.54	0.67	0.63	0.65
14	SW2000	N 45° 47.408' W 077° 07.866' Elev. 155m	2110m	0.54	0.67	0.67	0.52	0.69	0.67	0.68	0.67	0.83	0.57	0.67	0.63	0.65
15	S250	N 45° 48.129' W 077° 07.014' Elev. 131m	356m	1.54	2.04	0.67	1.42	1.72	1.32	1.18	0.67	1.64	1.34	2.04	1.55	1.43
16	S500	N 45° 48.029' W 077° 07.110' Elev. 143m	532m	0.77	0.67	0.67	0.52	0.93	0.67	0.68	0.67	1.21	1.14	0.75	0.66	0.78
17 (PAS # 12)	S1000	N 45° 46.466' W 077° 07.441' Elev. 158m	1450m	0.54	0.67	0.67	0.52	0.69	0.67	0.68	0.67	0.83	0.69	0.67	1.17	0.71
18	SE250	N 45° 48.189' W 077° 06.874' Elev. 132m	365m	3.46	2.54	2.36	4.19	1.37	1.39	3.04	1.17	1.86	2.71	3.50	6.28	2.82
19	SE500	N 45° 48.108' W 077° 06.783' Elev. 123m	554m	1.77	1.75	0.75	2.14	0.69	0.89	1.57	0.67	1.36	1.86	1.29	3.10	1.49
20	SE1000	N 45° 47.894' W 077° 06.501' Elev. 120m	1090m	0.66	0.67	0.67	0.67	0.85	0.67	1.07	0.67	0.83	1.49	0.67	0.76	0.81
21	SE2000	N 45° 47.505' W 077° 05.978' Elev. 137m	2080m	0.60	0.67	0.67	0.52	0.69	0.67	0.79	0.67	0.83	0.83	0.67	0.69	0.69
22	E250	N 45° 80.564' W 077° 11.556' Elev. 131m	220m	1.26	1.36	0.79	1.25	3.04	0.67	2.82	4.83	2.86	3.86	3.07	2.66	2.37
23	E500	N 45° 48.333' W 077° 06.693' Elev. 132m	520m	0.66	1.11	0.67	0.52	0.69	0.67	0.68	0.67	0.83	1.03	1.18	1.55	0.86
24	E1000	N 45° 48.303' W 077° 06.260' Elev. 143m	1080m	0.54	0.67	0.67	0.52	0.69	0.67	0.68	0.67	0.83	1.20	0.89	0.72	0.73
25	NE250	N 45° 48.371' W 077° 06.964' Elev. 124m	198m	1.71	1.71	1.14	1.19	2.78	0.67	1.79	3.86	3.32	3.89	4.68	8.38	2.93
26	NE500	N 45° 48.421' W 077° 06.732' Elev. 131m	508m	0.54	0.89	0.67	0.52	0.69	0.67	0.68	0.67	1.00	1.91	0.96	1.83	0.92
27	NE1000	N 45° 48.683' W 077° 06.441' Elev. 148m	1100m	0.66	0.67	1.39	0.52	0.70	0.67	0.68	0.67	0.83	1.51	0.82	1.10	0.85
28	NE2000	N 45° 49.116' W 077° 05.843' Elev. 156m	2200m	0.54	0.67	0.67	0.52	0.69	0.67	0.68	0.67	0.83	0.74	0.68	0.63	0.67
(PAS #1)		N 45° 48.287' W 077° 07.123' Elev. 129m	94.1m	7.71	2.21	5.71	1.08	3.93	5.07	5.46	5.97	11.61	4.54	4.46	3.00	5.06
(PAS #2)		N 45° 48.325' W 077° 07.132' Elev. 132m	52.8m	4.69	0.82	1.96	5.44	4.26	2.50	6.14	2.86	3.89	6.03	2.36	5.00	3.83
(PAS #13)		N 45° 48.262' W 077° 07.093' Elev. 132m	61.5m	1.20	1.43	3.07	1.06	2.00	1.36	2.64	4.54	3.79	4.57	2.25	1.17	2.42
4-2	NW250	N 45° 48.412' W 077° 07.189' Elev. 137m	222m	1.83	0.67	0.67	0.67	1.19	0.67	1.68	1.00	1.46	1.20	4.75	3.41	1.60
11-2	SW250	N 45° 48.247' W 077° 07.206' Elev. 140m	183m	0.71	0.89	0.67	0.52	0.69	0.67	0.68	0.67	1.21	1.14	0.67	0.63	0.76
18-2	SE250	N 45° 48.189' W 077° 06.874' Elev. 132m	365m	1.80	2.43	1.71	4.00	0.78	1.18	2.79	1.09	1.36	2.43	3.25	4.38	2.27
25-2	NE250	N 45° 48.371' W 077° 06.964' Elev. 124m	198m	0.91	1.32	0.89	0.97	1.70	0.67	1.29	3.46	2.89	3.54	3.96	7.41	2.42
Maika (PAS # 10)	SW	N 45° 46.367' W 077° 11.447' Elev. 149m	6690m	0.54	0.67	0.67	0.52	0.69	0.67	0.68	0.67	0.83	0.66	0.67	0.66	0.66
Maika	Duplicate	Same as above	6690m	0.54	0.67	0.67	0.52	0.69	0.67	0.68	0.67	0.83	0.52	0.67	0.63	0.65
Fitzpatrick	SE	N 45° 44.818' W 076° 59.822' Elev. 159m	11400m	0.54	0.67	0.67	0.52	0.69	0.67	0.68	0.67	0.83	0.69	0.67	0.63	0.66
Petawawa	NW	N 45° 51.497' W 077° 12.828' Elev. 149m	9480m	0.54	0.67	0.67	0.52	0.69	0.67	0.68	0.67	0.83	0.52	0.67	0.66	0.65
Farm	NE	N 45° 53.071' W 076° 56.768' Elev. 142m	16000m	0.60	0.67	0.67	0.52	0.69	0.67	0.68	N/A	0.83	0.52	0.67	0.63	0.65
Results shaded in blue are below minimum detectable activity			Sum	51.13	41.91	41.13	38.98	45.66	35.82	54.36	49.69	62.84	66.44	68.98	82.26	53.32

Monthly Average Concentrations of Tritium in Air in Environment


MAPS OF PAS STATIONS



PAS Stations N / NE / E 

Monthly Average Concentrations of Tritium in Air in Environment


MAPS OF PAS STATIONS



PAS Stations S / SE / E 

Monthly Average Concentrations of Tritium in Air in Environment


MAPS OF PAS STATIONS



PAS Stations W / SW / S ▲

Monthly Average Concentrations of Tritium in Air in Environment

MAPS OF PAS STATIONS




PAS Stations W / NW / N ▲

APPENDIX G

Wind Direction Information

Wind Direction Information

Direction	Passive Air Sampling Data (Results in Bq/m ³)																																															
	January				February				March				April				May				June				July				August				September				October				November				December			
	250 M	500 M	1000 M	2000 M	250 M	500 M	1000 M	2000 M	250 M	500 M	1000 M	2000 M	250 M	500 M	1000 M	2000 M	250 M	500 M	1000 M	2000 M	250 M	500 M	1000 M	2000 M	250 M	500 M	1000 M	2000 M	250 M	500 M	1000 M	2000 M	250 M	500 M	1000 M	2000 M	250 M	500 M	1000 M	2000 M	250 M	500 M	1000 M	2000 M				
North	1.94	0.80	0.80		1.96	0.67	0.67		1.36	0.67	0.67		0.52	0.52	0.52	0.52	0.69	0.69	0.70	0.69	0.67	0.67	0.67	0.67	0.68	0.68	0.75		0.67	0.67	0.67	0.67	0.83	0.96	0.83		2.17	1.66	0.97		5.68	1.29	0.82		3.17	6.83	0.66	
North West	1.89	0.91	0.77	0.54	1.04	0.79	0.93	1.00	0.75	0.67	0.67	0.67	0.86	0.52	0.52	0.52	1.37	0.69	0.69	0.69	0.67	0.67	0.67	0.67	1.75	0.68	0.68	0.68	1.20	0.71	0.67	0.67	1.79	0.83	0.83	0.83	1.80	0.57	0.60	0.91	5.00	1.46	1.50	0.67	4.28	0.97	1.14	1.21
West	1.77	1.06	0.94		1.29	0.71	0.67		0.82	0.68	1.00		0.52	0.52	0.52		1.78	0.69	0.69		0.67	0.67	0.67		1.89	1.25	1.14		0.67	0.67	0.67		0.83	0.83	0.83		1.86	1.34	0.77		0.67	1.43	0.86		0.63	0.90	0.63	
Southwest	1.23	0.54	0.54	0.54	0.96	0.67	0.67	0.67	0.67	0.67	0.67	0.67	0.52	0.52	0.52	0.52	0.69	0.69	0.69	0.69	0.67	0.67	0.67	0.67	1.04	0.68	0.68	0.68	0.91	0.67	0.67	0.67	1.54	0.83	0.83	0.83	1.43	0.69	0.54	0.57	0.67	0.67	0.67	0.67	0.63	0.66	0.63	0.63
South	1.54	0.77	0.54		2.04	0.67	0.67		0.67	0.67	0.67		1.42	0.52	0.52		1.72	1.72	0.69		1.32	0.67	0.67		1.18	0.68	0.68		0.67	0.67	0.67		1.64	1.21	0.83		1.34	1.14	0.69		2.04	0.75	0.67		1.55	0.66	1.17	
South East	3.46	1.77	0.66	0.60	2.54	1.75	0.67	0.67	2.36	0.75	0.67	0.67	4.19	2.14	0.67	0.52	1.37	0.69	0.85	0.69	1.39	0.89	0.67	0.67	3.04	1.57	1.07	0.79	1.17	0.67	0.67	0.67	1.86	1.36	0.83	0.83	2.71	1.86	1.49	0.83	3.50	1.29	0.67	0.67	6.28	3.10	0.76	0.69
East	1.26	0.66	0.54		1.36	1.11	0.67		0.79	0.67	0.67		1.25	0.52	0.52		3.04	0.69	0.69		0.67	0.67	0.67		2.82	0.68	0.68		4.83	0.67	0.67		2.86	0.83	0.83		3.86	1.03	1.20		3.07	1.18	0.89		2.66	1.55	0.72	
North East	1.71	0.54	0.54	0.54	1.71	0.89	0.67	0.67	1.14	0.67	1.39	0.67	1.19	0.52	0.52	0.52	2.78	0.69	0.70	0.69	0.67	0.67	0.67	0.67	1.79	0.68	0.68	0.68	3.86	0.67	0.67	0.67	3.32	1.00	0.83	0.83	3.89	1.91	1.51	0.74	4.68	0.96	0.82	0.68	8.38	1.83	1.10	0.63




APPENDIX H

Precipitation Monitoring Data

Precipitation Monitoring Data

PRECIPITATION SAMPLERS									
	1P	4P	8P	11P	15P	18P	22P	25P	AVG
Sample Collection - Date Range	Bq/L								
Jan. 4, 2023 - Feb. 1, 2023	33	57	55	66	55	136	93	38	67
Feb. 1, 2023 - Mar. 1, 2023	16	28	59	40	14	46	31	11	31
Mar. 1, 2023 - Apr. 6, 2023	6	29	25	7	0	6	6	3	10
Apr. 6, 2023 - May 3, 2023	2	11	19	7	157	9	30	23	32
May 3, 2023 - May 31, 2023	3	41	9	54	7	16	5	10	18
May 31, 2023 - Jun. 28, 2023	6	11	3	11	0	14	19	22	11
Jun. 28, 2023 - Aug. 2, 2023	9	15	19	8	4	17	20	16	14
Aug. 2, 2023 - Aug. 30, 2023	3	5	13	9	205	44	19	21	40
Aug. 30, 2023 - Oct. 4, 2023	19	24	12	6	30	42	180	153	58
Oct. 4, 2023 - Nov. 1, 2023	62	213	10	24	8	50	38	59	58
Nov. 1, 2023 - Nov. 30, 2023	19	77	9	0	1	153	44	110	52
Nov. 30, 2023 - Jan. 3, 2024	21	91	33	119	44	227	8	8	69
AVERAGE	17	50	22	29	44	63	41	40	38

Results shaded in blue are <minimum detectable activity (MDA)




Precipitation Sampling Stations

Precipitation Monitoring Data

Precipitation Monitor 1P


(Scale 0 - 250 Bq/L)



Precipitation Monitoring Data

Precipitation Monitor 4P


(Scale 0 - 750 Bq/L)



Precipitation Monitoring Data

Precipitation Monitor 8P


(Scale 0 - 250 Bq/L)



Precipitation Monitoring Data

Precipitation Monitor 11P


(Scale 0 - 250 Bq/L)



Precipitation Monitoring Data

Precipitation Monitor 15P


(Scale 0 - 250 Bq/L)



Precipitation Monitoring Data

Precipitation Monitor 18P


(Scale 0 - 750 Bq/L)



Precipitation Monitoring Data

Precipitation Monitor 22P


(Scale 0 - 250 Bq/L)



Precipitation Monitoring Data

Precipitation Monitor 25P

(Scale 0 - 250 Bq/L)



APPENDIX I


River Water Monitoring Data

River Water Monitoring Data


Muskrat River Tritium Concentration (2019-2023)

(Blue bars - sample measured as less than minimum detectable activity (MDA); orange bars were above > MDA for the month's sample set)

Jan. 2019 - Mar. 2020 - CNL sampling and analysis, typical MDA ~ 5-6 Bq/L.
 Apr. 2020 - Mar. 2021 - SRBT on-site sampling and analysis, typical MDA ~10-15 Bq/L.
 Apr. 2021 - Dec. 2023 - SRBT off-site sample preparation, on-site analysis, typical MDA ~10 Bq/L



River Water Monitoring Data



River Water Sampling Point 

APPENDIX J

Downspout / Facility Runoff Monitoring Data

Downspout / Facility Runoff Monitoring Data

2023 - Tritium Concentration in Facility Downspout / Runoff Water (Bq/L)								
---------------------------------------------------------------------------------	--	--	--	--	--	--	--	--

Date	Time	DS-1	DS-2	DS-3	DS-4	DS-5	DS-6	MDA
Apr. 17 (rain)	1015h	No sample	<MDA	<MDA	<MDA	<MDA	<MDA	42
	1115h	No sample	<MDA	115	112	<MDA	146	

Jun. 26 (moderate rain)	0915h	86	94	56	294	41	1,216	39
	1115h	<MDA	52	114	88	270	424	


Sep. 18 (heavy rain)	0800h	69	<MDA	770	2,219	10,483	5,201	37
	0930h	275	<MDA	<MDA	41	45	304	

Average (Bq/L) (<MDA taken to be 0)	108	24	176	459	1,807	1,216	39
----------------------------------------	-----	----	-----	-----	-------	-------	----

Average of all samples obtained (<MDA taken to be 0)	662 Bq/L
Average of all samples obtained (<MDA taken to be MDA value)	675 Bq/L
Average of samples exceeding MDA	979 Bq/L

*MDA = Minimum Detectable Activity

Downspout / Facility Runoff Monitoring Data




Facility Downspout Runoff Sampling Points 

APPENDIX K

Produce Monitoring Data

Produce Monitoring Data

Map – SRBT Produce Sampling 2023



Produce Sample Points ●

Produce Monitoring Data

2023 Residential Produce Sampling – Free-water Tritium Concentration

Sample	Units	Result
Cucumber 611 Moss Drive	Bq/kg Fresh weight	99
Green Onion 611 Moss Drive	Bq/kg Fresh weight	461
Beans 171 Sawmill Road	Bq/kg Fresh weight	8
Tomatoes 171 Sawmill Road	Bq/kg Fresh weight	8
Cucumber 171 Sawmill Road	Bq/kg Fresh weight	9
Carrots 171 Sawmill Road	Bq/kg Fresh weight	6
Rhubarb 632 Johnston Crescent	Bq/kg Fresh weight	68
Zucchini 632 Johnston Crescent	Bq/kg Fresh weight	48
Tomatoes 632 Johnston Crescent	Bq/kg Fresh weight	60

2023 Residential Produce Sampling – Organically-bound Tritium (OBT) Concentration

Sample	Units	Result
Tomatoes 632 Johnston Crescent	OBT Bq/kg Fresh weight	2
Cucumber 611 Moss Drive	OBT Bq/kg Fresh weight	2

Produce Monitoring Data

2023 Commercial Produce Sampling – Free-water Tritium Concentration

Sample	Units	Result
Tomatoes 11333 Round Lake Road	Bq/kg Fresh weight	3
Potatoes 11333 Round Lake Road	Bq/kg Fresh weight	5
Onions 11333 Round Lake Road	Bq/kg Fresh weight	3
Beets 11333 Round Lake Road	Bq/kg Fresh weight	4

2023 Commercial Produce Sampling – Organically-bound Tritium (OBT) Concentration


Sample	Units	Result
Tomato 11333 Round Lake Road	OBT Bq/kg Fresh weight	0

Produce Monitoring Data

Produce Sampling Data Trends
2019-2023


Produce Monitoring Data

Produce Monitoring - 11333 Round Lake Road
(Scale: 0 - 100 Bq/kg fresh weight)




Produce Monitoring Data

Produce Monitoring - 632 Johnston Crescent (Scale: 0 - 250 Bq/kg fresh weight)




Produce Monitoring Data

Produce Monitoring - 171 Sawmill Road (Scale: 0 - 250 Bq/kg fresh weight)




Produce Monitoring Data

Produce Monitoring - 611 Moss Drive (Scale: 0 - 500 Bq/kg fresh weight)




Produce Monitoring Data

Produce Monitoring - 413 Sweezy Court
(Scale: 0 - 250 Bq/kg fresh weight)



Produce Monitoring Data




APPENDIX L

Milk Monitoring Data

Milk Monitoring Data

MILK MONITORING		
Results shaded in blue are <MDA (minimum detectable activity)		
	LOCAL MILK PRODUCER	LOCAL MILK DISTRIBUTOR
	Bq/L	Bq/L
01-Mar-19	4.7	3
28-Jun-19	4.9	4
01-Nov-19	3	3
02-Mar-20	4.7	4
30-Jun-20	4	4
04-Nov-20	3	3
02-Mar-21	4	4
06-Jul-21	4	4
08-Sep-21	4	4
17-Mar-22	4	4
07-Sep-22	4	4
08-Mar-23	4	4
13-Sep-23	4	4



APPENDIX M

Weather Data

Weather Data

WEATHER DATA SUMMARY (2019-2023)																			
Month	Precip Counts, # (TOTAL)	Wind Speed, m/s (AVG)	Gust Speed, m/s (AVG)	Wind Direction, ° (AVG)	Temp, °C (AVG)	RH, % (AVG)	DewPt, °C (AVG)	Average wind sector (NSEW)	Total precipitation (rain eq. mm)										
January-2019	767	2.7	4.0	215.7	-13.0	79.2	-15.9	SW	153										
February-2019	116	2.6	3.9	196.8	-9.7	74.9	-13.5	SSW	23										
March-2019	178	3.0	4.5	231.7	-3.6	68.1	-9.2	SW	36										
April-2019	778	3.0	4.5	204.9	4.1	73.3	-0.8	SSW	156										
May-2019	369	2.6	4.0	212.2	10.8	72.9	5.6	SW	74										
June-2019	493	2.3	3.7	248.4	16.8	70.5	10.7	WSW	99										
July-2019	321	1.9	3.1	264.1	21.9	71.2	15.9	WSW	64										
August-2019	285	2.0	3.2	239.8	19.4	71.7	13.6	SW	57										
September-2019	228	2.1	3.3	246.7	14.6	78.8	10.6	WSW	46										
October-2019	690	2.4	3.7	246.2	7.8	80.9	4.5	WSW	138										
November-2019	219	2.1	3.3	249.3	14.8	78.9	10.8	WSW	44										
December-2019	190	1.7	2.8	237.0	-5.0	84.7	-7.2	SW	38										
January-2020	246	1.6	2.7	245.3	-7.4	84.1	-9.7	WSW	49										
February-2020	165	1.9	3.4	251.2	-7.4	73.2	-11.6	WSW	33										
March-2020	374	1.8	3.2	232.0	0.2	71.3	-4.9	SW	75										
April-2020	261	2.0	3.8	Wind Measurement Malfunction	4.6	61.4	-3.1	Wind Measurement Malfunction	52										
May-2020	375	1.2	2.8		12.1	59.4	3.2		75										
June-2020	297	1.3	2.7		19.0	70.2	12.9		59										
July-2020	358	1.0	2.2		23.2	72.5	17.4		72										
August-2020	1131	0.6	1.3		18.6	82.1	15.1		226										
September-2020	344	-6.9	-6.7		13.5	79.3	9.7		69										
October-2020	296	0.0	0.2		5.9	78.1	2.2		59										
November-2020	259	0.0	1.5		3.7	78.7	-0.9		52										
December-2020	192	0.0	1.1		-4.6	84.9	-6.8		38										
January-2021	66	0.1	0.9		-7.2	83.1	-9.6		13										
February-2021	121	0.3	1.2		-8.1	75.6	-11.8		24										
March-2021	Weather Station taken offline for investigation, corrective maintenance and component replacement.																		
April-2021																			
May-2021																			
June-2021																			
July-2021																			
August-2021																			
September-2021	Weather Station taken offline for investigation, corrective maintenance and component replacement.																		
October-2021											271	2.7	4.2	201.9	10.9	83.8	8.1	SSW	54
November-2021											102	3.1	4.7	225.2	0.9	79.4	-2.5	SW	20
December-2021											253	4.0	6.1	209.2	-4.5	79.4	-7.6	SSW	51
January-2022											80	3.4	5.0	223.1	-13.8	77.7	-17.0	SW	16
February-2022											36	3.5	5.3	222.7	-13.6	78.4	-16.6	SW	7
March-2022	198	3.8	5.8	186.9	-1.1	72.0	-5.8	SSW	40										
April-2022	401	4.3	6.6	192.0	6.2	66.3	-0.5	SSW	80										
May-2022	116	3.5	5.5	48.9	17.7	75.1	12.7	NE	23										
June-2022	100	3.2	5.1	151.8	16.0	63.0	7.6	SSE	20										
July-2022	Precipitation counting malfunction	2.8	4.8	153.6	20.6	71.0	14.7	SSE	Precipitation counting malfunction										
August-2022		2.6	4.3	214.0	19.9	77.4	15.4	SW											
September-2022		2.7	4.4	210.6	14.8	83.6	11.8	SSW											
October-2022		2.6	4.1	189.7	8.6	79.5	4.9	SSW											
November-2022		3.9	6.0	218.9	3.0	73.2	-1.7	SW											
December-2022	359	3.4	5.1	200.2	-2.4	84.2	-4.8	SSW	72										
January-2023	89	2.9	4.4	224.2	-7.1	84.7	-9.3	SW	18										
February-2023	134	3.3	5.1	203.2	-7.2	76.8	-10.7	SSW	27										
March-2023	348	3.8	6.0	227.4	-1.2	71.7	-5.9	SW	70										
April-2023	509	3.3	5.2	197.7	8.2	67.6	1.8	SSW	102										
May-2023	184	3.1	5.2	228.0	13.7	56.1	3.9	SW	37										
June-2023	596	2.7	4.3	207.3	18.4	73.3	13.0	SSW	119										
July-2023	598	2.4	4.0	221.4	20.5	78.4	16.2	SW	120										
August-2023	244	2.8	4.5	238.4	18.2	81.0	14.6	SW	49										
September-2023	149	2.0	3.3	228.5	16.3	80.1	12.4	SW	30										
October-2023	430	3.2	5.0	230.6	8.9	84.9	6.4	SW	86										
November-2023	91	3.4	5.3	229.2	0.0	80.6	-3.1	SW	18										
December-2023	181	2.6	4.0	202.8	-2.6	85.9	-4.7	SSW	36										


APPENDIX N

Groundwater Monitoring Data


Groundwater Monitoring Data - 2022

Well I.D.	Description (location, profile)		Distance from Stacks (m)	2023-03-22 (Bq/L)	2023-06-14 (Bq/L)	2023-09-19 (Bq/L)	2023-12-12 (Bq/L)	2023 Avg. (Bq/L)
Engineered Sampling Wells								
MW06-1	SRB SITE	IN SOIL	50	445	409	409	434	424
MW06-2	SRB SITE	IN SOIL	75	520	432	493	512	489
MW06-3	SRB SITE	IN SOIL	50	134	133	No Sample	157	141
MW06-8	SRB SITE	IN SOIL	55	No Sample	468	467	490	475
MW06-9	SRB SITE	IN SOIL	25	1,045	1,031	1,057	1,043	1,044
MW06-10	SRB SITE	SURFACE OF BEDROCK	0	20,347	24,981	31,011	28,540	26,220
MW07-11	SRB SITE	SURFACE OF BEDROCK	75	833	724	770	708	759
MW07-12	SRB SITE	SURFACE OF BEDROCK	55	432	413	416	490	438
MW07-13	SRB SITE	SURFACE OF BEDROCK	50	2,193	2,038	2,010	1,910	2,038
MW07-15	SRB SITE	SURFACE OF BEDROCK	25	1,029	912	1,011	1,007	990
MW07-16	SRB SITE	SURFACE OF BEDROCK	15	630	617	634	616	624
MW07-17	SRB SITE	DEEPER BEDROCK	15	256	227	194	272	237
MW07-18	SRB SITE	SURFACE OF BEDROCK	10	663	522	726	686	649
MW07-19	SRB SITE	SURFACE OF BEDROCK	20	596	588	752	665	650
MW07-20	SUPERIOR PROPANE PROPERTY	SURFACE OF BEDROCK	90	248	213	201	226	222
MW07-21	SUPERIOR PROPANE PROPERTY	SURFACE OF BEDROCK	110	290	244	307	314	289
MW07-22	SRB SITE	SURFACE OF BEDROCK	70	602	617	597	626	611
MW07-23	SRB SITE	SURFACE OF BEDROCK	90	939	881	903	910	908
MW07-24	HARRINGTON PROPERTY	SURFACE OF BEDROCK	115	1,265	1,182	1,238	1,217	1,226
MW07-26	SRB SITE	SURFACE OF BEDROCK	50	249	202	240	259	238
MW07-27	CITY PROPERTY	SURFACE OF BEDROCK	55	1,284	638	1,274	1,326	1,131
MW07-28	CITY PROPERTY	DEEPER BEDROCK	55	457	440	431	447	444
MW07-29	SRB SITE	DEEPER BEDROCK	10	544	643	699	782	667
MW07-31	SRB SITE	DEEPER BEDROCK	70	255	183	274	308	255
MW07-32	HARRINGTON PROPERTY	DEEPER BEDROCK	115	49	< MDA (37)	<MDA (36)	69	59
MW07-34	SRB SITE	SHALLOW BEDROCK	10	751	772	761	729	753
MW07-35	CITY PROPERTY	SHALLOW BEDROCK	55	1,136	973	1,077	1,116	1,076
MW07-36	CITY PROPERTY	SHALLOW BEDROCK	80	1,186	951	1,113	1,199	1,112
MW07-37	SRB SITE	SHALLOW BEDROCK	60	673	636	635	688	658
Residential and Business Wells								
RW-2	185 MUD LAKE ROAD		1,100	26		27		27
RW-3	183 MUD LAKE ROAD		1,100	39		No Sample		39
RW-5	171 SAWMILL ROAD		2,300	5		4		5
RW-6	40987 HWY 41		1,400	6		4		5
RW-7	40925 HWY 41		1,600	28		4		16
B-1	VALLEY POOL SERVICE OFFICE		160	798		927		863
B-2	SUPERIOR PROPANE TRUCK WASH		250	327		379		353


Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data




Groundwater Monitoring Data



Groundwater Monitoring Data



Groundwater Monitoring Data



APPENDIX O


Gaseous Effluent Data

Gaseous Effluent Data

2023 Gaseous Effluent Data													
Week	Date		H-3 in Air (GBq)			(GBq)		% 2021 SRBT DRL (12 hr. T.J.F. Data)				Weekly Action Levels	
	Initial	Final	HTO	HT	Total	Σ(HTO)	Σ(HTO + HT)	1 year old	10 year old	Adult Resident	Adult Worker	HTO (840 GBq)	HTO+HT (7,753 GBq)
1	2023-01-03	2023-01-10	88.64	785.05	873.69	88.64	873.69	0.04	0.05	0.04	0.10	11%	11%
2	2023-01-10	2023-01-17	86.12	192.70	278.82	174.76	1152.51	0.03	0.04	0.03	0.09	10%	4%
3	2023-01-17	2023-01-24	124.10	299.42	423.52	298.86	1576.03	0.05	0.06	0.05	0.12	15%	5%
4	2023-01-24	2023-01-31	57.52	112.40	169.92	356.38	1745.95	0.02	0.03	0.02	0.06	7%	2%
5	2023-01-31	2023-02-07	55.82	172.65	228.47	412.20	1974.42	0.02	0.03	0.02	0.06	7%	3%
6	2023-02-07	2023-02-14	109.87	219.06	328.93	522.07	2303.35	0.04	0.05	0.04	0.11	13%	4%
7	2023-02-14	2023-02-21	95.57	110.99	206.56	617.64	2509.91	0.03	0.04	0.04	0.09	11%	3%
8	2023-02-21	2023-02-28	120.85	187.62	308.47	738.49	2818.38	0.04	0.05	0.05	0.12	14%	4%
9	2023-02-28	2023-03-07	78.95	181.26	260.21	817.44	3078.59	0.03	0.03	0.03	0.08	9%	3%
10	2023-03-07	2023-03-14	106.32	253.74	360.06	923.76	3438.65	0.04	0.05	0.04	0.11	13%	5%
11	2023-03-14	2023-03-21	115.53	275.33	390.86	1039.29	3829.51	0.04	0.05	0.05	0.11	14%	5%
12	2023-03-21	2023-03-28	98.32	299.64	397.96	1137.61	4227.47	0.04	0.04	0.04	0.10	12%	5%
13	2023-03-28	2023-04-04	63.66	106.47	170.13	1201.27	4397.60	0.02	0.03	0.03	0.06	8%	2%
14	2023-04-04	2023-04-11	32.56	46.30	78.86	1233.83	4476.46	0.01	0.01	0.01	0.03	4%	1%
15	2023-04-11	2023-04-18	84.33	114.93	199.26	1318.16	4675.72	0.03	0.04	0.03	0.08	10%	3%
16	2023-04-18	2023-04-25	98.02	170.87	268.89	1416.18	4944.61	0.04	0.04	0.04	0.10	12%	3%
17	2023-04-25	2023-05-02	116.42	209.46	325.88	1532.60	5270.49	0.04	0.05	0.05	0.11	14%	4%
18	2023-05-02	2023-05-09	87.51	462.87	550.38	1620.11	5820.87	0.04	0.04	0.04	0.09	10%	7%
19	2023-05-09	2023-05-16	78.02	329.96	407.98	1698.13	6228.85	0.03	0.04	0.03	0.08	9%	5%
20	2023-05-16	2023-05-23	77.04	214.39	291.43	1775.17	6520.28	0.03	0.03	0.03	0.08	9%	4%
21	2023-05-23	2023-05-30	87.43	470.31	557.74	1862.60	7078.02	0.04	0.04	0.04	0.09	10%	7%
22	2023-05-30	2023-06-06	116.61	370.68	487.29	1979.21	7565.31	0.05	0.05	0.05	0.12	14%	6%
23	2023-06-06	2023-06-13	102.62	191.17	293.79	2081.83	7859.10	0.04	0.04	0.04	0.10	12%	4%
24	2023-06-13	2023-06-20	168.47	219.51	387.98	2250.30	8247.08	0.06	0.07	0.07	0.16	20%	5%
25	2023-06-20	2023-06-27	144.17	187.88	332.05	2394.47	8579.13	0.05	0.06	0.06	0.14	17%	4%
26	2023-06-27	2023-07-04	99.31	117.62	216.93	2493.78	8796.06	0.04	0.04	0.04	0.10	12%	3%
27	2023-07-04	2023-07-11	154.14	177.83	331.97	2647.92	9128.03	0.06	0.07	0.06	0.15	18%	4%
28	2023-07-11	2023-07-18	144.83	195.58	340.41	2792.75	9468.44	0.05	0.06	0.06	0.14	17%	4%
29	2023-07-18	2023-07-25	96.27	128.45	224.72	2889.02	9693.16	0.03	0.04	0.04	0.09	11%	3%
30	2023-07-25	2023-08-01	152.09	339.24	491.33	3041.11	10184.49	0.06	0.07	0.06	0.15	18%	6%
31	2023-08-01	2023-08-08	112.57	187.55	300.12	3153.68	10484.61	0.04	0.05	0.04	0.11	13%	4%
32	2023-08-08	2023-08-15	95.54	146.69	242.23	3249.22	10726.84	0.03	0.04	0.04	0.09	11%	3%
33	2023-08-15	2023-08-22	116.37	152.68	269.05	3365.59	10995.89	0.04	0.05	0.05	0.11	14%	3%
34	2023-08-22	2023-08-29	153.01	175.12	328.13	3518.60	11324.02	0.06	0.07	0.06	0.15	18%	4%
35	2023-08-29	2023-09-05	152.07	207.33	359.40	3670.67	11683.42	0.06	0.07	0.06	0.15	18%	5%
36	2023-09-05	2023-09-12	234.30	833.45	1067.75	3904.97	12751.17	0.09	0.11	0.10	0.24	28%	14%
37	2023-09-12	2023-09-19	147.77	215.07	362.84	4052.74	13114.01	0.05	0.06	0.06	0.14	18%	5%
38	2023-09-19	2023-09-26	167.42	285.10	452.52	4220.16	13566.53	0.06	0.07	0.07	0.16	20%	6%
39	2023-09-26	2023-10-03	137.46	125.42	262.88	4357.62	13829.41	0.05	0.06	0.05	0.13	16%	3%
40	2023-10-03	2023-10-10	164.36	143.94	308.30	4521.98	14137.71	0.06	0.07	0.06	0.16	20%	4%
41	2023-10-10	2023-10-17	288.78	754.13	1042.91	4810.76	15180.62	0.11	0.13	0.12	0.29	34%	13%
42	2023-10-17	2023-10-24	222.64	406.45	629.09	5033.40	15809.71	0.08	0.10	0.09	0.22	27%	8%
43	2023-10-24	2023-10-31	224.57	437.68	662.25	5257.97	16471.96	0.08	0.10	0.09	0.22	27%	9%
44	2023-10-31	2023-11-07	172.38	218.81	391.19	5430.35	16863.15	0.06	0.07	0.07	0.17	21%	5%
45	2023-11-07	2023-11-14	138.61	545.44	684.05	5568.96	17547.20	0.06	0.06	0.06	0.14	17%	9%
46	2023-11-14	2023-11-21	193.74	296.72	490.46	5762.70	18037.66	0.07	0.08	0.08	0.19	23%	6%
47	2023-11-21	2023-11-28	178.72	453.26	631.98	5941.42	18669.64	0.07	0.08	0.07	0.18	21%	8%
48	2023-11-28	2023-12-05	137.97	464.59	602.56	6079.39	19272.20	0.05	0.06	0.06	0.14	16%	8%
49	2023-12-05	2023-12-12	112.42	195.72	308.14	6191.81	19580.34	0.04	0.05	0.04	0.11	13%	4%
50	2023-12-12	2023-12-19	217.45	411.74	629.19	6409.26	20209.53	0.08	0.09	0.09	0.21	26%	8%
51	2023-12-19	2023-12-26	99.91	164.47	264.38	6509.17	20473.91	0.04	0.04	0.04	0.10	12%	3%
52	2023-12-26	2024-01-02	31.11	15.18	46.29	6540.28	20520.20	0.01	0.01	0.01	0.03	4%	1%
Annual Total			6540.28	13979.92	20520.20			Average % DRL					
Weekly Average			125.77	268.84	394.62			0.05	0.06	0.05	0.12		
% Annual Release Limit:			Limit (Bq/a)		% Limit (2021)		Projected Dose (uSv/a)						
			HTO		9.73		0.47						
			HTO + HT		4.58		0.55						
							1 year old						
							10 year old						
							Adult Resident						
							Adult Worker						
Derived Weekly HTO Release/Emission Limit (GBq/week)							2.90E+05						
Derived Weekly HT Release/Emission Limit (GBq/week)							7.24E+06						
							2.45E+05						
							6.83E+06						
							6.90E+06						
							3.63E+06						


Gaseous Effluent Data

Weekly Gaseous Effluent: HTO 2023



Gaseous Effluent Data

Weekly Gaseous Effluent: Total Tritium 2023



APPENDIX P


Liquid Effluent Data

Liquid Effluent Data

ANNUAL LIQUID EFFLUENT DATA		
2023		
WEEK ENDING	WEEKLY RELEASE (Bq)	WEEK
8-Jan-23	0	1
15-Jan-23	0	2
22-Jan-23	2,640,493	3
29-Jan-23	0	4
5-Feb-23	0	5
12-Feb-23	0	6
19-Feb-23	0	7
26-Feb-23	2,825,320	8
5-Mar-23	64,736,700	9
12-Mar-23	634,667	10
19-Mar-23	0	11
26-Mar-23	0	12
2-Apr-23	2,171,287	13
9-Apr-23	0	14
16-Apr-23	827,840	15
23-Apr-23	0	16
30-Apr-23	0	17
7-May-23	3,780,000	18
14-May-23	4,083,600	19
21-May-23	0	20
28-May-23	0	21
4-Jun-23	0	22
11-Jun-23	0	23
18-Jun-23	166,250	24
25-Jun-23	2,140,293	25
2-Jul-23	7,432,000	26
9-Jul-23	0	27
16-Jul-23	45,693,267	28
23-Jul-23	48,619,560	29
30-Jul-23	5,414,347	30
6-Aug-23	11,977,535	31
13-Aug-23	0	32
20-Aug-23	14,456,640	33
27-Aug-23	12,705,000	34
3-Sep-23	0	35
10-Sep-23	131,951,603	36
17-Sep-23	195,894,300	37
24-Sep-23	14,470,587	38
1-Oct-23	3,635,280	39
8-Oct-23	0	40
15-Oct-23	0	41
22-Oct-23	0	42
29-Oct-23	0	43
5-Nov-23	3,846,773	44
12-Nov-23	0	45
19-Nov-23	0	46
26-Nov-23	0	47
3-Dec-23	0	48
10-Dec-23	5,968,807	49
17-Dec-23	0	50
24-Dec-23	94,320,600	51
31-Dec-24	0	52
Annual Total (Bq)	680,392,749	
Annual Total (GBq)	0.68	
Licence Limit (GBq)	200	
% of limit	0.34%	

Liquid Effluent Data

Daily Liquid Effluent: 2023



APPENDIX Q

Groundwater Monitoring Well Level Data

Groundwater Monitoring Well Level Data


Well ID	Well Location and Characteristics							2023 Well Level Measurements (masl)			
	Eastings	Northing	TOP Elevation (m)	GS Elevation (m)	Well Diameter (m)	Well Depth (m)	Stick-up (m)	Mar. 21	Jun. 13	Sep. 19	Dec. 11
MW06-1	335449	5074615	130.99	130.17	0.051	5.165	0.820	128.75	128.72	128.11	128.31
MW06-2	335478	5074578	130.03	129.24	0.051	5.330	0.788	127.37	127.73	127.43	127.83
MW06-3	335363	5074535	133.09	132.32	0.051	6.130	0.767	129.12	128.09	127.07	127.70
MW06-8	335464	5074590	130.30	129.58	0.032	6.700	0.720	127.46	127.20	126.45	126.70
MW06-9	335401	5074605	131.15	129.86	0.032	5.930	1.290	128.66	128.60	127.28	127.79
MW06-10	335408	5074506	131.32	130.24	0.032	7.770	1.077	128.32	128.07	126.91	127.40
MW07-11	335478	5074576	130.06	129.15	0.032	7.215	0.905	127.42	127.66	126.50	126.86
MW07-12	335465	5074588	130.41	129.58	0.032	7.450	0.835	127.42	127.21	126.39	126.71
MW07-13	335448	5074616	130.92	130.03	0.032	6.615	0.893	127.32	128.15	126.27	126.59
MW07-15	335403	5074605	130.84	129.93	0.032	7.230	0.910	128.24	128.14	127.02	127.51
MW07-16	335393	5074599	130.98	130.16	0.032	7.050	0.822	128.26	127.88	126.87	127.38
MW07-17	335392	5074599	131.08	130.16	0.051	14.610	0.915	123.22	123.08	121.97	122.34
MW07-18	335387	5074595	131.23	130.37	0.032	7.250	0.868	128.17	128.03	126.86	127.31
MW07-19	335378	5074587	131.61	130.79	0.032	7.400	0.815	128.41	128.11	126.87	127.38
MW07-20	335296	5074616	130.70	129.85	0.032	7.820	0.850	126.70	126.14	125.22	125.34
MW07-21	335522	5074584	129.51	128.78	0.032	7.580	0.730	126.36	125.21	124.00	124.59
MW07-22	335472	5074584	130.25	129.05	0.032	7.465	1.200	127.30	128.08	126.28	126.47
MW07-23	335492	5074560	130.04	129.29	0.032	5.905	0.750	127.95	127.60	126.92	127.36
MW07-24	335519	5074530	129.03	128.22	0.032	6.525	0.810	126.93	126.67	126.11	126.45
MW07-26	335357	5074567	132.42	131.85	0.032	7.310	0.570	128.42	127.72	126.19	127.04
MW07-27	335354	5074611	132.89	132.02	0.032	8.330	0.870	127.59	127.39	125.90	126.34
MW07-28	335352	5074612	132.71	132.04	0.032	14.400	0.670	123.31	123.01	122.13	122.54
MW07-29	335384	5074592	131.09	130.57	0.032	13.000	0.520	123.28	123.19	122.13	122.52
MW07-31	335471	5074583	130.16	129.38	0.032	13.240	0.780	122.29	121.83	120.49	120.58
MW07-32	335517	5074530	128.86	128.23	0.032	13.090	0.630	122.26	121.78	120.48	120.59
MW07-34	335393	5074591	131.12	130.71	0.032	9.110	0.410	127.00	126.87	125.69	126.06
MW07-35	335354	5074613	132.89	132.16	0.032	9.390	0.730	127.14	127.09	125.69	125.11
MW07-36	335338	5074629	133.10	132.31	0.032	9.330	0.790	125.95	125.90	124.94	125.17
MW07-37	335468	5074589	130.06	129.47	0.032	8.590	0.590	127.57	127.36	126.55	126.82

APPENDIX R

Public Dose Data

Public Dose Data
ADULT WORKER

Dose Calculation	2023 μSv
%2021 DRL (gaseous emissions)	1.239
2023 EMP (no groundwater)	1.408
2023 EMP (groundwater included)	2.251



**Public Dose Data
ADULT WORKER**

Stack Emissions

2023 Emissions as %2021 SRBT DRL		
ADULT WORKER		
Sample End	% weekly DRL	(uSv)
2023-01-10	0.10	0.0199
2023-01-17	0.09	0.0164
2023-01-24	0.12	0.0237
2023-01-31	0.06	0.0108
2023-02-07	0.06	0.0109
2023-02-14	0.11	0.0207
2023-02-21	0.09	0.0176
2023-02-28	0.12	0.0225
2023-03-07	0.08	0.0150
2023-03-14	0.11	0.0203
2023-03-21	0.11	0.0220
2023-03-28	0.10	0.0191
2023-04-04	0.06	0.0119
2023-04-11	0.03	0.0060
2023-04-18	0.08	0.0156
2023-04-25	0.10	0.0184
2023-05-02	0.11	0.0218
2023-05-09	0.09	0.0180
2023-05-16	0.08	0.0156
2023-05-23	0.08	0.0149
2023-05-30	0.09	0.0181
2023-06-06	0.12	0.0227
2023-06-13	0.10	0.0193
2023-06-20	0.16	0.0312
2023-06-27	0.14	0.0267
2023-07-04	0.10	0.0183
2023-07-11	0.15	0.0284
2023-07-18	0.14	0.0268
2023-07-25	0.09	0.0178
2023-08-01	0.15	0.0289
2023-08-08	0.11	0.0210
2023-08-15	0.09	0.0178
2023-08-22	0.11	0.0215
2023-08-29	0.15	0.0282
2023-09-05	0.15	0.0282
2023-09-12	0.24	0.0461
2023-09-19	0.14	0.0275
2023-09-26	0.16	0.0313
2023-10-03	0.13	0.0251
2023-10-10	0.16	0.0300
2023-10-17	0.29	0.0554
2023-10-24	0.22	0.0418
2023-10-31	0.22	0.0423
2023-11-07	0.17	0.0319
2023-11-14	0.14	0.0276
2023-11-21	0.19	0.0361
2023-11-28	0.18	0.0342
2023-12-05	0.14	0.0270
2023-12-12	0.11	0.0211
2023-12-19	0.21	0.0409
2023-12-26	0.10	0.0187
2024-01-02	0.03	0.0056
Sum (uSv)		1.239
Ave. (%DRL)	0.12	
Annual Dose Est.	1.239 uSv/a	

**Public Dose Data
ADULT WORKER
EMP Factors for Dose**

Pathways Analysis of Dose to the Public		per annum
Atmospheric HTO inhalation, immersion	P(i)19, P(e)19	0.662
Surface HTO ingestion	P(i)29	0.843
Surface HTO immersion	P(e)29	0.000
External soil exposure	P39	0.000
Forage & crop ingestion	P49	0.731
Animal produce ingestion	P59	0.015
Aquatic animal ingestion	P69	0.000
Aquatic plant ingestion	P79	0.000
External sediment exposure	P89	0.000
Total (uSv)		2.251 uSv/a
Total without P₂₉ (uSv)		1.408 uSv/a

**Public Dose Data
ADULT WORKER
EMP Factors for Dose P19**

P19 is the transfer pathway of exposure to HTO from compartment 1 (Atmosphere) to 9 (dose)

P(i)19 is the pathway of exposure due to inhalation of HTO, and also implicitly captures skin absorption dose P(e)19 as per CSA N288.1-14 Table C.1.

Formula:

$$P(i)19 \text{ (uSv)} = [\text{HTO}]_{\text{air}} \text{ (Bq/m}^3\text{)} \times \text{Inhalation (m}^3\text{)} \times \text{DCF (uSv/Bq)}$$

Calculation:

PAS # (#)	P(i)19 (uSv)	[HTO]air (Bq/m ³)	Volume (m ³)	(uSv/Bq)	(uSv/a)	(uSv/a)	(uSv/a)	Maximum (uSv/a)	
1	0.303	5.060	1994.496	3.000E-05	0.303				
2	0.229	3.830	1994.496	3.000E-05		0.229			
3	0.000			3.000E-05					
4	0.359	1.870	6405.504	3.000E-05	0.359	0.359	0.359		
5	0.000			3.000E-05					
6	0.000			3.000E-05					
7	0.000			3.000E-05					
8	0.000			3.000E-05					
9	0.000			3.000E-05					
10	0.000			3.000E-05					
11	0.000			3.000E-05					
12	0.000			3.000E-05					
13	0.145	2.420	1994.496	3.000E-05			0.145		
P(i)19 Sum					0.662	0.589	0.504	0.662	uSv/a

**Public Dose Data
ADULT WORKER
EMP Factors for Dose P29**

P29 is the transfer pathway of exposure to HTO from compartment 2 (Surface Water) to 9 (Dose)

P(i)29 is the pathway of exposure due to ingestion of HTO

P(e)29 is the pathway of exposure due to immersion in HTO

Formula:

$$P(i)29 = [HTO] \text{ (Bq/L)} \times \text{Ingestion (L)} \times \text{DCF (uSv/Bq)}$$

Well	P(i)29 (uSv/a)	[HTO]well (Bq/L)	Ingestion (L/a)	DCF (uSv/Bq)	Date	Well 2 (Bq/L)	Well 3 (Bq/L)	Well 5 (Bq/L)	Well 6 (Bq/L)	Well 7 (Bq/L)
2	0.573	26.5	1081.1	2.00E-05	March 8, 2023	26	39	5	6	28
3	0.843	39.0	1081.1	2.00E-05	September 13, 2023	27	NS	4	4	4
5	0.097	4.5	1081.1	2.00E-05	Average	26.5	39.0	4.5	5.0	16.0
6	0.108	5.0	1081.1	2.00E-05						
7	0.346	16.0	1081.1	2.00E-05						
Avg P(i)29		0.394 uSv/annum								

Well 2	185 Mud Lake Road
Well 3	183 Mud Lake Road
Well 5	171 Sawmill Road
Well 6	40987 Highway 41
Well 7	40925 Highway 41

Well 3	P(i)29	0.843	uSv/a
	P(e)29	0.000	uSv/a
	P29	0.843	uSv/a

P(e)29 is the pathway of exposure to HTO due to immersion in surface water, and is negligible.

**Public Dose Data
ADULT WORKER
EMP Factors for Dose P49**

P49 is the pathway for exposure to HTO due to ingestion of forage and crops.

Produce Sample Results (Bq free water tritium / kg fresh weight)														
Source	Farm Gate Market 11133 Round Lake Road					Residences								
Type	Tomato	Potato	Beet	Onion	Average	LOCATION	Cucumber	Green Onion	Beans	Tomatoes	Carrots	Zucchini	Rhubarb	Average
	3	5	4	3	3.8	611 MOSS DRIVE	99	461						280.0
						171 SAWMILL ROAD	9		8	8	6			7.8
						632 JOHNSON CRES.				60		48	68	58.7
					3.8	Average	54	461	8	34	6	48	68	38.0
Produce Sample Results (Bq organically bound tritium / kg fresh weight)														
OBT	0.3				0.3	408 BOUNDARY ROAD		2		2				2.0
Produce Consumption														
100%=	413.300 kg/a		[HTO] (Bq/kg)	(Bq/a)	[OBT] (Bq/kg)	(Bq/a)								
70%	289.310 kg/a		3.8	1084.91	0.3	86.79								
30%	123.990 kg/a		280.0	34717.20	2.0	247.98								

$P49 = [HTO \text{ or } OBT]_{produce} (Bq/kg) \times Produce \text{ Ingested } (kg/mo) \times DCF (uSv/Bq)$

P49 (uSv/a)	[HTO] pro (Bq/a)	DCF (uSv/Bq)	[OBT] pro (Bq/a)	DCF (uSv/Bq)
0.731	35802.11	2.00E-05	334.77	4.60E-05

P49	0.731	uSv/a
-----	-------	-------

**Public Dose Data
ADULT WORKER
EMP Factors for Dose P59**

P59 is the exposure to HTO due to ingestion of animal produce.

Local Producer	
	(Bq/L)
1	4.00
2	4.00
Average	4.00

Local Distributor	
	(Bq/L)
1	4.00
2	4.00
Average	4.00

TOTAL AVERAGE	4.00	Bq/L
---------------	-------------	------

Milk Density Adjustment		
Milk Average (Bq/L) x Milk density (L/kg)		
Bq/L	L/kg	Bq/kg
4.00	0.97	3.880


Consumption		
kg/da x da/a = kg/a		
(kg/da)	(da/a)	(kg/a)
0.516	365.25	188.5

P59 = [HTO] animal produce (Bq/kg) x Ingestion (kg) x DCF			
P59	[HTO]	Ingested	DCF
(uSv/a)	(Bq/kg)	(kg/a)	(uSv/Bq)
0.015	3.88	188.5	2.00E-05

P59	0.015	uSv/a
------------	--------------	-------

Public Dose Data
ADULT RESIDENT

Dose Calculation	2023 μSv
%2021 DRL (gaseous emissions)	0.503
2023 EMP (no groundwater)	1.217
2023 EMP (groundwater included)	2.060



**Public Dose Data
ADULT RESIDENT**

Stack Emissions

2023 Emissions as %2021 SRBT DRL		
ADULT RESIDENT		
Sample End	% weekly DRL	(uSv)
2023-01-10	0.04	0.0085
2023-01-17	0.03	0.0066
2023-01-24	0.05	0.0096
2023-01-31	0.02	0.0044
2023-02-07	0.02	0.0044
2023-02-14	0.04	0.0084
2023-02-21	0.04	0.0071
2023-02-28	0.05	0.0091
2023-03-07	0.03	0.0061
2023-03-14	0.04	0.0083
2023-03-21	0.05	0.0090
2023-03-28	0.04	0.0078
2023-04-04	0.03	0.0048
2023-04-11	0.01	0.0024
2023-04-18	0.03	0.0063
2023-04-25	0.04	0.0074
2023-05-02	0.05	0.0088
2023-05-09	0.04	0.0075
2023-05-16	0.03	0.0065
2023-05-23	0.03	0.0061
2023-05-30	0.04	0.0075
2023-06-06	0.05	0.0093
2023-06-13	0.04	0.0078
2023-06-20	0.07	0.0126
2023-06-27	0.06	0.0108
2023-07-04	0.04	0.0074
2023-07-11	0.06	0.0114
2023-07-18	0.06	0.0108
2023-07-25	0.04	0.0072
2023-08-01	0.06	0.0117
2023-08-08	0.04	0.0085
2023-08-15	0.04	0.0072
2023-08-22	0.05	0.0087
2023-08-29	0.06	0.0113
2023-09-05	0.06	0.0114
2023-09-12	0.10	0.0189
2023-09-19	0.06	0.0111
2023-09-26	0.07	0.0127
2023-10-03	0.05	0.0101
2023-10-10	0.06	0.0121
2023-10-17	0.12	0.0226
2023-10-24	0.09	0.0169
2023-10-31	0.09	0.0172
2023-11-07	0.07	0.0128
2023-11-14	0.06	0.0114
2023-11-21	0.08	0.0146
2023-11-28	0.07	0.0139
2023-12-05	0.06	0.0111
2023-12-12	0.04	0.0085
2023-12-19	0.09	0.0166
2023-12-26	0.04	0.0075
2024-01-02	0.01	0.0022
Sum (uSv)		0.503
Ave. (%DRL)	0.05	
Annual Dose Est.	0.503 uSv/a	

**Public Dose Data
ADULT RESIDENT
EMP Factors for Dose**

Pathways Analysis of Dose to the Public		per annum
Atmospheric HTO inhalation, immersion	P(i)19, P(e)19	0.471
Surface HTO ingestion	P(i)29	0.843
Surface HTO immersion	P(e)29	0.000
External soil exposure	P39	0.000
Forage & crop ingestion	P49	0.731
Animal produce ingestion	P59	0.015
Aquatic animal ingestion	P69	0.000
Aquatic plant ingestion	P79	0.000
External sediment exposure	P89	0.000
Total (uSv)		2.060 uSv/a
Total without P₂₉ (uSv)		1.217 uSv/a

**Public Dose Data
ADULT RESIDENT
EMP Factors for Dose P19**

P19 is the transfer pathway of exposure to HTO from compartment 1 (Atmosphere) to 9 (dose)

P(i)19 is the pathway of exposure due to inhalation of HTO, and also implicitly captures skin absorption dose P(e)19 as per CSA N288.1-14 Table C.1.

Formula:

$$P(i)19 \text{ (uSv)} = [\text{HTO}]_{\text{air}} \text{ (Bq/m}^3\text{)} \times \text{Inhalation (m}^3\text{)} \times \text{DCF (uSv/Bq)}$$

Calculation:

PAS # (#)	P(i)19 (uSv)	[HTO]air (Bq/m ³)	Volume (m ³)	(uSv/Bq)	(uSv/a)	(uSv/a)	(uSv/a)	Maximum (uSv/a)
1	0.000			3.000E-05				
2	0.000			3.000E-05				
3	0.000			3.000E-05				
4	0.471	1.870	8400.000	3.000E-05	0.471	0.471	0.471	
5	0.000			3.000E-05				
6	0.000			3.000E-05				
7	0.000			3.000E-05				
8	0.000			3.000E-05				
9	0.000			3.000E-05				
10	0.000			3.000E-05				
11	0.000			3.000E-05				
12	0.000			3.000E-05				
13	0.000			3.000E-05				
P(i)19 Sum					0.471	0.471	0.471	0.471 uSv/a

**Public Dose Data
ADULT RESIDENT
EMP Factors for Dose P29**

P29 is the transfer pathway of exposure to HTO from compartment 2 (Surface Water) to 9 (Dose)

P(i)29 is the pathway of exposure due to ingestion of HTO

P(e)29 is the pathway of exposure due to immersion in HTO

Formula:

$$P(i)29 = [HTO] \text{ (Bq/L)} \times \text{Ingestion (L)} \times \text{DCF (uSv/Bq)}$$

Well	P(i)29 (uSv/a)	[HTO]well (Bq/L)	Ingestion (L/a)	DCF (uSv/Bq)	Date	Well 2 (Bq/L)	Well 3 (Bq/L)	Well 5 (Bq/L)	Well 6 (Bq/L)	Well 7 (Bq/L)
2	0.573	26.5	1081.1	2.00E-05	March 8, 2023	26	39	5	6	28
3	0.843	39.0	1081.1	2.00E-05	September 13, 2023	27	NS	4	4	4
5	0.097	4.5	1081.1	2.00E-05	Average	26.5	39.0	4.5	5.0	16.0
6	0.108	5.0	1081.1	2.00E-05						
7	0.346	16.0	1081.1	2.00E-05						
Avg P(i)29		0.394 uSv/annum								

Well 2	185 Mud Lake Road
Well 3	183 Mud Lake Road
Well 5	171 Sawmill Road
Well 6	40987 Highway 41
Well 7	40925 Highway 41

Well 3	P(i)29	0.843	uSv/a
	P(e)29	0.000	uSv/a
	P29	0.843	uSv/a

P(e)29 is the pathway of exposure to HTO due to immersion in surface water, and is negligible.

**Public Dose Data
ADULT RESIDENT
EMP Factors for Dose P49**

P49 is the pathway for exposure to HTO due to ingestion of forage and crops.

Produce Sample Results (Bq free water tritium / kg fresh weight)														
Source	Farm Gate Market 11133 Round Lake Road					Residences								
Type	Tomato	Potato	Beet	Onion	Average	LOCATION	Cucumber	Green Onion	Beans	Tomatoes	Carrots	Zucchini	Rhubarb	Average
	3	5	4	3	3.8	611 MOSS DRIVE	99	461						280.0
						171 SAWMILL ROAD	9		8	8	6			7.8
						632 JOHNSON CRES.				60		48	68	58.7
					3.8	Average	54	461	8	34	6	48	68	38.0
Produce Sample Results (Bq organically bound tritium / kg fresh weight)														
OBT	0.3				0.3	408 BOUNDARY ROAD		2		2				2.0
Produce Consumption														
100% =	413.300 kg/a	[HTO] (Bq/kg)	(Bq/a)	[OBT] (Bq/kg)	(Bq/a)									
70%	289.310 kg/a	3.8	1084.91	0.3	86.79									
30%	123.990 kg/a	280.0	34717.20	2.0	247.98									

$P49 = [HTO \text{ or } OBT]_{produce} (Bq/kg) \times Produce \text{ Ingested } (kg/mo) \times DCF (uSv/Bq)$

P49 (uSv/a)	[HTO] pro (Bq/a)	DCF (uSv/Bq)	[OBT] pro (Bq/a)	DCF (uSv/Bq)
0.731	35802.11	2.00E-05	334.77	4.60E-05

P49	0.731	uSv/a
-----	-------	-------

**Public Dose Data
ADULT RESIDENT
EMP Factors for Dose P59**

P59 is the exposure to HTO due to ingestion of animal produce.

Local Producer	
	(Bq/L)
1	4.00
2	4.00
Average	4.00

Local Distributor	
	(Bq/L)
1	4.00
2	4.00
Average	4.00

TOTAL AVERAGE	4.00	Bq/L
---------------	-------------	------

Milk Density Adjustment		
Milk Average (Bq/L) x Milk density (L/kg)		
Bq/L	L/kg	Bq/kg
4.00	0.97	3.880


Consumption		
kg/da x da/a = kg/a		
(kg/da)	(da/a)	(kg/a)
0.516	365.25	188.5

<i>P59 = [HTO]animal produce (Bq/kg) x Ingestion (kg) x DCF</i>			
P59	[HTO]	Ingested	DCF
(uSv/a)	(Bq/kg)	(kg/a)	(uSv/Bq)
0.015	3.88	188.5	2.00E-05

P59	0.015	uSv/a
------------	--------------	--------------

Public Dose Data
CHILD - 10 YEAR OLD

Dose Calculation	2023 μSv
%2021 DRL (gaseous emissions)	0.553
2023 EMP (no groundwater)	1.177
2023 EMP (groundwater included)	1.647



**Public Dose Data
CHILD - 10 YEAR OLD**

Stack Emissions

2023 Emissions as %2021 SRBT DRL		
CHILD - 10 YEAR OLD		
Sample End	% weekly DRL	(uSv)
2023-01-10	0.05	0.0092
2023-01-17	0.04	0.0073
2023-01-24	0.06	0.0106
2023-01-31	0.03	0.0048
2023-02-07	0.03	0.0049
2023-02-14	0.05	0.0092
2023-02-21	0.04	0.0078
2023-02-28	0.05	0.0100
2023-03-07	0.03	0.0067
2023-03-14	0.05	0.0091
2023-03-21	0.05	0.0098
2023-03-28	0.04	0.0086
2023-04-04	0.03	0.0053
2023-04-11	0.01	0.0027
2023-04-18	0.04	0.0069
2023-04-25	0.04	0.0082
2023-05-02	0.05	0.0097
2023-05-09	0.04	0.0082
2023-05-16	0.04	0.0071
2023-05-23	0.03	0.0067
2023-05-30	0.04	0.0082
2023-06-06	0.05	0.0102
2023-06-13	0.04	0.0086
2023-06-20	0.07	0.0138
2023-06-27	0.06	0.0118
2023-07-04	0.04	0.0081
2023-07-11	0.07	0.0126
2023-07-18	0.06	0.0119
2023-07-25	0.04	0.0079
2023-08-01	0.07	0.0129
2023-08-08	0.05	0.0094
2023-08-15	0.04	0.0079
2023-08-22	0.05	0.0096
2023-08-29	0.07	0.0125
2023-09-05	0.07	0.0125
2023-09-12	0.11	0.0207
2023-09-19	0.06	0.0122
2023-09-26	0.07	0.0139
2023-10-03	0.06	0.0111
2023-10-10	0.07	0.0133
2023-10-17	0.13	0.0248
2023-10-24	0.10	0.0186
2023-10-31	0.10	0.0189
2023-11-07	0.07	0.0141
2023-11-14	0.06	0.0124
2023-11-21	0.08	0.0160
2023-11-28	0.08	0.0153
2023-12-05	0.06	0.0121
2023-12-12	0.05	0.0094
2023-12-19	0.09	0.0182
2023-12-26	0.04	0.0083
2024-01-02	0.01	0.0025
Sum (uSv)		0.553
Ave. (%DRL)	0.06	
Annual Dose Est.	0.553 uSv/a	

**Public Dose Data
CHILD - 10 YEAR OLD
EMP Factors for Dose**

Pathways Analysis of Dose to the Public		per annum
Atmospheric HTO inhalation, immersion	P(i)19, P(e)19	0.558
Surface HTO ingestion	P(i)29	0.470
Surface HTO immersion	P(e)29	0.000
External soil exposure	P39	0.000
Forage & crop ingestion	P49	0.588
Animal produce ingestion	P59	0.031
Aquatic animal ingestion	P69	0.000
Aquatic plant ingestion	P79	0.000
External sediment exposure	P89	0.000
Total (uSv)		1.647 uSv/a
Total without P₂₉ (uSv)		1.177 uSv/a

**Public Dose Data
CHILD - 10 YEAR OLD
EMP Factors for Dose P19**

P19 is the transfer pathway of exposure to HTO from compartment 1 (Atmosphere) to 9 (dose)

P(i)19 is the pathway of exposure due to inhalation of HTO, and also implicitly captures skin absorption dose P(e)19 as per CSA N288.1-14 Table C.1.

Formula:

$$P(i)19 \text{ (uSv)} = [\text{HTO}]_{\text{air}} \text{ (Bq/m}^3\text{)} \times \text{Inhalation (m}^3\text{)} \times \text{DCF (uSv/Bq)}$$

Calculation:

PAS # (#)	P(i)19 (uSv)	[HTO]air (Bq/m ³)	Volume (m ³)	(uSv/Bq)	(uSv/a)	(uSv/a)	(uSv/a)	Maximum (uSv/a)
1	0.000			3.800E-05				
2	0.000			3.800E-05				
3	0.000			3.800E-05				
4	0.558	1.870	7850.000	3.800E-05	0.558	0.558	0.558	
5	0.000			3.800E-05				
6	0.000			3.800E-05				
7	0.000			3.800E-05				
8	0.000			3.800E-05				
9	0.000			3.800E-05				
10	0.000			3.800E-05				
11	0.000			3.800E-05				
12	0.000			3.800E-05				
13	0.000			3.800E-05				
P(i)19 Sum					0.558	0.558	0.558	0.558 uSv/a

**Public Dose Data
CHILD - 10 YEAR OLD
EMP Factors for Dose P29**

P29 is the transfer pathway of exposure to HTO from compartment 2 (Surface Water) to 9 (Dose)

P(i)29 is the pathway of exposure due to ingestion of HTO

P(e)29 is the pathway of exposure due to immersion in HTO

Formula:

$$P(i)29 = [HTO] \text{ (Bq/L)} \times \text{Ingestion (L)} \times \text{DCF (uSv/Bq)}$$

Well	P(i)29 (uSv/a)	[HTO]well (Bq/L)	Ingestion (L/a)	DCF (uSv/Bq)	Date	Well 2 (Bq/L)	Well 3 (Bq/L)	Well 5 (Bq/L)	Well 6 (Bq/L)	Well 7 (Bq/L)
2	0.319	26.5	482.1	2.50E-05	March 8, 2023	26	39	5	6	28
3	0.470	39.0	482.1	2.50E-05	September 13, 2023	27	NS	4	4	4
5	0.054	4.5	482.1	2.50E-05	Average	26.5	39.0	4.5	5.0	16.0
6	0.060	5.0	482.1	2.50E-05						
7	0.193	16.0	482.1	2.50E-05						
Avg P(i)29		0.219 uSv/annum								

Well 2	185 Mud Lake Road
Well 3	183 Mud Lake Road
Well 5	171 Sawmill Road
Well 6	40987 Highway 41
Well 7	40925 Highway 41

Well 3	P(i)29	0.470	uSv/a
	P(e)29	0.000	uSv/a
	P29	0.470	uSv/a

P(e)29 is the pathway of exposure to HTO due to immersion in surface water, and is negligible.

**Public Dose Data
CHILD - 10 YEAR OLD
EMP Factors for Dose P49**

P49 is the pathway for exposure to HTO due to ingestion of forage and crops.

Produce Sample Results (Bq free water tritium / kg fresh weight)														
Source	Farm Gate Market 11133 Round Lake Road					Residences								
Type	Tomato	Potato	Beet	Onion	Average	LOCATION	Cucumber	Green Onion	Beans	Tomatoes	Carrots	Zucchini	Rhubarb	Average
	3	5	4	3	3.8	611 MOSS DRIVE	99	461						280.0
						171 SAWMILL ROAD	9		8	8	6			7.8
						632 JOHNSON CRES.				60		48	68	58.7
					3.8	Average	54	461	8	34	6	48	68	38.0
Produce Sample Results (Bq organically bound tritium / kg fresh weight)														
OBT	0.3				0.3	408 BOUNDARY ROAD		2		2				2.0
Produce Consumption														
100% =	265.200 kg/a	[HTO] (Bq/kg)	(Bq/a)	[OBT] (Bq/kg)	(Bq/a)									
70%	185.640 kg/a	3.8	696.15	0.3	55.69									
30%	79.560 kg/a	280.0	22276.80	2.0	159.12									

$P49 = [HTO \text{ or } OBT]_{produce} (Bq/kg) \times Produce \text{ Ingested } (kg/mo) \times DCF (uSv/Bq)$

P49 (uSv/a)	[HTO] pro (Bq/a)	DCF (uSv/Bq)	[OBT] pro (Bq/a)	DCF (uSv/Bq)
0.588	22972.95	2.50E-05	214.81	6.30E-05

P49	0.588	uSv/a
-----	-------	-------

**Public Dose Data
CHILD - 10 YEAR OLD
EMP Factors for Dose P59**

P59 is the exposure to HTO due to ingestion of animal produce.

Local Producer	
	(Bq/L)
1	4.00
2	4.00
Average	4.00

Local Distributor	
	(Bq/L)
1	4.00
2	4.00
Average	4.00

TOTAL AVERAGE	4.00	Bq/L
---------------	-------------	------

Milk Density Adjustment		
Milk Average (Bq/L) x Milk density (L/kg)		
Bq/L	L/kg	Bq/kg
4.00	0.97	3.880


Consumption		
kg/da x da/a = kg/a		
(kg/da)	(da/a)	(kg/a)
0.875	365.25	319.6

<i>P59 = [HTO]animal produce (Bq/kg) x Ingestion (kg) x DCF</i>			
P59	[HTO]	Ingested	DCF
(uSv/a)	(Bq/kg)	(kg/a)	(uSv/Bq)
0.031	3.88	319.6	2.50E-05

P59	0.031	uSv/a
------------	--------------	--------------

Public Dose Data
INFANT - 1 YEAR OLD

Dose Calculation	2023 μSv
%2021 DRL (gaseous emissions)	0.471
2023 EMP (no groundwater)	1.066
2023 EMP (groundwater included)	1.698



**Public Dose Data
INFANT - 1 YEAR OLD**

Stack Emissions

2023 Emissions as %2021 SRBT DRL		
INFANT - 1 YEAR OLD		
Sample End	% weekly DRL	(uSv)
2023-01-10	0.04	0.0080
2023-01-17	0.03	0.0062
2023-01-24	0.05	0.0090
2023-01-31	0.02	0.0041
2023-02-07	0.02	0.0042
2023-02-14	0.04	0.0079
2023-02-21	0.03	0.0066
2023-02-28	0.04	0.0085
2023-03-07	0.03	0.0057
2023-03-14	0.04	0.0077
2023-03-21	0.04	0.0084
2023-03-28	0.04	0.0073
2023-04-04	0.02	0.0045
2023-04-11	0.01	0.0023
2023-04-18	0.03	0.0059
2023-04-25	0.04	0.0070
2023-05-02	0.04	0.0083
2023-05-09	0.04	0.0070
2023-05-16	0.03	0.0061
2023-05-23	0.03	0.0057
2023-05-30	0.04	0.0070
2023-06-06	0.05	0.0087
2023-06-13	0.04	0.0073
2023-06-20	0.06	0.0118
2023-06-27	0.05	0.0101
2023-07-04	0.04	0.0069
2023-07-11	0.06	0.0107
2023-07-18	0.05	0.0101
2023-07-25	0.03	0.0067
2023-08-01	0.06	0.0110
2023-08-08	0.04	0.0080
2023-08-15	0.03	0.0067
2023-08-22	0.04	0.0081
2023-08-29	0.06	0.0106
2023-09-05	0.06	0.0106
2023-09-12	0.09	0.0178
2023-09-19	0.05	0.0104
2023-09-26	0.06	0.0119
2023-10-03	0.05	0.0094
2023-10-10	0.06	0.0113
2023-10-17	0.11	0.0212
2023-10-24	0.08	0.0158
2023-10-31	0.08	0.0161
2023-11-07	0.06	0.0120
2023-11-14	0.06	0.0106
2023-11-21	0.07	0.0136
2023-11-28	0.07	0.0131
2023-12-05	0.05	0.0104
2023-12-12	0.04	0.0080
2023-12-19	0.08	0.0155
2023-12-26	0.04	0.0071
2024-01-02	0.01	0.0021
Sum (uSv)		0.471
Ave. (%DRL)	0.05	
Annual Dose Est.	0.471 uSv/a	

**Public Dose Data
INFANT - 1 YEAR OLD
EMP Factors for Dose**

Pathways Analysis of Dose to the Public		per annum
Atmospheric HTO inhalation, immersion	P(i)19, P(e)19	0.410
Surface HTO ingestion	P(i)29	0.632
Surface HTO immersion	P(e)29	0.000
External soil exposure	P39	0.000
Forage & crop ingestion	P49	0.586
Animal produce ingestion	P59	0.070
Aquatic animal ingestion	P69	0.000
Aquatic plant ingestion	P79	0.000
External sediment exposure	P89	0.000
Total (uSv)		1.698 uSv/a
Total without P₂₉ (uSv)		1.066 uSv/a

**Public Dose Data
INFANT - 1 YEAR OLD
EMP Factors for Dose P19**

P19 is the transfer pathway of exposure to HTO from compartment 1 (Atmosphere) to 9 (dose)

P(i)19 is the pathway of exposure due to inhalation of HTO, and also implicitly captures skin absorption dose P(e)19 as per CSA N288.1-14 Table C.1.

Formula:

$$P(i)19 \text{ (uSv)} = [\text{HTO}]_{\text{air}} \text{ (Bq/m}^3\text{)} \times \text{Inhalation (m}^3\text{)} \times \text{DCF (uSv/Bq)}$$

Calculation:

PAS # (#)	P(i)19 (uSv)	[HTO]air (Bq/m ³)	Volume (m ³)	(uSv/Bq)	(uSv/a)	(uSv/a)	(uSv/a)	Maximum (uSv/a)
1	0.000			3.800E-05				
2	0.000			3.800E-05				
3	0.000			3.800E-05				
4	0.410	1.870	2740.000	8.000E-05	0.410	0.410	0.410	
5	0.000			3.800E-05				
6	0.000			3.800E-05				
7	0.000			3.800E-05				
8	0.000			3.800E-05				
9	0.000			3.800E-05				
10	0.000			3.800E-05				
11	0.000			3.800E-05				
12	0.000			3.800E-05				
13	0.000			3.800E-05				
P(i)19 Sum					0.410	0.410	0.410	0.410 uSv/a

**Public Dose Data
INFANT - 1 YEAR OLD
EMP Factors for Dose P29**

P29 is the transfer pathway of exposure to HTO from compartment 2 (Surface Water) to 9 (Dose)

P(i)29 is the pathway of exposure due to ingestion of HTO

P(e)29 is the pathway of exposure due to immersion in HTO

Formula:

$$P(i)29 = [HTO] \text{ (Bq/L)} \times \text{Ingestion (L)} \times \text{DCF (uSv/Bq)}$$

Well	P(i)29 (uSv/a)	[HTO]well (Bq/L)	Ingestion (L/a)	DCF (uSv/Bq)	Date	Well 2 (Bq/L)	Well 3 (Bq/L)	Well 5 (Bq/L)	Well 6 (Bq/L)	Well 7 (Bq/L)
2	0.429	26.5	305.7	5.30E-05	March 8, 2023	26	39	5	6	28
3	0.632	39.0	305.7	5.30E-05	September 13, 2023	27	NS	4	4	4
5	0.073	4.5	305.7	5.30E-05	Average	26.5	39.0	4.5	5.0	16.0
6	0.081	5.0	305.7	5.30E-05						
7	0.259	16.0	305.7	5.30E-05						
Avg P(i)29		0.295 uSv/annum								

Well 2	185 Mud Lake Road
Well 3	183 Mud Lake Road
Well 5	171 Sawmill Road
Well 6	40987 Highway 41
Well 7	40925 Highway 41

Well 3	P(i)29	0.632	uSv/a
	P(e)29	0.000	uSv/a
	P29	0.632	uSv/a

P(e)29 is the pathway of exposure to HTO due to immersion in surface water, and is negligible.

**Public Dose Data
INFANT - 1 YEAR OLD
EMP Factors for Dose P49**

P49 is the pathway for exposure to HTO due to ingestion of forage and crops.

Produce Sample Results (Bq free water tritium / kg fresh weight)														
Source	Farm Gate Market 11133 Round Lake Road					Residences								
Type	Tomato	Potato	Beet	Onion	Average	LOCATION	Cucumber	Green Onion	Beans	Tomatoes	Carrots	Zucchini	Rhubarb	Average
	3	5	4	3	3.8	611 MOSS DRIVE	99	461						280.0
						171 SAWMILL ROAD	9		8	8	6			7.8
						632 JOHNSON CRES.				60		48	68	58.7
					3.8	Average	54	461	8	34	6	48	68	38.0
Produce Sample Results (Bq organically bound tritium / kg fresh weight)														
OBT	0.3				0.3	408 BOUNDARY ROAD		2		2				2.0
Produce Consumption														
100% =	124.800 kg/a	[HTO] (Bq/kg)	(Bq/a)	[OBT] (Bq/kg)	(Bq/a)									
70%	87.360 kg/a	3.8	327.60	0.3	26.21									
30%	37.440 kg/a	280.0	10483.20	2.0	74.88									

$P49 = [HTO \text{ or } OBT]_{produce} (Bq/kg) \times Produce \text{ Ingested } (kg/mo) \times DCF (uSv/Bq)$

P49 (uSv/a)	[HTO] pro (Bq/a)	DCF (uSv/Bq)	[OBT] pro (Bq/a)	DCF (uSv/Bq)
0.586	10810.80	5.30E-05	101.09	1.30E-04

P49	0.586	uSv/a
-----	-------	-------

**Public Dose Data
INFANT - 1 YEAR OLD
EMP Factors for Dose P59**

P59 is the exposure to HTO due to ingestion of animal produce.

Local Producer	
	(Bq/L)
1	4.00
2	4.00
Average	4.00

Local Distributor	
	(Bq/L)
1	4.00
2	4.00
Average	4.00

TOTAL AVERAGE	4.00	Bq/L
---------------	-------------	------

Milk Density Adjustment		
Milk Average (Bq/L) x Milk density (L/kg)		
Bq/L	L/kg	Bq/kg
4.00	0.97	3.880

Consumption		
kg/da x da/a = kg/a		
(kg/da)	(da/a)	(kg/a)
0.931	365.25	340.0

P59 = [HTO] animal produce (Bq/kg) x Ingestion (kg) x DCF			
P59	[HTO]	Ingested	DCF
(uSv/a)	(Bq/kg)	(kg/a)	(uSv/Bq)
0.070	3.88	340.0	5.30E-05

P59	0.070	uSv/a
------------	--------------	-------

APPENDIX S

Summary of Outgoing Shipments Containing Radioactive Material

Summary of Outgoing Shipments Containing Radioactive Material

Month	Number of Shipments
January	75
February	62
March	85
April	58
May	49
June	67
July	56
August	60
September	52
October	53
November	69
December	53
TOTAL	739
<i>Average per month</i>	62

Distribution of Outgoing Shipments

Country	Number of Shipments
United States	431
Canada	256
United Kingdom	15
South Korea	7
Netherlands	5
Singapore	4
Mexico	4
Germany	3
Israel	3
Switzerland	3
Australia	2
France	2
Taiwan	2
Brazil	1
Norway	1

APPENDIX T

Summary of Incoming Shipments Containing Radioactive Material

Summary of Incoming Shipments Containing Radioactive Material

Month	Number of Shipments
January	12
February	15
March	17
April	17
May	14
June	17
July	19
August	7
September	26
October	15
November	16
December	12
TOTAL	187
<i>Average per month</i>	16

Distribution of Incoming Shipments

Country	Number of Shipments
United States	155
Canada	16
Singapore	5
Switzerland	2
United Kingdom	2
China	1
France	1
Germany	1
Japan	1
Netherlands	1
New Zealand	1
South Korea	1