



SRB TECHNOLOGIES (CANADA) INC.

320-140 Boundary Road
Pembroke, Ontario, Canada, K8A 6W5
Tel.: (613) 732-0055
Fax: (613) 732-0056
E-Mail: sales@betalight.com
Web: www.betalight.com

FOR IMMEDIATE RELEASE

June 1, 2016

As required under the Public Disclosure Protocol for SRB Technologies (Canada) Inc. (SRBT) we are reporting a minor incident that occurred at our facility on June 1, 2016 at approximately 11:50 am, the facility fire alarm system activated. All personnel were evacuated safely from the facility, and accounted for immediately at the muster point.

The Pembroke Fire Department was automatically dispatched to the facility by way of communication via the facility security system, the first responders arrived within minutes after the alarm sounded.

The fire alarm panel point that was activated corresponded to the facility air compressor room, where no radioactive materials are kept. Upon opening the door to this room, smoke was observed. The compressor was shut down, as well as an air exchange fan. These actions eliminated the source of smoke in the room immediately.

The Pembroke Fire Department and a licensed electrician have determined that the air compressor malfunctioned. A failed belt on the unit was quickly identified as the cause of the smoke that triggered the alarm.

The facility was cleared by the Pembroke Fire Department for staff re-entry and the resumption of normal operations at 12:15 pm. During this event there was no risk to workers, members of the public or the environment.

The CNSC have been notified and a full report will be completed within 21 working days of the event and posted on our website.

One of SRBT's goals is to be transparent, visible and open with our community, our regulators, and our staff.

For more information please contact:

Stephane Levesque
President
SRB Technologies (Canada) Inc.
Tel: (613) 732-0055, Extension #111
Cel: (613) 639-1349
e-mail: stephane@betalight.com